

## Summary of Non-Material Modification Determinations

### **Q#393 – Berrians East Replacement**

Modification to the proposed generator to retire the existing 38.5 MVAR cap bank and replace the existing 547 MVA H65 generator with a new H84 generator with a rating of 600 MVA in order to meet Con Edison's power factor requirements.