



MMU Review of 2021-2030 CRP

Presented by:

Pallas LeeVanSchaick
NYISO Market Monitoring Unit
Potomac Economics

November 17, 2021



Introduction

- The MMU provided comments on the Comprehensive Reliability Plan (CRP) and its implications for market design.
 - ✓ This presentation provides a brief overview of three topics discussed in the memo.
- The CRP finds that the system meets all applicable reliability criteria under base case assumptions for the entire study period.
 - ✓ However, analysis in the CRP demonstrates that NYISO markets could be improved to better signal the value of addressing future reliability needs.

Locational Signals in ICAP Market

- **CRP Finding:** resources at different locations in same capacity zone have different resource adequacy value:
 - ✓ Zones A and B vs. zones C-F
 - ✓ Staten Island vs. rest of Zone J (*after* ConEd LTP projects)
 - ✓ Zone G vs. Zones H-I
- **Implication:** capacity prices do not adequately signal where investment and retirement would be efficient. Leads to:
 - ✓ Premature retirement at high-value locations,
 - ✓ Over-retention at low-value locations, and
 - ✓ Barriers to new entry in the interconnection process.
- **Recommendation:** Implement C-LMP, which considers the marginal value of capacity at more locations.

Market Signals to Integrate Renewables

- **CRP Finding:** State policies will drive major changes in the NYISO system by 2040, including:
 - ✓ Shift to winter peaking system with 56 GW peak load.
 - ✓ Need to balance short and long periods of low intermittent output.
 - ✓ Over 35 GW of CLCPA-compliant, dispatchable, non-duration limited resources needed for reliability.
- **Implication:** It is critical that NYISO markets efficiently signal value of resources that support reliability as load and generation patterns evolve.
 - ✓ Efficient markets will minimize the cost of this transition.
- **Recommendation:** apply marginal capacity accreditation to all resource types, including conventional resources.

Transmission Security in the ICAP Market

- **CRP Finding:** The margin for satisfying transmission security (TS) needs in Zone J is very tight (42 MW by 2031).
 - ✓ NYISO markets should signal how much capacity is needed to satisfy TS needs and value the contribution of each resource.
- NYISO recently updated TSL-based LCR floors in the ICAP market to reflect resource availability from TS analysis.
- However, resources are treated differently in TS analysis and the capacity market:
 - ✓ Wind assumed to provide 0 MW in TS analysis.
 - ✓ SCRs assumed to provide 0 MW under normal conditions in TS analysis.
 - ✓ Conventional generators are treated as fully available in TS analysis.

Transmission Security in the ICAP Market

- **Implication:** The capacity market does not accurately signal resources' value for addressing TS needs.
 - ✓ Assumption that some resource types provide 0 MW for TS is not realistic, causing TSL floors and LCRs to be inflated.
 - ✓ Resources lack incentives to address TS needs:
 - Lack of incentive for SCRs to register as DERs.
 - Lack of new entry may lead to reliability agreements.
- **Recommendation:**
 - ✓ Use reasonable availability assumption for all resources in TS analysis.
 - NYISO has indicated it intends to revisit these assumptions.
 - ✓ Consider discounting payments to suppliers (such as large generators) that cause capacity requirements to increase.



Conclusion

- Overall, we find that the NYISO markets are well-designed and generally provide efficient investment signals.
- We recommend the following improvements to ensure that NYISO markets efficiently address reliability needs:
 - ✓ Implement C-LMP to accurately reflect resource adequacy value at each location.
 - ✓ Implement marginal capacity accreditation for all resource types.
 - ✓ Use reasonable assumptions for all resource types in transmission security analysis.
 - ✓ Consider discounting capacity payments to resources that do not help address transmission security needs.