

2022 RNA Base Case Preliminary MARS Topology

Laura Popa, Manager, Resource Planning

TPAS\ESPG

April 1, 2022

Agenda

- **Preliminary MARS topology changes, compared with the 2021-2030 Comprehensive Reliability Plan (CRP) base case assumptions**
 - This is a preliminary overview of known major changes, and before application of the 2022 RNA 1st pass Base Case inclusion rules

GE MARS and System Topology Background

- The NYISO uses the GE MARS program for assessing the resource adequacy of the NY bulk power system
- The GE MARS program is a probabilistic analysis tool used for calculating expected values of reliability indices such as Loss of Load Expectation (LOLE, days/year) and includes load, generation, and transmission representation. The four external Control Areas interconnected to the NYCA are also modeled
- The transmission system is modeled through transfer limits on the interfaces between pairs of interconnected areas;
 - aka “the topology”
- A graphical representation of the topology is developed and provided as a communication tool

Summary of Changes (compared with the 2021-2032 CRP Base Case and for the 2022 RNA Study Period of 2026-2032)

1. M51, M52, 71 and 72 series reactors assumed in-service starting 2023 and delta impact re-alignment with the 2021 Operations UPNY-ConEd Voltage Study
2. Large loads projects inclusion

M51, M52, 71, 72 Series Reactors Assumptions and UPNY-ConEd Interface Limits Impacts

■ 2020 RNA to CRP (“post-2020RNA”)

- M51, 52, 71, 72 series reactors assumption changed from bypassed to I/S starting 2023 (ConEd’s regulated backstop solution to 2020 Q3 STAR needs)
- The assumed impact on UPNY-ConEd was -750MW (associated delta from the 2020 Operations UPNY-ConEd Voltage Study):
 - UPNY-ConEd pre-AC PPTPs (SY 2021-2023): $7000 - 750 = 6,250$ MW,
 - UPNY-ConEd post-AC PPTPs (SY2024-2030): $7375 - 750 = 6,625$ MW

■ CRP to 2021 Planning Models and the 2022 RNA

- An associating smaller delta (-325MW) when the series reactors on M51, M52, 71, 72 are assumed I/S (and 41, 42, Y49 O/S) starting 2023, aligning with the 2021 Operations Voltage Study UPNY-ConEd [\[link\]](#)
 - UPNY-ConEd pre-AC PPTPs (SY 2022-2023): $7000 - 325 = 6,675$ MW,
 - UPNY-ConEd post-AC PPTPs (SY2024-2030): $7375 - 325 = 7,050$ MW

Large Loads Impacts

- **The following Large Loads were included in the resource adequacy base cases assumptions starting with the 2021 Q3 STAR databases**
 - Q0580 – WNY STAMP
 - Q0776 – Greenidge Load
 - Q0849 – Somerset Load
 - Q0850 – Cayuga Load
 - Q0979 – North Country Data Center (load increase)
- **The MW impact of the large loads will be modeled consistent with the 2022 Gold Book (in progress).**
 - For example, the Dysinger East and Group A MARS interfaces were impacted as shown below, and as modeled for the 2022 Q1 STAR:
 - Dysinger East and Zone A group interfaces MARS limits were reduced in 2026 (and beyond) by 400 MW and 500 MW respectively, to reflect impacts of the forecasted large loads located in Zones A and C
 - Dysinger East $2200-400=1,800\text{MW}$; Group A $2650-500=2,150\text{MW}$
 - To be confirmed based on the 2022 RNA models
- **A preliminary MARS topology is in the assumption matrix document posted for this meeting**

Questions?

Our Mission & Vision



Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation