

# Assumptions Matrix for 2021-2040 System & Resource Outlook Draft for Discussion at April 1, 2022 ESPWG



## **Preliminary Assumptions in Capacity Expansion Model for Policy**

## **Reference Case**

Existing Generation	Consistent with Policy Case production cost simulation database, noting that the model simulates optimal retirement decisions which may differ from production cost database.								
Existing Generation FOM Costs		Fixed O&M costs for existing generators assumed per 2018 documentation for EPA Platform. Chapter 4:  Generating Resources							
Existing Generation Properties	Firm capaci	Firm capacity (i.e., UCAP) values based on 2016-2020 historic values, as used in 2020 RNA base case.							
Energy Demand & Profile	Energy, with  10 Re	n modification  GW BTM-PV  moval of impanothed annu	by 2030 CL	ct for the foll CPA targe ergy storage ation foreca	owing: t, e resource: sts through	s, and	taining th	CPA Case Fore e original foreca	ast for 2040.
	Year	Base Shape	BTM PV	EV El	ectrification A	nnual Energy	Year	Summer Peak	Winter Peak
	2021	149,637	-3,577	612	5,022	151,694	2021	32,111	25,303
	2022	147,128	4,461	878	6,088	149,633	2022	31,978	25,428
	2023	144,774	-5,478	1,176	7,094	147,566	2023	31,785	25,631
	2024	142,723 139,863	-6.487 -7.483	1,543 1,922	8,096 10,402	145,875 144,704	2024 2025	31,590 31,679	25,788 26,491
	2026	138,459	-8,433	2,430	12,731	145,187	2025	32,056	27,258
	2027	137.196	-9.318	3.111	15.131	146.120	2027	32.541	28.343
	2028	136,515	-10.066	3,878	17.587	147,914	2028	33,155	29.410
	2029	135,185	-10.684	4.674	20,076	149,251	2029	33.820	30.527
	2030	133,856	-11.068	5,488	22,633	150,909	2030	34,416	31,717
	2031	133,122	-11,325	6,373	25,368	153,538	2031	35,200	33,095
	2032	132,810	-11,526	7,313	28,491	157,088	2032	36,091	34,503
	2033	131,801	-11,694	8,230	33,199	161,536	2033	37,318	36,802
	2034	131,239	-11,846	9,249	38,171	166,813	2034	38,644	39,206
	2035	130,775	-11,983	10,322	43.452	172,566	2035	40,033	41,681
	2036	130,766	-12,100	11,415	48,963	179,044	2036	41,429	44,288
	2037	130,000	-12,204	12,577	54,954	185,327	2037	43,058	47,130
	2038	129,646	-12,300	13,795	61,440	192,581	2038	44,738	50,350
	2039 2040	129,322 129,178	-12,378 -12,454	15,048 16,361	68,243 75,594	200,235 208,679	2039 2040	46,479 48,253	53,641 57,144
	Each year is of the year b	s represented by season (Sp ock per year r	l by 17 load oring, Summ epresents a	blocks. For ner, Fall, Wi period of p	each year nter) and ti eak load h	, 16 of the lo ime of day ( ours. The s	oad blocks overnight easonal/ti	s are represente , morning, afterr me of day block	ed by slicing hours noon, evening) and s are based on
	2018 NREL	<u>ReEDS</u> docu	umentation a	and the pea	k load hou	irs are based	on the in	put hourly load	data.




#### Existing Transmission

Nodal to zonal reduction performed by PLEXOS to create a pipe-and-bubble equivalent model, where intra-zonal lines are collapsed.

Voltage and stability limited interface limits consistent with Policy Case production cost simulation database. Thermally limited pipe limits set to sum of thermal normal ratings of each interface line (N-0 normal limit).

Applicable N-X contingencies modeled explicitly in production cost simulation.



Years	Interface/Interzonal Pipes	+ Limit (MW)	- Limit (MW)	Source
All	DYSINGER EAST	2,700	*	2020 ATR
All	A to C Ties	550	0	2021 CRP limit
All	WEST-CENTRAL	1,475	*	2020 ATR
2021-2024	MOSES-SOUTH	3,050	-1,500	1/2015 Ops study stability limit <sup>1</sup>
2025-2040	MOSES-SOUTH	4,050	-1,500	Tier 4 contract <sup>2</sup>
2021-2023	CENTRAL-EAST (summer)	2,380	-2,380	Operational nomogram <sup>3</sup>
2021-2023	CENTRAL-EAST (winter)	2,615	-2,615	Operational nomogram <sup>3</sup>
2024-2040	CENTRAL-EAST (summer)	3,255	-3,255	Operational nomogram <sup>3</sup>
2024-2040	CENTRAL-EAST (winter)	3,490	-3,490	Operational nomogram <sup>3</sup>
2021-2023	UPNY-CONED	6,150	*	2021 CRP limit
2024-2040	UPNY-CONED	6,525	*	2021 CRP limit
All	DUNWOODI-NYC	*	*	
All	DUNWOODI-LI	*	*	
All	NYC-LI	0	-350	Wheel contract
2027-2040	CLEAN PATH NEW YORK	1,300	-1,300	Tier 4 contracts <sup>4</sup>
2025-2040	CHAMPLAIN HUDSON POWER EXPRESS	1,250	-1,250	Tier 4 contracts <sup>4</sup>



#### New Generation Types

Updated to include units with financial contracts, including state sponsored programs, per firm builds as noted in <a href="Large-scale">Large-scale renewable projects reported by NYSERDA</a>. Specific generation added to the <a href="Contract Case">Contract Case</a> was assumed firm build in the Policy Case.

Updated to include units to support achievement of state and federal policies, per 2021 EIA Energy Outlook. Capacity expansion is limited to the NYCA, where each zone assumes one candidate generator per technology.

Generation types from <u>2021\_EIA\_Energy\_Outlook\_</u> Table 3 assumed in model:

land based wind

offshore wind

utility PV

4-hour battery storage

In addition to the generator types noted above, Dispatchable Emission Free Resource (DEFR) has been added as a candidate technology type for years 2030 and beyond, with additional details below.

### New Generation

Overnight (capital) costs, fixed O&M, and variable O&M costs assumed per 2021 EIA Energy Outlook.

Overnight costs, fixed O&M and variable O&M costs for Dispatchable Emission Free Resource (DEFR) options will represent a range of costs and are still under consideration. Preliminary costs for the Dispatchable Emission Free Resource (DEFR) options are:

Candidate Capacity Expansion Technology	Capital Cost (\$/kW)	Variable O&M Costs (\$/MWh)	Variable O&M Costs Fuel Cost (\$/MWh) (\$/mmBtu)		
High Operating/Low Capital	1,000	16	40	6.37	
Medium Operating/Medium Capital	4,500	9	23	6.37	
Low Operating/High Capital	8,000	2	5	6.37	

Regional multipliers assumed for candidate generators by zone are based on the 2021 EIA Energy Outlook and the Climate Action Council Integration Analysis Assumptions (Accessed Assumptions at https://climate.ny.gov/Climate-Resources December 10, 2021). Regional multipliers assumed for candidate battery storage units are based on the 2021 EIA Energy Outlook and 2021-2025 Demand Curve Reset.

Candidate Technology	Base	Zonal Multiplier for Capital Costs										
Candidate reciniology	Capital	Α	В	С	D	E	F	G	Н	- 1	J	K
Utility PV	1,248	1.05	1.04	1.04	1.01	1.01	1.04	1.20	-	-	-	1.39
Land based wind	1,846	0.98	0.96	1.02	1.06	1.03	1.06	1.14	-	-	-	-
Offshore wind	4,362	-	-	-	-	-	-	-	-	-	1.01	1.01
4-hour battery storage	1,165	1.00	1.00	1.00	1.00	1.00	1.01	1.02	1.02	1.02	1.28	1.10

 $Technological\ optimism factors\ applied\ to\ capital\ costs\ per\ NREL\ \underline{2020-ATB-data}.$ 

Candidate Technology	Technology Optimism Factors by Year							
Candidate reciniology	2020	2025	2030	2035	2040			
Utility PV	1	0.81	0.62	0.59	0.56			
Land based wind	1	0.90	0.79	0.75	0.71			
Offshore wind	1	0.81	0.70	0.63	0.59			
4-hour battery storage	1	0.69	0.56	0.53	0.49			

Formatted: Font color: Red



New Generation Properties	Unit heat rates per 2021 EIA Energy Outlook. The heat rates for the Dispatchable Emission Free Resource (DEFR) option are consistent with the combined cycle technology option in the 2021 EIA Energy Outlook. The Dispatchable Emission Free Resource (DEFR) technologies are modeled as flexible resources with parameters consistent with the combined cycle technology option in the 2021 EIA Energy Outlook.  Linear capacity expansion by technology-zone. Maximum allowable capacities are enforced for applicable
	generator types based on 2040 limitations, per Appendix G: Annex 1: Inputs and Assumptions of the Climate Action Council Draft Scoping Plan.
	The firm capacity (i.e., UCAP) values for the Dispatchable Emission Free Resource (DEFR) option are consistent with the combined cycle technology option, based on default derating factor value from the NERC GADS database.
	Firm capacity values for Land based wind, offshore wind, utility PV, and battery storage units are modeled as having a declining capacity value as a function of that generator type's installed capacity. These values are based on the <a href="2020">2020 Grid in Evolution</a> Study.
New Transmission	Transmission expansion not enabled in PLEXOS as a modeling option.
	New policy-based transmission projects included:
	-NYPA Northern New York Priority Transmission Project
	-Champlain Hudson Power Express
	-Clean Path New York
Capacity Reserve Margin	Capacity reserve margins (IRM and LCRs) for 2021-2022 Capability Year translated to UCAP equivalent for model years, per NYISO ICAP to UCAP translation. The minimum capacity reserve margin for the G-J Locality assumes a 10% reduction in its requirement due to future impacts from AC Transmission.
	Minimum UCAP requirements by capacity zone are as follows:
	NYCA: 110.11% summer, 110.56% winter
	<ul> <li>Zones G-J: 84.43% summer, 83.69% winter model years 2021-2023, 74.43% summer, 73.69% winter model years 2024-2040</li> </ul>
	• Zone J: 78.14% summer, 78.31% winter
	Zone K: 97.85% summer, 95.48% winter
Policy Targets	CLCPA targets and other state policy mandates modeled include:
and Other Model	6 GW BTM-PV by 2025
Constraints	70% renewable energy by 2030
	3 GW energy storage by 2030
	• 10 GW BTM-PV by 2030
	9 GW offshore wind by 2035
	100% emission free by 2040
	As noted above, maximum allowable capacities are enforced for applicable generator types by zone based on 2040 limitations, per <a href="Appendix G: Annex 1: Inputs and Assumptions">Appendix G: Annex 1: Inputs and Assumptions</a> of the Climate Action Council Draft Scoping Plan.

Formatted: Font color: Red

Formatted: Font color: Red