


# WINTER 2001-2002 OPERATING STUDY



November 2001  
*prepared by*  
NYISO Operations Engineering

**NYISO OPERATING STUDY - WINTER 2001-02**

**NOVEMBER 2001**

Prepared by  
Operations Engineering Staff  
New York Independent System Operator, Inc.

And reviewed by  
The NYISO Operating Studies Task Force

NYISO OPERATING STUDY  
WINTER 2001-02

## **TABLE OF CONTENTS**

<b><u>SECTION</u></b>	<b><u>PAGE</u></b>
1. INTRODUCTION	5
2. RECOMMENDATIONS	5
3. SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS	5
4. DISCUSSION	6
Cross-State Limits	7
New York – New England Limits	11
New York – PJM Limits	14
New York – Ontario Limits	14
New York – Quebec Limits	16
5. RESULTS	17

## **APPENDICES**

- A. SCHEDULE OF SIGNIFICANT INTERCHANGES ASSUMED FOR TRANSFER LIMIT STUDIES - WINTER 2001-02
- B. POWER FLOW BASE CONDITIONS
- C. POWER FLOW TRANSCRIPTION DIAGRAMS
- D. RATINGS OF MAJOR TRANSMISSION FACILITIES IN NEW YORK
- E. INTERFACE DEFINITIONS and  
GENERATION CHANGES ASSUMED FOR THERMAL ANALYSIS
- F. SELECTED TLTG RESULTS
- G. TRANSFER LIMIT SENSITIVITY GRAPHS
- H. COMPARISON OF TRANSFER LIMITS:  
WINTER 2001-02 vs. WINTER 2000-01
- I. SUMMARY OF EXISTING STABILITY LIMITS

NYISO OPERATING STUDY  
WINTER 2001-02

## **NYISO OPERATING STUDY - WINTER 2001-02**

### **1. INTRODUCTION**

The following report, prepared by the Operating Studies Task Force (OSTF) at the direction and guidance of the System Operations Advisory Subcommittee (SOAS), highlights the significant results of the thermal analysis completed for the Winter 2001-02 capability period. This analysis indicates that, for the Winter 2001-02 capability period, the New York interconnected bulk power system can be operated reliably in accordance with the "NYSRC Reliability Rules for Planning and Operating the New York State Power System" (September 10, 1999) and the NYISO System Operating Procedures.

### **2. RECOMMENDATIONS**

The following recommendations are presented based on the analysis and results documented in this report.

- 1) System Operators should monitor the critical facilities noted in the enclosed tables, along with other limiting conditions, while maintaining bulk system power transfers within secure operating limits.
- 2) Installed Capacity (ICAP) resources of 36,132 MW are anticipated to be adequate to meet the forecast peak demand of 24,670 MW. The NYISO should have adequate operating reserve during the period.

### **3. SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS**

#### **I. System Representation**

The representation was developed from the NYISO Databank and assumes the forecast winter coincident peak load of 24,670 MW. The other NPCC members and adjacent regions representations were obtained from MEN/VEM Winter 2001-02 Reliability Assessment power flow.

For the Winter 2001-02 peak load period Ravenswood 3 (980 MW) unit is modeled as out of service. The generator output levels for major EHV-connected units are summarized in Appendix B, and are consistent with typical operation for the period. The inter-Area transactions represented in the study base case are summarized in Appendix A, and are consistent with those modeled in the MEN/VEM Winter 2001-02 Reliability Assessment.

Significant changes in the transmission system for this season include:

Dunwoodie – Shore Rd. 345kV (Y50)      Expected return 03/2002

New transmission facilities represented in this study include:

Middletown 345/138kV transformer      Expected in service 11/2001

## **II. Base Study Assumptions**

The Normal and Emergency Criteria thermal limits have been determined by the PTI PSS/e thermal analysis activities (TLTG). The thermal limits presented have been determined for all transmission facilities scheduled in service during the Winter 2001-02 period.

The schedules used in the base case loadflows for this analysis assumed a net flow of 600 MW from PSE&G to Consolidated Edison via the phase-angle-regulating (PAR) transformers controlling the Hudson – Farragut and Linden – Goethals interconnections, and 1000 MW on the South Mahwah – Waldwick circuits from Consolidated Edison to PSE&G, controlled by the PARs at Waldwick. The Branchburg - Ramapo 500 kV (5018) circuit is scheduled in accordance with the "Ramapo Phase Angle Regulator Operating Procedure", December 11, 1987. These schedules are consistent with the scenarios developed in the MAAC-ECAR-NPCC (MEN) Inter-regional Reliability Assessment for Winter 2001-02, and the NERC/MMWG Winter 2001-02 loadflow base case.

Thermal transfer capabilities between New York and adjacent Areas are also determined in this analysis. These transfer limits supplement, but do not change, existing internal operating limits. *There may be facilities internal to each system that may reduce the transfer capability between Areas. Reductions due to these situations are considered to be the responsibility of the respective operating authority.* Some of these potential limitations are indicated in the summary tables by “       Internal” limits, which supplement the “Direct Tie” limits. Transfer conditions within and between neighboring Areas can have a significant effect on inter- and intra-Area transfer capabilities. Coordination of schedules and conditions between Areas is necessary to provide optimal transfer conditions while maintaining the reliability and security of the interconnected systems.

## **4. DISCUSSION**

### **I. Resource Assessment**

*Load and Capacity Assessment*

The forecast peak demand for the Winter 2001-02 capability period is 24,670MW. This forecast is approximately 1.0% above the forecast for Winter 2000-01 capability period, and 1.03% above the all-time New York control area seasonal peak of 24,051 MW, which occurred on January 18, 2000. The Installed Capacity (ICAP) requirement of 36,132 MW, based on the NYSRC 18% reserve requirement, is anticipated to be adequate to meet forecast demand.

### **NYISO Peak Load and Capacity Assessment – Winter 2001-02**


NYISO ICAP Requirement	36132
Net of full-responsibility purchases/sales	0
Scheduled generation outages	1335
Allowance for unplanned outages	4878
<b>Net capacity for load</b>	<b>29919</b>
NYISO Forecast Peak	24670
Operating Reserve Requirement	1800
<b>Available Reserve</b>	<b>5249</b>
<b>Net Margin</b>	<b>3449</b>

The assumed allowance for unplanned outages is an equivalent rate of 13.5% and includes forced outages and deratings based on historical performance of all generation in the New York control area.

## **II. Cross-State Interfaces**

### A. Transfer Limit Analysis

Figure 1 presents a comparison of the Winter 2001-02 thermal transfer limits to Winter 2000-01. Changes in these limits from last year are due to changes in the base case load flow generation and load patterns that result in different pre-contingency line loadings, changes in limiting contingencies, or changes in circuit ratings, or line status. The detailed comparison of Cross-State limits between Winter 2001-02 and 2000-01, with limiting element/contingency descriptions, is located in Appendix H.



**Figure 1 – Cross-State Transfer Limits**

- **Dysinger East** and **West Central** limits have increased by 100 MW and 50 MW respectively.
- **UPNY – ConEd** interface limit has increased 550 MW due to a decrease in the base loading of the Leeds – Pleasant Valley circuits of over 200 MW, return of the Hudson – Farragut 345kV circuit B3402, and slightly lower TDF and ODF.
- **Sprain Brook/Dunwoodie – South** interface limit has decreased 300 MW due to changes in pre-contingency circuit loading. The maintenance outage of Ravenswood 3 (980 MW) results in increased loading on the Dunwoodie – Rainey 345kV circuits and reduced loading on the Sprain Brook – West 49<sup>th</sup> Street 345kV circuits. This results in the thermal limit shifting from the Sprain Brook – West 49<sup>th</sup> Street circuit from last winter to the Dunwoodie – Rainey circuits.
- **Con Edison – LIPA** interface limit has decreased 300MW as a result of the scheduled outage of the Dunwoodie – Shore Road 345kV circuit Y50.
- **Central East** and **Total East** thermal transfer limits have increased; however this will not result in increased overall transfer capability, as both of these interfaces will continue to be limited by voltage and stability performance.

B. Sensitivity Testing

The thermal limits presented in Section 5 were determined using the base conditions and transactions. The effects of various intra- and inter-Area transfers or generation patterns in the system are presented in Appendix G.

Phase angle regulator schedules may vary from day-to-day. Sensitivity analysis for selected interfaces has been included for the Ramapo, St. Lawrence, and Northport interconnections. Graphs showing the sensitivity of the interface limit to the PAR schedule are included in Appendix G.

C. West Woodbourne Transformer

The Total-East interface may be limited at significantly lower transfer levels for certain contingencies that result in overloading of the West Woodbourne 115/69kV transformer. Should the West Woodbourne tie be the limiting facility, it may be removed from service to allow higher Total-East transfers. An overcurrent relay is installed at West Woodbourne to protect for contingency overloads.

D. LIPA Import Analysis

Normal transfer limits were determined using the base case generation dispatch and PAR settings as described in Appendix B. Both normal and emergency limits are dispatch dependant and can vary based on generation and load patterns in the LIPA system.

For emergency transfer limit analysis the ConEd - LIPA PARs were adjusted to allow for maximum transfer capability into LIPA:

ConEd - LIPA PAR Settings for Emergency Conditions

Jamaica - Lake Success	178MW
Jamaica - Valley Stream	75MW
Sprain Brook - East Garden City	(free-flow)
Norwalk Harbor – Northport	0MW

**Dunwoodie – Shore Road 345kV circuit Y50** is scheduled to be out of service for replacement of cable for most of the peak load period and is represented out of service in the study base case and for this analysis of transfers (ConEd – LIPA and New York – New England) into the Long Island load zone. The Y50 outage has a significant impact on the transfer capability between the ConEdison and LIPA systems.

***Norwalk Harbor – Northport 138kV circuit 1385*** – Several times within the last year since being returned to service in July, 2000, the LIPA has not been able to maintain the scheduled power flow on the Norwalk Harbor – Northport 138kV circuit due to angle limitations on the phase angle regulator at Northport. This generally has occurred during periods with low generation on Long Island and high generation in southwest New England. System Operators should closely monitor this situation.


E. Transfer Limits for Outage Conditions

Transfer limits for scheduled outage conditions are determined by the NYISO Scheduling and Market Operations groups. The NYISO real-time Security Constrained Dispatch system monitors the EHV transmission continuously to maintain the secure operation of the interconnected system.

F. Transient Stability Limits

The thermal interface limits in Section 5 do not include the results of transient stability testing. The existing all lines in service and maintenance outage stability interface limits are summarized in Appendix I.

### III. Transfer Capabilities with Adjacent Control Areas



**Figure 2 – Inter-Area Transfer Capabilities**

#### A. New York – ISO New England Analysis

##### 1. New England Capacity Additions

In the New England Control Area, from April 2000 through January 2001, approximately 1,170 MW (winter capability) of new capacity has been added with an additional 1050 MW expected to be in service prior to the start of the Winter 2001-2002 capability period. During the Winter 2001-2002 period, an additional 500 MW of capacity is expected to become available. Since the beginning of the previous winter (2000-2001) capability period, the following new generation has become available or is expected to be available:

Maine Independence	520 MW
Tiverton	250 MW
Rumford	250 MW
Androscoggin	150 MW
Bucksport	180 MW
Millenium	350 MW
Westbrook	520 MW
ANP-Blackstone	500 MW

2. Thermal Analysis

The transfer limits between the NYISO and ISO New England for normal and emergency transfer criteria are summarized in Section 5, Table 2. Referring to Figure 2, above, the transfer capability from NY to NE has decreased by 225 MW due to an increase in the pre-transfer loading of the Greenbush – Reynolds Road 115kV line (toward Reynolds Road), and Pleasant Valley – Long Mountain 345kV line toward NY. This change in loading also results in a 150MW decrease in the NE to NY transfer capability.

3. CHG&E and Northeast Utilities will operate the Smithfield-Falls Village 69kV line (FV/690) normally closed during the winter period. The maximum allowable transfer on this line is 28 MVA, based on limitations in the Northeast Utilities 69 kV system. The FV/690 has over-current protection that will trip the line in the event of an actual overload. This facility will not limit NYISO-ISO-NE transfers.

4. Northport - Norwalk Harbor Cable Flow

As system conditions vary the following may be used to optimize transfer capability between the Areas. Exhibits in Appendix G graphically demonstrate the optimization of transfer capability by regulating the flow on the Northport-Norwalk Harbor tie.

**New York to New England:** With power flowing from New York to New England on the Northport to Norwalk Harbor (1385) cable, potential overloads of the Norwalk Harbor to Rowayton Junction (1867) and the Norwalk Harbor to Rowayton Junction (1880) circuits must be considered as follows:

- The flow from Norwalk Harbor to Rowayton Junction (1867) should not exceed 237 MVA (Normal rating of Norwalk Harbor to

Rowayton Junction (1867).

- The flow from Norwalk Harbor to Rowayton Junction (1880) should not exceed 214 MVA (Normal rating of Norwalk Harbor to Rowayton Junction (1880)).

**New England to New York:** With power flowing from New England to New York on the Norwalk Harbor to Northport (1385) cable, potential overloads of the Trumbull Junction to Weston (1730) circuit must be considered as follows:

- The algebraic sum of the flow from Trumbull Junction to Weston (1730) and 27% of the flow from Pequonnock to Trumbull Junction (1710) and 29% of the flow from Devon to Trumbull Junction (1710) should not exceed 278 MVA (STE rating of Trumbull Junction to Weston (1730)).
- The algebraic sum of the flow from Trumbull Junction to Weston (1730) and 25% of the flow from Pequonnock to Ash Creek (91001) and 21% of the flow from Bridgeport Resco should not exceed 278 MVA (STE rating of Trumbull Junction to Weston (1730)).
- In order to transfer 200 MVA from Norwalk Harbor to Northport, Norwalk Harbor generation should be on.

#### 5. Plattsburgh – Sandbar (PV-20) Circuit

A new phase angle regulating transformer controlling the Plattsburgh, NY, to Sandbar, VT, 115kV circuit (PV-20) was placed in service in February 2001 and normal operating procedures have been restored.

#### 6. Transient Stability Limitations

For certain system configurations, stability performance determines the transfer capability between the Areas. For those instances, the limits have been obtained from the report "1992-1996 NYPP-NEPOOL TRANSFER LIMIT STUDY - OCTOBER 1992." These stability transfer limits are presented in Appendix I.

The stability limits are expressed in terms of the transfer on the "Northern Ties", i.e., excluding flow on the Norwalk Harbor – Northport circuit. Stability limits for transfers from New England to New York are a

function of the New England MW load level, and include the effect of Northfield and Bear Swamp in the generating and pumping mode.

## B. New York - PJM Analysis

### 1. Thermal Analysis

The transfer limits for the New York - PJM interface are summarized in Section 5, Table 3. The comparison with Winter 2000-01 in Figure 2 shows an increase of 275 MW transfer capability toward NY. This is due to the changes in assumed phase angle regulator schedules in Winter 2001-02 and the return of the Hudson – Farragut circuit (B3402) that was out of service in the Winter 2000-01 analysis. For similar reason, the New York to PJM limit has decreased by 175MW.

### 2. Opening of PJM to New York 115 kV Ties as Required

The normal criteria thermal transfer limits presented in Section 5 were determined for an all lines in-service condition. The 115kV interconnections between GPU Energy and New York (Warren - Falconer, North Waverly - East Sayre and Tiffany - Goudey) may be opened in accordance with NYISO and PJM Operating Procedures provided this does not cause unacceptable impact on local reliability in either system. Over-current protection is installed on the Warren - Falconer and the North Waverly - East Sayre 115kV circuits; either of these circuits would trip by relay action for an *actual overload* condition. There is no overload protection on the Laurel Lake - Goudey circuit, however it may be opened by operator action if it imposes an actual or post-contingency overload condition. The results presented in Table 3 include limits that assume one (or more) of these lines removed from service to achieve higher inter-Area transfer capability.

## C. Ontario – New York Analysis

### 1. Thermal Analysis

The thermal limits between the New York ISO and the Independent Market Operator (IMO-Ontario) Areas for normal and emergency transfer criteria are presented in Section 5, Table 4. The New York to Ontario limit has increased 75 MW. The Ontario to New York limit has decreased 400 MW due to increased counter-clockwise pre-contingency flow on the interface.

### 2. Transient Stability Limitations

Transient stability limits for the NYISO - IMO interconnection are reported in "NYPP-OH TRANSIENT STABILITY TESTING REPORT on DIRECT TIE TRANSFER CAPABILITY - OCTOBER 1993." This stability testing is summarized in Appendix I of this report.

3. Ontario – Michigan PARs

Phase Angle Regulating transformers are being installed on the interconnections between Ontario and Michigan:

Lambton – St. Clair 345kV L4D  
Lambton – St. Clair 230kV L51D  
Scott – Bunce Creek 230kV B3N

They are not expected to be operational during the winter period.

4. Generation Rejection for Loss of L33P/L34P-St. Lawrence Ties

The interface limits were determined for a particular load, transmission and generation pattern. When system conditions vary from those forecast in the study, normal interface limits may vary. Generation rejection special protection systems (SPSs) are available at Beauharnois, St. Lawrence/Saunders, and St. Lawrence/FDR to reject generation for the loss of the L33P and/or L34P interconnections. These SPSs can be selected by the Ontario or NYPA (as appropriate) operators consistent with system conditions.

Of the two circuits, L33P is more limiting. At 0 degrees phase shift the limiting STE rating is 465 MVA (voltage regulator rating). The outage distribution factor for the loss of L34P is 0.601 and based on this, the maximum pre-contingency flow on each circuit should not exceed 290 MW. At 40 degrees phase shift the limiting STE rating is 334 MVA (PAR rating). The outage distribution factor for the loss of L34P is 0.462 and based on this, the maximum flow on each circuit should not exceed 228 MW.

D. TransEnergie–New York Interface

Thermal transfer limits between TransEnergie (Hydro-Quebec) and New York are not analyzed as part of this study. Respecting the NYSRC and NYISO operating reserve requirements, the maximum allowable delivery into the NYCA from TE is limited to 1200 MW. Maximum delivery from NYCA to TE is 1000 MW.

**5. SUMMARY OF RESULTS  
TRANSFER LIMIT ANALYSIS**



TABLE 1

NYISO CROSS STATE INTERFACE THERMAL LIMITS-WINTER 2001-02  
ALL LINES I/S

	Dysinger East	West Central	UPNY-ConEd	Sprain Brook Dunwoodie So.	ConEd-LIPA
NORMAL	3375 <sup>(1)</sup>	2550 <sup>(2)</sup>	5175 <sup>(4)</sup>	3300 <sup>(5)</sup>	675 <sup>(7)</sup>
EMERGENCY	3650 <sup>(1)</sup>	2600 <sup>(3)</sup>	5625 <sup>(4)</sup>	3925 <sup>(6)</sup>	925 <sup>(7)</sup>
LIMITING ELEMENT			LIMITING CONTINGENCY		
(1)	Niagara – Rochester (NR2) 345kV	@LTE @STE	1591 MW 1744 MW	L/O	AES/Somerset – Rochester (SR-1) 345kV
(2)	Clay – Edic 345kV	@LTE	1434 MW	L/O	(Breaker failure @ Clay 345kV) Clay – Edic 345kV Clay 345/115kV
(3)	Clay – Edic 345kV	@STE	1434 MW	L/O	Clay – Edic 345kV
(4)	Leeds – Pleasant Valley 345kV	@LTE @STE	1783 MW 1912 MW	L/O	Leeds – Pleasant Valley 345kV
(5)	Dunwoodie - Rainey 345kV	@LTE	871 MW	L/O	(Breaker failure @ Dunwoodie 345kV) Dunwoodie – Rainey 345kV Sprainbrook – Dunwoodie 345kV
(6)	Dunwoodie – Rainey 345kV	@STE	1113 MW	L/O	Dunwoodie – Rainey 345kV
(7)	Sprainbrook – E.G.C. (Y49) 345kV	@NOR	693 MW		Pre-contingency Loading

NOTE: Some transfers may be stability limited. See Appendix I for existing transient stability limits.

TABLE 1.a

NYISO CROSS STATE INTERFACE THERMAL LIMITS-WINTER 2001-02  
ALL LINES I/S

		HQ -> NY @ 400 MW	HQ -> NY @ 0 MW
<b>CENTRAL EAST</b>			
	NORMAL	3275 <sup>(1)</sup>	3175 <sup>(1)</sup>
	EMERGENCY	3500 <sup>(2)</sup>	3225 <sup>(2)</sup>
<b>TOTAL EAST</b>			
	NORMAL	6000 <sup>(1)</sup>	5850 <sup>(1)</sup>
	EMERGENCY	6450 <sup>(2)</sup>	5950 <sup>(2)</sup>
<b>MOSES SOUTH</b>			
	NORMAL	1650 <sup>(3)</sup>	1300 <sup>(3)</sup>
	EMERGENCY	2250 <sup>(4)</sup>	2125 <sup>(5)</sup>
<b>LIMITING ELEMENT</b>		<b>LIMITING CONTINGENCY</b>	
(1)	Oakdale - Fraser 345kV	@LTE	1380 MW
			L/O
			Marcy – Coopers Corners (UCC2-41) 345kV
			Edic – Fraser 345kV
(2)	Clay - Edic 345kV	@STE	1434 MW
			L/O
			Clay – Edic 345kV
(3)	Adirondack – Porter 230kV	@LTE	376 MW
			L/O
			Moses – Massena MMS-1 230kV
			Moses – Massena MMS-2 230kV
(4)	Marcy 765/345 kV	@STE	1654 MW
			L/O
			Marcy 765/345 kV
(5)	Moses – Massena MMS-1 230kV	@STE	1404 MW
			L/O
			Moses – Massena MMS-2 230kV

NOTE: Some transfers may be stability limited. See Appendix I for existing transient stability limits.

TABLE 2.a

NYISO to ISO-NE INTERFACE LIMITS - WINTER 2001-02  
ALL LINES I/S

<b>New York to New England</b>		<b>Northport – Norwalk @ 100MW</b>		
	DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY	
NORMAL	2075 <sup>(1)</sup>	1050 <sup>(3)</sup>	2450 <sup>(5)</sup>	
EMERGENCY	2450 <sup>(2)</sup>	1500 <sup>(3)</sup>	2450 <sup>(5)</sup>	
<b>Northport – Norwalk @ 0 MW</b>				
NORMAL	2300 <sup>(4)</sup>	975 <sup>(3)</sup>	2400 <sup>(5)</sup>	
EMERGENCY	2375 <sup>(2)</sup>	1450 <sup>(3)</sup>	2400 <sup>(5)</sup>	

LIMITING ELEMENT			LIMITING CONTINGENCY		
(1)	Norwalk - Northport (1385) 138kV	@LTE	318 MW	L/O	Pleasant Valley – Long Mtn (398) 345kV
(2)	Hoosick– Bennington 115kV	@STE	159 MW	L/O	Alps – Berkshire (393) 345kV
(3)	Greenbush – Reynolds Rd. (9) 115kV	@LTE @STE	234 MW 278 MW	L/O	New Scotland – Alps (2) 345kV
(4)	Pleasant Valley–Long Mountain (398) 345kV	@LTE	1317 MW	L/O	Millstone #3
(5)	Pratts Junction (8AX) 230/115kV	@STE	215 MW	L/O	Bear Swamp – Harriman - Adams (E131) 115kV

Note: Northport – Norwalk Harbor flow is positive in the direction of transfer.

TABLE 2.b

ISO-NE to NYISO INTERFACE LIMITS - WINTER 2001-02  
ALL LINES I/S

<b>New England to New York</b>		<b>Norwalk – Northport @ 100MW</b>		
		DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY
NORMAL		1525 <sup>(1)</sup>	2425 <sup>(2)</sup>	1900 <sup>(4)</sup>
EMERGENCY		1925 <sup>(1)</sup>	2575 <sup>(3)</sup>	1900 <sup>(4)</sup>

<b>Norwalk – Northport @ 200MW</b>				
NORMAL	1050 <sup>(1)</sup>		2475 <sup>(2)</sup>	2050 <sup>(4)</sup>
EMERGENCY	1450 <sup>(1)</sup>		2625 <sup>(3)</sup>	2050 <sup>(4)</sup>

<b>LIMITING ELEMENT</b>			<b>LIMITING CONTINGENCY</b>		
(1)	Norwalk - Northport (1385) 138kV	@LTE @STE	318 MW 428 MW	L/O	Pleasant Valley – Long Mtn (398) 345kV
(2)	N.Troy – Boyntonville 115kV	@LTE	159 MW	L/O	(Alps Bus Fault) Alps – Berkshire (393) 345kV Alps – Reynolds Rd. 345kV New Scotland – Alps 345kV
(3)	N.Troy – Boyntonville 115kV	@STE	159 MW	L/O	Alps – Berkshire (393) 345kV
(4)	Newtown - Plumtree (1760) 115kV	@STE	335 MW	L/O	Frost Bridge - Long Mountain (352) 345kV Frost Bridge (1X) 345/115 kV

Note: Norwalk Harbor – Northport cable schedule is positive in the direction of transfer

TABLE 3.a

PJM to NYISO INTERFACE LIMITS-WINTER 2001-02  
ALL LINES I/S

<b>PJM to NYISO</b>	<b>DIRECT TIE</b>	<b>NYISO FACILITY</b>	<b>PJM FACILITY</b>
NORMAL	2000 <sup>(1)</sup>		
3-115-O/S	3350 <sup>(2)</sup>		2675 <sup>(3)</sup>
EMERGENCY	3425 <sup>(2)</sup>		3025 <sup>(3)</sup>

<b>LIMITING ELEMENT</b>			<b>LIMITING CONTINGENCY</b>		
(1)	Warren-Falconer (171) 115 kV	@NOR	96 MW		Pre-Contingency Loading
(2)	E. Towanda-Hillside (70) 230kV	@LTE @STE	564 MW 598 MW	L/O	Homer City - Watercure (30) 345kV
(3)	No. Meshoppen 230/115kV	@LTE @STE	172 MW 217 MW	L/O	E. Towanda – No. Meshoppen 230kV

**NOTE:** Emergency Transfer Limits may require line outages as described in Section 4.III. PAR schedules have been optimized for the emergency limits as described in Appendix B. Some transfers may be stability limited. See Appendix I for existing transient stability limits.

TABLE 3.b

NYISO to PJM INTERFACE LIMITS-WINTER 2001-02  
ALL LINES I/S

NYISO to PJM	DIRECT TIE	NYISO FACILITY	PJM FACILITY
NORMAL	1775 <sup>(1)</sup>		
3-115-O/S	2450 <sup>(2)</sup>		2200 <sup>(3)</sup>
EMERGENCY	1925 <sup>(4)</sup>		
3-115-O/S	2500 <sup>(5)</sup>		2400 <sup>(6)</sup> 2675 <sup>(3)</sup>

LIMITING ELEMENT			LIMITING CONTINGENCY		
(1)	E. Sayre - N. Waverly 115kV	@LTE	139 MW	L/O	Grover – E. Towanda 230 kV E. Towanda - Hillside 230 kV E. Towanda 230/115 kV
(2)	E. Towanda – Hillside 230kV	@LTE	564 MW	L/O	Forest – Glade 230kV
(3)	Homer City 345/230 kV	@LTE @STE	779 MW 975 MW	L/O	Homer City 345/230 kV
(4)	E. Sayre - N. Waverly 115kV	@STE	139 MW	L/O	E. Towanda – Hillside 230kV
(5)	E. Towanda – Hillside 230kV	@NOR	512 MW		Pre-contingency loading
(6)	Homer City – Shelocta 230kV	@STE	815 MW	L/O	Erie West – Wayne 345kV Wayne 345/115kV

**NOTE:** Emergency Transfer Capability Limits may have required line outages as described in Section 4.III. PAR schedules have been optimized for the emergency limits as described in Appendix B. Some transfers may be stability limited. See Appendix I for existing transient stability limits.

TABLE 4

NYISO- IMO INTERFACE LIMITS - WINTER 2001-02  
ALL LINES I/S

<b>Ontario to New York</b>	<b>L33/34P @ 0 MW</b>			<b>L33/34P @ 400 MW</b>		
	DIRECT TIE	NYISO FACILITY	IMO FACILITY	DIRECT TIE	NYISO FACILITY	IMO FACILITY
NORMAL	2350 <sup>(1)</sup>	1025 <sup>(2)</sup>	2000 <sup>(3)</sup>	2725 <sup>(1)</sup>	1450 <sup>(2)</sup>	2375 <sup>(3)</sup>
EMERGENCY	2900 <sup>(1)</sup>	1325 <sup>(2)</sup>		3275 <sup>(1)</sup>	1750 <sup>(2)</sup>	

<b>New York to Ontario</b>	<b>L33/L34P @ 0 MW</b>			<b>L33/34P @ 200 MW</b>	
	NORMAL	1625 <sup>(4)</sup>	1350 <sup>(6)</sup>	1825 <sup>(4)</sup>	1550 <sup>(6)</sup>
EMERGENCY	1950 <sup>(5)</sup>		2050 <sup>(7)</sup>	2150 <sup>(5)</sup>	2250 <sup>(7)</sup>

<b>LIMITING ELEMENT</b>				<b>LIMITING CONTINGENCY</b>	
(1)	Beck - Niagara 230kV (PA27)	@LTE @STE	540 MW 685 MW	L/O	Beck - Niagara (PA302) 345kV
(2)	Niagara - Rochester (NR-2) 345kV	@LTE @STE	1744 MW 1686 MW	L/O	AES/Somerset - Rochester (SR-1) 345kV
(3)	Middleport – Neal Jct 220kV (Q25BM)	@LTE	569 MW	L/O	Beck- Hannon-Middleport (Q24HM) 220kV Beck-Neal Jct-Burlington (Q23BM) 220kV
(4)	Beck - Niagara (PA27) 230kV	@LTE	540 MW	L/O	(Breaker failure @ Niagara 345kV) Beck – Niagara (PA301) 345 kV Niagara 345/230 kV
(5)	Beck - Niagara 230kV (PA27)	@NOR	480 MW		Pre-Contingency Loading
(6)	Beck – Middleport 220kV (Q30HM)	@LTE	515 MW	L/O	Beck- Hannon-Nebo-Middleport(Q24HM) 220kV Beck- Hannon-Nebo-Middleport(Q29HM) 220kV
(7)	Beck – Middleport 220kV (Q30HM)	@NOR	455 MW		Pre-Contingency Loading

**NOTE:** Some transfers may be stability limited. See Appendix I for existing transient stability limits.

## APPENDIX A

### SCHEDULE OF SIGNIFICANT INTERCHANGES ASSUMED FOR TRANSFER LIMITS STUDIES

WINTER 2001-02



**SCHEDULE OF NET INTERCHANGES**

**NYISO Operating Study – Winter 2001-02**  
**Appendix A**

<b>TO</b>	<b>NYISO</b>	<b>PJM</b>	<b>IMO</b>	<b>ISONE</b>	<b>NB/NS</b>	<b>ECAR</b>	<b>HQ</b>	<b>TOTAL EXPORT+ IMPORT-</b>
<b>FROM</b>								
<b>NYISO</b>		-392	0	123	0	82	0	-187
<b>PJM</b>	392		0	0	0	-118	0	274
<b>IMO</b>	0	0		0	0	0	-500	-500
<b>ISONE</b>	-123	0	0		-600	0	-750	-1473
<b>NB/NS</b>	0	0	0	600		0	0	600
<b>ECAR</b>	-82	118	0	0	0		0	-36
<b>HQ</b>	0	0	500	750	500	0		1750

**APPENDIX A**  
**SUMMARY OF Winter 2001-02 BASE TRANSFERS**

<b>NEW BRUNSWICK/NOVA SCOTIA</b>	
New Brunswick to Hydro-Quebec: Madawaska and Eel River HVdc	-500
New Brunswick to New England.	600
<b>Total Export (+) / Import (-)</b>	<b>100</b>
<b>NEW ENGLAND</b>	
New England to New Brunswick.	-600
New England to Hydro-Quebec: Sandy Pond and Highgate HVdc	-750
New England to New York.	-123
<b>Total Export (+) / Import (-)</b>	<b>-1473</b>
<b>NEW YORK ISO</b>	
New York to Hydro Quebec	0
New York to New England (NYPA to VELCO)	123
New York to PJM: NYPA to PA-RECS	94
New York to PJM. (Sithe Allegheny)	-36
New York to ECAR: NYPA to AMP- Ohio	82
New York to IMO (Ontario)	0
New York to PJM. (Non-Firm Energy)	-450
<b>Total Export (+) / Import (-)</b>	<b>-187</b>

<b>IMO (Ontario)</b>	
IMO (Ontario) to Hydro-Quebec.	-500
IMO (Ontario) to New York	0
IMO (Ontario) to MECS (DECO)	0
IMO (Ontario) to MAPP	-200
<b>Total Export (+) / Import (-)</b>	<b>-700</b>

**APPENDIX A**  
**SUMMARY OF Winter 2001-02 BASE TRANSFERS**

<b>PJM</b>	
PJM to New York: NYPA to PA-RECS	-94
PJM to New York. ( Sithe Allegheny to NYSEG)	36
PJM to New York: (Non Firm Energy)	450
PJM to VACAR.	0
PJM to ECAR.( DLCO to PEPCO)	0
PJM to ECAR.( FE to PEPCO)	- 450
PJM to ECAR.( HE to PECO)	0
PJM to FE. (Seneca Pumped Hydro)	332
<b>Total Export (+) / Import (-)</b>	<b>274</b>

<b>HYDRO-QUEBEC</b>	
Hydro-Quebec to Brunswick. Madawaska and Eel River HVdc	500
Hydro-Quebec to New England: Sandy Pond and Highgate HVdc	750
Hydro-Quebec to New York	0
Hydro-Quebec to IMO (Ontario)	500
<b>Total Export (+) / Import (-)</b>	<b>1750</b>

This Page Intentionally Left Blank.

**APPENDIX B**  
**WINTER 2001-02 BASE CASE CONDITIONS**

NYISO OPERATING STUDY  
WINTER 2001-02

A. WINTER 2001-02 Conditions

**GENERATION FACILITIES (LEVEL OF MWS IN CASE)**

The status and dispatch of generation represented in this analysis is listed below.

**NYISO**

Indian Pt #2	926 MW	In Service
Indian Pt #3	1011 MW	In Service
AES/Somerset	522 MW	In Service
Nine Mile Pt #1	626 MW	In Service
Nine Mile Pt #2	1212 MW	In Service
Oswego #5	648 MW	In Service
Oswego #6	0 MW	Out of Service
Albany	371 MW	In Service
Ravenswood (#1 & #2)	649 MW	In Service
Ravenswood #3	0 MW	Out of Service
Roseton 1	344 MW	In Service
Roseton 2	0 MW	Out of Service
Bowline Pt 1	0 MW	Out of Service
Bowline Pt 2	592 MW	In Service
Niagara (1-13)	2420 MW	In Service
St. Lawrence/FDR (17-32)	873 MW	In Service
Poletti	855 MW	In Service
Gilboa	500 MW	In Service
CoGen Tech	645 MW	In Service
J.A. Fitzpatrick	849 MW	In Service
JMC Selkirk II (A,B,C)	221 MW	In Service
Saranac Energy	239 MW	In Service
Sithe	1064 MW	In Service
Ginna	504 MW	In Service

**ISO-NE**

Millstone Point #2	868 MW	In Service
Millstone Point #3	1146 MW	In Service
Vermont Yankee	502 MW	In Service
Northfield 1 & 3	750 MW	In Service
Bear Swamp 1+2	440 MW	In Service
Norwalk Harbor 1+2	162/168 MW	In Service
Seabrook	1150 MW	In Service

**IMO (Ontario)**

Darlington	3720 MW	In Service
Beck 1 & 2	163/1348 MW	In Service
Bruce >B=	3300 MW	In Service
Lambton	1940 MW	In Service
Pickering (A & B)	1080/1620 MW	In Service
Nanticoke	3000 MW	In Service
St. Lawrence/Saunders (1-16)	848 MW	In Service

**PJM**

Peach Bottom #2	1120 MW	In Service
Peach Bottom #3	1119 MW	In Service
Salem #1	0 MW	Out of Service
Salem #2	1120 MW	In Service
Limerick #1	1182 MW	In Service
Limerick #2	1198 MW	In Service
Hope Creek	1100 MW	In Service
Susquehanna #1	1140 MW	In Service
Susquehanna #2	1144 MW	In Service

**HQ HVdc CONVERTER SCHEDULES**

Chateauguay HVdc	0 MW	Out of Service
Sandy Pond HVdc	500 MW	In Service
Highgate HVdc	200 MW	In Service
Madawaska HVdc	250 MW	In Service
Eel River HVdc	250 MW	In Service

**AREA LOADS & LOSSES**

NYISO	25096 MW
ISO-NE	20976 MW
IMO (Ontario)	24604 MW
PJM	43765 MW

**PHASE ANGLE REGULATOR SCHEDULES**

Inghams (CD-ED)	120 MW
Plattsburgh-Sandbar (PV-20)	90 MW
St. Lawrence-Moses L33P	0 MW
St. Lawrence-Moses L34P	0 MW
Norwalk Harbor-Northport	0 MW
Jamaica-Valley Stream	0 MW
Jamaica-Lake Success	0 MW
Hudson-Farragut (B3402)	300 MW
Hudson-Farragut (C3403)	300 MW
Linden-Goethals	0 MW
Waldwick-Hinchmans	310 MW
Waldwick-Fairlawn	300 MW
Waldwick-Hillsdale	330 MW
Ramapo PAR #1 (+ to NY)	265 MW
Ramapo PAR #2 (+ to NY)	265 MW
East Garden City #1	Free-Flow
East Garden City #2	Free-Flow

This Page Intentionally Left Blank.

## APPENDIX C


### POWER FLOW TRANSCRIPTION DIAGRAMS

NYISO OPERATING STUDY  
WINTER 2001-02


## INDEX

<b>System Overview</b>	.....	<b>C-3</b>
<b>Western NYISO</b>	.....	<b>C-4</b>
<b>Eastern NYISO</b>	.....	<b>C-5</b>
<b>Southern NYISO</b>	.....	<b>C-6</b>
<b>Central Hudson</b>	.....	<b>C-7</b>
<b>Consolidated Edison</b>	.....	<b>C-8</b>
<b>LIPA</b>	.....	<b>C-9,10</b>
<b>NYSEG</b>	.....	<b>C-11,12</b>
<b>NMPC</b>	.....	<b>C-13-18</b>
<b>Orange &amp; Rockland</b>	.....	<b>C-19</b>
<b>Rochester</b>	.....	<b>C-20</b>
<b>Beauharnois</b>	.....	<b>C-21</b>
<b>PJM</b>	.....	<b>C-22</b>
<b>PSE&amp;G</b>	.....	<b>C-23</b>
<b>UPNY-ConEdison</b>	.....	<b>C-24</b>


NYISO OPERATING STUDY  
WINTER 2001-02



NYISO OPERATING STUDY  
WINTER 2001-02




	2001/2002 WINTER PEAK BASE CASE TRIAL #3 LEVEL 5, HQNY=0 MW R.O.W. UPDATED 1) WESTERN NYISO FRI, OCT 12 2001 9:37	BUS - VOLTAGE (PU) BRANCH - MW/MVAR EQUIPMENT - MW/MVAR
	KV: ≤138	.230 .345




**2001/2002 WINTER PEAK BASE CASE TRIAL #3**  
**LEVEL 5, HQNY=0 MW R.O.W. UPDATED**  
**2) EASTERN NYISO FRI, OCT 12 2001 9:37**

NYISO OPERATING STUDY  
WINTER 2001-02



 2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HONY=0 MW R.O.W. UPDATED  
3) SOUTHERN NYISO FRI, OCT 12 2001 9:37

NYISO OPERATING STUDY  
WINTER 2001-02





2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
4) CENTRAL HUDSON FRI, OCT 12 2001 9:38

POWER  
TECHNOLOGIES,  
INC.

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR  
KV: ≤ 138 .**\$230** .**\$315**

NYISO OPERATING STUDY  
WINTER 2001-02






 POWER  
TECHNOLOGIES  
INC.®

2001/2002 WINTER PEAK BASE CASE TRIAL #4  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
6) LIPA THU, OCT 25 2001 16:38

100% RATEC  
950 UV 1.050 OV  
≤69 , ≤138 . ≤345

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR

NYISO OPERATING STUDY  
WINTER 2001-02




2001/2002 WINTER PEAK BASE CASE TRIAL #4

LIPA EMERGENCY TRANSFER CASE

7) LIPA EMERGENCY TRANSFER THU, OCT 25 2001 16:38

100% RATEC  
0.950 UV 1.050 DV  
KV: ≤ 69, ≤ 138, ≤ 345


BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR




2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
8) NYSEG FRI, OCT 12 2001 9:39

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR  
KV: ≤35 .≤115 .≤230

NYISO OPERATING STUDY  
WINTER 2001-02



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
9) NYSEG PLATTSBG FRI, OCT 12 2001 9:39  
KV: <38 .#115 .#230  
BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR




2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
10) NMPC SOUTHWEST FRI, OCT 12 2001 9:39

POWER  
TECHNOLOGIES,  
INC.

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR  
KV: ≤23 .535 .115


NYISO OPERATING STUDY  
WINTER 2001-02



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
11) NMPC NORTH FRI, OCT 12 2001 9:40

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR

NYISO OPERATING STUDY  
WINTER 2001-02




2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
12) NMPC BUFFALO FRI, OCT 12 2001 9:40

POWER  
TECHNOLOGIES,  
NEA

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR


NYISO OPERATING STUDY  
WINTER 2001-02



 2001/2002 WINTER PEAK BASE CASE TRIAL #3  
POWER TECHNOLOGIES, INC. LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
13) NMPC ALBANY FRI, OCT 12 2001 9:4

**\$230** BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR


NYISO OPERATING STUDY  
WINTER 2001-02



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
14) NMPC SYRACUSE FRI, OCT 12 2001 9:40

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
KV: ≤ 138 .**1.230** .**3.915**  
EQUIPMENT - MW/MVAR

NYISO OPERATING STUDY  
WINTER 2001-02



 2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
15) NMPC LOCKPORT 115 FRI, OCT 12 2001


15) NMPC LOCKPORT 115 FRI, OCT

**ENC.V**


KV: **≤69** . **\$130** . **\$345** BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR

KV: ≤69    **\$138**    **\$375**    EQUIPMENT - MW/MVAR

Page 10 of 10




NYISO OPERATING STUDY  
WINTER 2001-02



 2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
17) ROCHESTER FRI, OCT 12 2001 9:41  
**POWER TECHNOLOGIES, INC.**

US - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR




## BEAUFARNOIS POWER PLANT REPRESENTATION

2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY= MW R.O.W. UPDATED  
18) BEAU FRI, OCT 12 2001 9:41


US - VOLTAGE (PU)  
RANCH - MW/MVAR  
EQUIPMENT - MW/MVAR

NYISO OPERATING STUDY  
WINTER 2001-02



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
19) PJM FRI, OCT 12 2001 9:41


BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR  
KV: ≤20 .**555** .**5115**



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
20) PSE&G FRI, OCT 12 2001 9:42

BUS - VOLTAGE (PU)  
BRANCH - MW/MVAR  
EQUIPMENT - MW/MVAR  
KV: ≤138 .**\$230** .**\$315**

NYISO OPERATING STUDY  
WINTER 2001-02



2001/2002 WINTER PEAK BASE CASE TRIAL #3  
LEVEL 5, HQNY=0 MW R.O.W. UPDATED  
21) UPNY - CONED FRI, OCT 12 2001 9:42

KV: ≤115 , ≤230 , ≤345



**APPENDIX D**  
**RATINGS OF MAJOR TRANSMISSION FACILITIES**  
**IN NEW YORK**

NYISO OPERATING STUDY  
WINTER 2001-02

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
ADRON B1 - MOSES W	MA-1	348	359	440	782	25269
ADRON B2 - MOSES W	MA-2	348	386	440	784	25270
ALBANY - AIR INDE	8	278	321	368	2817	25496
ALCOA N - GR-TAP1	MAL-6	218	253	291	792	25582
ALCOA-NM - ALCOA N	R8105	206	247	310	786	25202
ALCOA-NM - BRADY	13	128	147	159	787	25230
ALCOA-NM - BRADY	9	159	159	159	820	25230
ALCOA-NM - DENNISON	12	166	191	210	788	25227
ALLENS F - COLTON	3	119	128	152	846	25241
ALPS345 - N.SCOT77	2	1204	1326	1589	993	25217
ALPS345 - REYNLD3	1	459	562	755	994	25587
ANDRWS-4 - DENNISON	5	182	197	248	861	25226
ASTORIAE - CORONA	34186	154	239	387	133	25282
ASTORIAE - CORONA	34185	154	239	387	132	25281
ASTORIAE - CORONA	34184	154	239	387	131	25280
ASTORIAE - CORONA	34183	154	239	387	130	25279
ASTORIAE - CORONA	34182	154	239	387	129	25278
ASTORIAE - HG 1	34052	161	245	393	134	25324
ASTORIAE - HG 4	34051	161	245	393	135	25323
ASTORIAW - HG 2	24054	140	186	186	146	25213
ASTORIAW - HG 3	24053	140	186	186	147	25212
ASTORIAW - HG 5	24051	177	249	480	148	25210
ASTORIAW - HG 6	24052	177	249	480	149	25211
ASTORIAW - QUENBRDG	28241	154	239	387	151	25315
ASTORIAW - QUENBRDG	28242	154	239	387	150	25316
ASTORIAW - QUENBRDG	28243	308	478	645	152	25317
ASTORIAW - QUENBRDG	28244	308	478	645	153	25318
BARRETT - BRRT PH	461	169	259	297	7	25155
BARRETT - VLY STRM	291	233	289	364	9	25312
BARRETT - VLY STRM	292	233	289	364	10	25313
BATAVIA1 - EBAT-107	107	119	128	152	636	25124
BATAVIA1 - NAKR-108	108	130	136	159	647	25125
BATAVIA1 - OAKFLDTP	112	128	136	159	446	25126
BELL-129 - DURZ-129	129	168	185	199	765	69854
BELL-129 - MLPN-129	129	168	185	199	765	69854
BLUE LAK - LAKE RD.	89/993	112	130	137	483	69353
BLUE LAK - RINGWOD6	89/993	112	130	137	483	69353
BORDR115 - FRMGTN-4	977/4	150	179	195	507	25057
BORDR115 - HYATT115	979	129	148	160	506	25106
BOWLINE1 - W.HAV345	67	687	747	747	164	25567
BOWLINE2 - LADENTWN	68	687	747	747	166	25249
BRANCHBG - RAMAPO 5	5018	999	1303	1751	366	25019
BRDGPORT - PETRBORO	5	116	120	145	940	25896
BRDGPORT - TEALL	5	116	120	145	940	25896
BRKHAVEN - HOLBROOK	887	390	435	498	11	25340
BRKHAVEN - RVRHD	864	250	288	322	14	25553
BRKHAVEN - SHOREHAM	861	433	480	586	16	25114
BUCH N - E VIEW1	W93	1720	1890	2401	175	25133
BUCH N - RAMAPO	Y94	1703	1890	2401	178	25184
BUCH S - LADENTWN	Y88	1703	1890	2401	180	25185
BUCH S - MILLWOOD	W98	1493	1680	1902	182	25146
BUCH S - MILLWOOD	W97	1493	1680	1902	181	25247
BURNS 1 - W.HAVERS	530/531	224	260	274	473	68644
BURNS 6 - TALLMAN	59/591	50	104	110	469	68642
CARLE PL - E.G.C.	361	250	288	322	18	25533
CARML115 - UNION115	991/992	215	247	270	190	68885
CATON115 - HICK 115	958/960	102	113	120	574	69341

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE	NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
CLAY	- 9MI PT1	8	1032	1271	1562	839	25167
CLAY	- CLAY	BK#1	308	367	405	826	25387
CLAY	- CLAY	BK#2	308	367	405	827	25421
CLAY	- DEWITT 3	13	1032	1284	1434	835	25168
CLAY	- DUGUID	5	193	213	240	829	25519
CLAY	- HPKNS-11	11	220	239	239	831	25516
CLAY	- HPKNS-11	10	116	120	145	834	25520
CLAY	- PANNELL3	PC-2	1032	1284	1434	768	25050
CLAY	- PANNELL3	PC-1	1032	1284	1434	769	25058
CLAY	- VOLNEY	6	1032	1284	1434	838	25198
CLINTON	- MARSH115	11/12	125	143	154	1012	68794
CLTNCORN	- CLYDE199	971/3	108	128	145	510	25063
CLYDE199	- CLYDE 34	3	125	143	154	509	25221
COBHL115	- COBHIL34	906	40	41	45	513	25426
CODNT115	- ETNA 115	998	227	253	283	515	25734
CODNT115	- MONTR115	982	108	128	144	516	25728
COFFEEN	- E WTRTWN	5	116	119	119	840	25504
COOPC345	- COOPC115	#2	212	266	300	519	25433
COOPC345	- COOPC115	#3	232	296	300	520	25434
COOPC345	- FRASR345	FCC-33	1207	1404	1703	521	25236
COOPC345	- MARCY T1	UCC2-41	1345	1345	1345	2803	25113
CORONA1R	- JAMAICA	18001	161	245	393	185	25285
CORONA2R	- JAMAICA	18002	161	245	393	186	25286
CORTLAND	- LABRADOR	3	125	143	154	855	25894
CORTLAND	- TULLER H	947	108	128	143	631	25059
CROTN115	- UNION115	991/992	215	247	270	190	68885
DELPHI	- LABRADOR	3	125	143	154	855	25894
DELPHI	- OM-FENNR	3	125	143	154	855	25894
DENNISON	- LWRNCE-B	4	182	197	248	796	25225
DENNISON	- LWRNCE-B	4	182	197	248	935	25225
DEWITT 3	- DEWITT 1	2	516	657	796	862	25418
DEWITT 3	- LAFAYTTE	22	1434	1434	1434	866	25174
DUN NO	- DUN SO	99997	226	317	342	194	25532
DUN NO1R	- S CREEK	99031	129	188	290	197	25193
DUN NO2R	- S CREEK	99032	129	188	290	198	25239
DUN SO1R	- E179 ST	99153LM	223	314	396	203	25287
DUNKIRK	- DUNKIRK1	41	139	177	226	657	25386
DUNKIRK	- DUNKIRK1	31	138	173	223	656	25430
DUNKIRK	- GRDNVL2	73	556	637	637	663	25166
DUNKIRK	- GRDNVL2	74	556	637	637	664	25197
DUNWODIE	- DUN NO	W74	352	484	578	195	25209
DUNWODIE	- DUN SO	W73	352	484	578	202	25208
DUNWODIE	- PL VILLE	W89	1720	1976	2265	206	25182
DUNWODIE	- PL VILLW	W90	1720	1976	2265	205	25250
DUNWODIE	- RAINNEY	72	715	817	1081	208	25191
DUNWODIE	- RAINNEY	71	715	817	1081	207	25151
DUNWODIE	- SHORE RD	Y50	400	877	1416	115	25091
DUNWODIE	- SPRBROOK	W75	2384	2708	3247	209	25071
DURZ-130	- SUMIT PK	130	168	181	206	764	69855
DURZ-130	- ZRMN-130	130	168	181	206	764	69855
E FISH I	- FISHKILL	F33	412	445	445	2868	25724
E VIEW1	- EASTVIEW	87874	370	424	424	211	25471
E VIEW1	- SPRBROOK	W79	1720	2214	2657	224	25153
E VIEW2	- EASTVIEW	87873	370	424	424	210	25472
E VIEW2	- MILLWOOD	W82	2293	2708	3236	225	25147
E VIEW2	- SPRBROOK	W64	2293	2708	3236	223	25143
E VIEW3	- EASTVIEW	87872	370	424	424	212	25470

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE	NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
E	VIEW3 - MILLWOOD	W99	2293	2708	3236	222	25255
E	VIEW3 - SPRBROOK	W65	1720	2214	2657	226	25144
E	VIEW4 - EASTVIEW	87871	370	424	424	2835	25373
E	VIEW4 - MILLWOOD	W85	2293	2708	3236	325	25258
E	VIEW4 - SPRBROOK	W78	2293	2708	3236	2834	25346
E.G.C.	- NEWBRGE	462	200	294	396	24	25303
E.G.C.	- NEWBRGE	465	216	311	424	26	25535
E.G.C.	- ROSLYN	362	258	297	332	28	25534
E.G.C.-1	- E.G.C.	BK#2	444	556	761	2860	25552
E.NOR115	- JENN 115	946	80	110	131	530	25729
E.NOR115	- WILET115	945	108	128	145	531	25732
E.SAYRE	- N.WAV115	956	90	124	124	608	25013
E.SPR115	- INGHAM-E	941	80	106	131	536	25061
E.TWANDA	- HILSD230	70	483	531	554	582	25014
E.WALD 1	- ROCK TV1	D	232	265	311	416	69038
E15ST 45	- E13 ST	37375	232	305	321	228	25468
E15ST 45	- FARRAGUT	45	726	882	1258	234	25190
E15ST 45	- W 49 ST	M55	774	866	1291	237	25222
E15ST 46	- E13 ST	37373	225	299	362	230	25465
E15ST 46	- FARRAGUT	46	726	882	1258	236	25251
E15ST 46	- W 49 ST	M54	774	866	1291	235	25228
E15ST 47	- ASTOR345	Q35L	538	621	1476	139	25134
E15ST 47	- E RIVER	44371	240	254	275	217	25459
E15ST 47	- E13 ST	37378	240	305	384	231	25469
E15ST 47	- FARRAGUT	B47	419	683	1124	238	25177
E15ST 48	- ASTOR345	Q35M	538	621	1476	140	25142
E15ST 48	- E13 ST	37376	232	305	321	232	25463
E15ST 48	- FARRAGUT	48	419	683	1124	239	25252
E179 ST	- HG 1	15054	161	245	393	240	25290
E179 ST	- HG 4	15053	161	245	393	241	25289
E179 ST	- HG 6	15055	222	328	480	242	25288
E179 ST	- PK-CITY1	38X01	108	151	189	243	25327
E179 ST	- PK-CITY2	38X02	108	151	189	244	25328
E179 ST	- PK-CITY3	38X03	108	151	189	245	25330
E179 ST	- PK-CITY4	38X04	108	151	189	246	25329
E179 ST	- S CREEK	15032	161	245	393	248	25156
E179 ST	- S CREEK	15031	161	245	393	247	25157
EDIC	- JA FITZP	FE-1	1434	1434	1912	867	25077
EDIC	- MARCY T1	UE1-7	1677	1792	1792	868	25229
EDIC	- N.SCOT77	14	1331	1538	1724	873	25170
EDIC	- PORTER 1	BK#3/10	455	539	679	871	25424
EDIC	- PORTER 1	BK#4/20	505	629	794	870	25454
EDIC	- PORTER 2	BK#2/17	478	562	637	872	25422
ELBRIDGE	- ELBRIDGE	BK#1	470	557	717	874	25448
ELBRIDGE	- LAFAYTTE	17	940	1562	1912	880	25149
ELBRIDGE	- OSWEGO	17	1206	1326	1685	881	25234
ELWOOD 1	- NRTHPRT2	681	352	504	604	33	25544
ELWOOD 2	- NRTHPRT2	678	352	504	604	2863	25543
ERIE E	- S RIPLEY	69	499	607	617	665	25016
ETNA 115	- WILET115	945	108	128	145	540	25731
FARRAGUT	- GOWANUSN	41	618	807	1183	260	25141
FARRAGUT	- GOWANUSS	42	618	807	1183	261	25140
FARRAGUT	- HAE TR1	B43	110	155	195	262	25293
FARRAGUT	- RAINNEY	63	661	758	1081	267	25152
FARRAGUT	- RAINNEY	62	694	791	1097	266	25253
FARRAGUT	- RAINNEY	61	661	758	1081	265	25254
FISHKILL	- PL VILLE	F38/Y86	1839	2606	3105	270	25367

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
FISHKILL - PLTVLLEY	F36	1720	2214	2657	268	25256
FISHKILL - PLTVLLEY	F37	1720	2214	2657	269	25257
FISHKILL - SYLVN115	A/990	232	253	312	376	25066
FISHKILL - WOOD A	F39	1839	2606	3400	271	25368
FOXHLLS1 - GRENSWOOD	29231	154	239	387	276	25321
FOXHLLS2 - GRENSWOOD	29232	154	239	387	278	25322
FR KILLS - FRKILLR2	TA1	275	387	486	283	25457
FR KILLS - FRKILLSR	TB1	272	372	440	284	25458
FR KILLS - GOTHLS N	22	982	1390	1624	285	25137
FR KILLS - GOTHLS S	21	920	1010	1283	286	25138
FR-KILLS - FRKILLR2	21192	275	387	486	2804	25639
FR-KILLS - FRKILLSR	21192	272	372	440	280	25640
FR-KILLS - WILOWBK1	29211	169	271	452	277	25319
FR-KILLS - WILOWBK1	29212	169	271	452	281	25319
FR-KILLS - WILOWBK2	29212	169	271	452	279	25320
FR-KILLS - WILOWBK2	29211	169	271	452	282	25320
FRASR345 - EDIC	EF24-40	1380	1380	1380	2802	25112
FRASR345 - FRASR115	BK#2	305	386	420	2851	25391
FRASR345 - GILB 345	GF5-35	1428	1524	1524	544	25060
FRASR345 - OAKDL345	32	1255	1380	1380	543	25235
FRMGTN-4 - PANNELLI	4	207	247	280	887	25080
GALEVILE - KERHNKMK	MK	33	41	44	425	69391
GALEVILE - MODENA 6	MK	33	41	44	425	69391
GARDV115 - LANGN115	903/904	139	163	183	524	68914
GARDV115 - STOLE115	925	203	226	239	547	25116
GARDV230 - GARDN M6	#6	316	409	420	545	25405
GARDV230 - GARDN M7	#7	204	246	300	546	25435
GARDV230 - GRDNVL2	T8-12	663	739	773	550	25089
GARDV230 - STOLE230	66	474	478	478	549	25180
GERES LK - SOREL-9	9	142	151	185	890	25510
GINNA115 - PANNELLI	912	207	247	285	1074	25260
GLNWWD GT - ROSLYN	364	291	320	372	42	25556
GLNWWD NO - SHORE RD	366	447	499	572	44	25154
GLNWWD SO - CARLE PL	363	291	321	372	19	25554
GLNWWD SO - SHORE RD	365	492	549	630	46	25205
GOETH T - GOETHALS	BKA2253	528	727	817	287	25642
GOTHLS N - GOWANUSN	25	460	683	1022	290	25139
GOTHLS R - GOETH T	BKA2253	528	727	817	287	25642
GOTHLS S - GOWANUSS	26	460	683	1022	291	25571
GOUDY115 - S.OWE115	961	112	131	143	555	25725
GOWANUSN - GOWNUS1T	T2	238	276	328	292	25476
GOWANUSS - GOWNUS2T	T14	238	276	328	293	25475
GOWNUS1R - GRENSWOOD	42232	226	301	409	301	25214
GOWNUS2R - GRENSWOOD	42231	226	301	409	297	25215
GRDNVL2 - GRDNVL1	2	257	280	354	677	25385
GRDNVL2 - GRDNVL1	4	141	183	250	679	25417
GRDNVL2 - GRDNVL1	3	141	182	250	678	25416
GRDNVL2 - SUNY-79	79	566	654	755	690	25165
GRDNVL2 - SUNY-80	80	566	654	755	691	25196
GRENWOOD - VERNON-E	31232	154	239	387	305	25298
GRENWOOD - VERNON-E	31231	154	239	387	304	25299
HAE TR1 - HUDEV E	32077	110	155	195	264	25291
HAE TR3 - HUDEV E	32078	110	155	195	263	25292
HAMLT115 - ELBRIDGE	983	125	143	154	878	69053
HAMLT115 - FARMGTON1	983	125	143	154	884	69138
HAMLT115 - HAMLTN34	1	30	37	56	563	25394
HAR.CORN - W.NYACK	751	65	76	79	478	69314

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
HARRIMAN - SLOSBURG	31/311	112	130	137	479	69318
HILLBURN - RINGWOD6	89/993	112	130	137	483	69353
HILLBURN - SLOSBURG	31/311	112	130	137	479	69318
HILLBURN - TALLMAN	59/591	50	104	110	469	68642
HILSD230 - HILSD M3	BK#3	231	294	336	576	25397
HILSD230 - WATRC230	69	504	584	657	581	25181
HINMN115 - LOCKPORT	100	220	252	280	585	25087
HOLBROOK - NYPAHOLT	888	703	817	935	2927	25542
HOLBROOK - PT JEFF1	886	284	312	373	61	25540
HOLBROOK - RULND RD	882	468	520	623	68	25538
HOLBROOK - WADNGRV1	884	328	392	434	70	25341
HOMER CY - STOLE345	37	605	757	840	630	25036
HOMER CY - WATRC345	30	926	927	927	635	25018
HONK FLS - KERHNKMK	MK	33	41	44	425	69391
HUDAVE E - JAMAICA	702	129	213	366	317	25295
HUDAVE E - JAMAICA	701	129	213	366	316	25294
HUNT - ST.FORES	89/993	112	130	137	483	69353
HUNT - WISNER	89/993	112	130	137	483	69353
HUNTLEY1 - S129-39	38	129	151	185	703	69428
HUNTLEY1 - ZRMN-130	129	168	181	199	705	69426
HUNTLEY2 - PACKARD2	78	556	644	746	707	25164
HUNTLEY2 - PACKARD2	77	556	644	746	706	25195
HUNTLEY2 - SUNY-79	79	566	654	755	708	25127
HUNTLEY2 - SUNY-80	80	566	654	755	709	25128
HURLEY 3 - HURLEY 1	BK 1	419	481	488	431	25419
HURLEY 3 - ROSETON	303	1395	1623	1870	434	25218
HYATT115 - ELBRIDGE	15	129	148	160	587	25109
INGMS-CD - INGHAM-E	2	167	197	239	898	25242
JAMAICA - L SUCSPH	903	238	341	428	78	25090
JAMAICA - V STRM P	901L+M	272	361	441	118	25048
KINTI345 - ROCH 345	SR1-39	1301	1501	1685	624	25073
KNAPPS 6 - LAGRANGE	G	41	44	51	438	69534
LAIDENTWN - RAMAPO	W72	1720	1890	2401	320	25233
LAIDENTWN - W.HAV345	67	1720	2214	2657	321	25248
LAGRANGE - PL.VAL 6	G	41	44	51	438	69534
LAKE RD. - ST.FORES	89/993	112	130	137	483	69353
LAUREL L - GOUDY115	952	108	128	143	556	25012
LCST GRV - NEWBRGE	558	393	466	568	2898	25158
LEEDS 3 - GILB 345	GL-3	1428	1605	1912	1017	25219
LEEDS 3 - N.SCOT77	93	1331	1538	1724	1029	25171
LEEDS 3 - N.SCOT99	94	1331	1538	1724	1028	25203
LOCKPORT - NAKR-108	108	130	136	165	712	25266
LOCKPORT - OAKFLDTP	112	131	144	159	646	25300
LOCKPORT - SHEL-113	113	143	165	180	718	25263
LOCKPORT - SOUR-111	111	131	144	159	717	25262
LOCKPORT - TELRDTP1	107	199	199	199	637	25265
LOCKPORT - TELRDTP1	114	143	165	180	721	25264
LONGTAP - NIAG115E	GV-180	160	166	206	681	25104
LTHSE HL - BLACK RV	6	106	114	134	805	25506
LTHSE HL - E WTRTWN	5	116	119	119	840	25504
MACDN115 - QUAKER	930	60	75	112	594	25093
MALONE - NICHOLVL	3	119	128	152	905	25585
MALONE - WILL 115	WM-1	129	159	175	906	25586
MARCY765 - MARCY T1	MAR-AT2	1488	1793	2338	908	25456
MARCY765 - MARCY T1	MAR-AT1	1488	1654	1654	907	25455
MARCY765 - MASS 765	MSU1	3975	3975	5300	911	25224
MASS 765 - CHATG-NY	MSC7040	3975	3975	5300	825	25301

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
MASS 765 - MASS230A	MAS-AT1	936	1151	1348	912	25665
MASS 765 - MASS230B	MAS-AT2	936	1151	1348	914	25666
MASS230A - MOSES E	MMS1	936	1151	1348	913	25274
MASS230B - MOSES E	MMS2	936	1151	1348	915	25275
MEYER230 - MEYER M4	BK#4	231	294	336	595	25398
MEYER230 - STOLE230	67	430	494	540	598	25064
MILAN - N.CAT. 1	T7	124	138	159	441	69719
MILAN - PL.VAL 1	R10	129	166	206	338	69896
MILLWOOD - MLWD TA	96922	216	307	346	323	25530
MILLWOOD - MLWD TA	96921	205	297	321	322	25531
MILLWOOD - WOOD B	W80	1720	2214	2657	326	25148
MLPN-129 - PACK(S)W	133	168	181	199	465	69854
MLPN-130 - PACK(S)W	130	168	181	206	764	69855
MLPN-130 - SUMIT PK	130	168	181	206	764	69855
MORAI115 - BENET115	966	125	152	179	503	68439
MORTIMER - PTSFD-24	NMP #24	129	148	160	728	25096
MORTIMER - S33 901	901	129	159	159	731	25097
MORTIMER - S33 901	902	123	139	159	1117	25097
MORTIMER - S80 3TR	904	227	251	284	732	25081
MORTIMER - STA 89	NMP#25	114	123	142	729	25095
MORTIMER - SWDN-111	111	129	136	153	723	25347
MOS 115 - GR-TAP1	MAL-6	218	253	291	792	25582
MOS 115 - GR-TAP2	MAL-5	238	275	310	794	25583
MOSES W - MOS 115	SL-AT1	401	490	646	922	25411
MOSES W - MOS 115	SL-AT2	401	490	646	923	25451
MOSES W - MOS 115	SL-AT3	192	240	287	920	25452
MOSES W - MOS 115	SL-AT4	537	598	773	921	25453
MOSES W - WILLIS E	MW-2	349	418	512	927	25188
MOSES W - WILLIS W	MW-1	349	418	512	926	25271
MOUNTAIN - NIAG115E	MT-121	176	211	240	2902	25070
MOUNTAIN - NIAG115E	MT-122	176	211	240	2903	25072
MTNS-120 - NIAG115E	MT-120	176	211	239	733	25135
N.SCOT1 - AIR INDE	8	278	321	368	2817	25496
N.SCOT1 - RTRDM1	13	241	265	318	1041	25494
N.SCOT77 - N.SCOT1	BK#1	458	474	489	1039	25445
N.SCOT99 - GILB 345	GNS-1	1242	1386	1589	1018	25052
N.SCOT99 - MARCY T1	UNS-18	1488	1792	1792	910	25276
N.SCOT99 - N.SCOT1	BK#2	455	461	484	2816	25460
N.WAV115 - CHEMU115	962	112	131	143	577	25726
N.WAV115 - LOUNS115	962	112	131	143	607	25727
NEWBRGE - RULND RD	561	255	294	329	81	25305
NEWBRGE - RULND RD	562	255	294	329	80	25306
NIAG 345 - BECK A	PA302	1070	1322	1714	759	25041
NIAG 345 - BECK B	PA301	1070	1322	1714	758	25040
NIAG 345 - NIAGAR2E	N-AT5	384	479	575	745	25408
NIAG 345 - NIAGAR2E	N-AT3	384	479	575	744	25450
NIAG 345 - NIAGAR2W	N-AT4	767	943	1104	752	25449
NIAG 345 - ROCH 345	NR-2	1793	1793	1793	623	25074
NIAG 345 - KINTI345	38	1793	1793	1793	757	25084
NIAGAR2W - NIAG115E	N-AT1	220	276	288	739	25409
NIAGAR2W - NIAG115W	N-AT2	286	329	400	747	25410
NIAGAR2W - PA27 REG	PA27	400	460	558	756	25025
NRTHPRT1 - NRTHPRT2	BUS / PS2	407	505	570	91	25599
NRTHPRT1 - PILGRIM	679	409	575	604	93	25309
NRTHPRT1 - PILGRIM	677	409	575	604	92	25308
NRTHPRT1 - PILGRIM	672	204	288	353	94	25307
OAKDL230 - OAKDL115	BK#1	275	400	440	609	25400

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
OAKDL345 - LAFAYTTE	4-36	1255	1380	1380	614	25049
OAKDL345 - OAK2M115	BK#3	428	556	600	571	25399
OAKDL345 - OAK3M115	BK#2	428	556	600	610	25401
OAKDL345 - WATRC345	31	926	1076	1076	613	25178
OAKWOOD - SYOSSET	675	269	358	541	96	25547
ONEIDA - PETRBORO	5	116	120	145	940	25896
OSW 3&4 - S OSWEGO	5	209	239	239	952	25508
OSW 3&4 - S OSWEGO	8	400	462	478	953	25509
OSWEGO - OSW 3&4	BK 7	496	552	690	966	25372
OSWEGO - VOLNEY	11	1200	1326	1685	948	25199
OSWEGO - VOLNEY	12	1200	1326	1685	949	25201
OW CRN W - UNVL 9TP	2	116	120	145	450	25067
PACK(N)E - NIAG115E	PK-191	248	299	354	742	25075
PACK(N)E - NIAG115E	PK-192	248	299	354	741	25099
PACK(S)W - NIAG115W	PK-194	248	299	354	750	25100
PACK(S)W - NIAG115W	PK-193	248	299	354	749	25101
PACK(S)W - NIAG115W	PK-195	233	253	335	751	25102
PACKARD2 - BP76 REG	BP76	478	492	569	763	25024
PACKARD2 - NIAGAR2W	PK-62	620	717	841	755	25186
PACKARD2 - NIAGAR2W	PK-61	620	717	841	754	25220
PACKARD2 - PACK(N)E	3	141	182	250	760	25414
PACKARD2 - PACK(S)W	2	106	136	183	761	25383
PACKARD2 - PACK(S)W	4	141	182	250	762	25415
PALMT115 - ANDOVER1	932	78	85	98	615	25094
PALOMA - S OSWEGO	6	114	120	142	903	25513
PALOMA - S OSWEGO	6	116	120	145	954	25513
PANNELL3 - PANNELLI	122 2TR	255	320	330	771	25396
PANNELL3 - PANNELLI	122 1TR	255	320	330	770	25431
PANNELLI - QUAKER	914	207	247	285	1081	25261
PANNELLI - QUAKER	883/889	468	515	654	67	25682
PANNELLI - QUAKER	925	275	300	355	136	25682
PARK TR1 - PARK1REG	R11	215	301	379	330	25649
PARK TR2 - PARK2REG	R12	215	301	379	333	25650
PAWLN115 - SYLVN115	990/994	176	179	179	188	68887
PILGRIM - RULND RD	661	549	549	549	105	25310
PILGRIM - RULND RD	662	549	549	549	104	25311
PL VILLE - PLTVILLE	1	59	67	67	345	25477
PL VILLW - PLTVILLE	2	59	67	67	344	25478
PL VILLW - WOOD A	Y87	1839	2605	3105	352	25132
PL.VAL 1 - PLTVLLEY	BK S1	415	450	450	334	25382
PLAT 115 - T MIL RD	PS-1/B	96	123	150	959	25078
PLAT T#1 - WILLIS E	WP-1	170	203	249	967	25272
PLAT T#4 - WILLIS W	WP-2	170	203	249	956	25273
PLTVLLEY - LEEDS 3	91	1331	1538	1724	347	25054
PLTVLLEY - LEEDS 3	92	1331	1538	1724	348	25056
PLTVLLEY - WOOD B	F30	1720	2214	2657	346	25237
PORTER 1 - ILION	5	116	120	145	896	25232
PORTER 1 - ILION	2	116	120	145	991	25232
PORTER 1 - VALLEY	4	116	120	145	973	25231
PORTER 2 - ADRON B1	AP11	321	353	449	783	25051
PORTER 2 - ADRON B2	AP12	321	353	449	785	25082
PORTER 2 - PORTER 1	2	268	320	338	972	25389
PORTER 2 - PORTER 1	1	268	320	338	971	25423
PORTER 2 - ROTRDM.2	30	440	505	560	974	25173
PORTER 2 - ROTRDM.2	31	439	505	560	975	25194
PTSFD-24 - PANNELLI	24	129	148	160	1079	69863
PTSFD-25 - PANNELLI	25	114	123	142	1080	69862

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
QUENBRDG - VERNON-E	31282	308	478	602	354	25159
QUENBRDG - VERNON-W	31281	312	542	602	353	25160
RAINEY - 8E DUM	36311	215	302	348	358	25296
RAINEY - 8W DUM	36312	215	305	358	359	25297
RAM PAR - RAMAPO	BK4500	545	741	999	2806	25370
RAM PAR - RAMAPO	BK3500	545	741	999	2805	25371
RAMAPO - RAMAPO 1	1300	391	513	567	363	25441
RAMAPO - RAMAPO 1	2300	391	513	567	362	25442
RAMAPO - SMAHWAH1	69	1226	1737	2271	364	25021
RAMAPO - SMAHWAH2	70	1720	1890	2401	365	25259
RAMAPO 5 - RAM PAR	1500	995	1304	1752	360	25656
REYNLD3 - REY. RD.	BK#2	459	562	755	1050	25403
ROBIN230 - NIAGAR2E	RR-64	496	598	704	618	25088
ROBIN230 - ROBIN M1	BK#1	297	367	420	616	25395
ROBIN230 - STOLE230	65	550	637	717	617	25065
ROCH 345 - PANELL3	RP-1	1301	1501	1685	767	25192
ROCH 345 - PANELL3	RP-2	1301	1501	1685	766	25172
ROCH 345 - S80 1TR	BK #1TR	207	247	284	772	25412
ROCH 345 - S80 3TR	BK #3TR	245	296	360	774	25446
ROCK TAV - COOPC345	CRT-34	1464	1793	1793	2800	25110
ROCK TAV - COOPC345	CRT-42	1554	1733	1793	2801	25111
ROCK TAV - ROCK TV1	BK TR	396	445	445	457	25406
ROCK TV1 - SUGARLF	SL/6108	179	196	206	498	25420
ROSETON - FISHKILL	RFK-305	1935	2677	3137	272	25108
RTRDM1 - ROTRDM.2	BK#6	345	375	522	1056	25407
RTRDM1 - ROTRDM.2	BK#7	300	355	402	1057	25392
RTRDM1 - ROTRDM.2	BK#8	326	369	423	1058	25413
S.PER115 - STA 162	T224	125	152	180	625	25062
SANBORNT - NIAG115E	LK-101	233	253	318	713	25267
SARANAC - T MIL RD	PS-1/B	96	123	150	959	25078
SCRIBA - 9M PT 2G	23	1670	1931	2211	981	70513
SCRIBA - 9MI PT1	9	994	1109	1271	980	25359
SCRIBA - JA FITZP	FS-10	1434	1434	1912	900	25076
SCRIBA - VOLNEY	20	1200	1396	1686	978	25204
SCRIBA - VOLNEY	21	1670	1912	1912	979	25314
SHEL-113 - SWDN-113	113	129	149	153	724	25263
SHORE RD - L SUCS	368	208	346	604	76	25150
SHORE RD - L SUCS	367	208	346	604	75	25145
SHORE RD - SHORE RD	BK#2	457	569	731	114	25440
SHORE RD - SHORE RD	BK#1	457	569	731	113	25439
SLEIG115 - QUAKER	NMP #13	150	170	189	621	25079
SMAHWAH1 - S.MAHWAH	258	436	528	602	496	25393
SNBRN102 - NIAG115E	LK-102	233	253	318	743	25103
SOUR-114 - MORTIMER	114	129	149	153	725	25349
SPRBROOK - REACBUS	Y49	660	936	1392	2856	25105
SPRBROOK - TREMONT	X28	452	656	879	373	25175
SPRBROOK - W 49 ST	M52	774	866	1291	375	25223
SPRBROOK - W 49 ST	M51	774	866	1291	374	25053
STATE115 - CLTNCORN	971/3	108	128	145	510	25063
STATE115 - ELBRIDGE	972/5	108	128	145	627	25107
STILV115 - HANCO115	954/955	102	113	120	565	69271
STOLE345 - STOLE115	#4	305	387	420	629	25462
STOLE345 - STOLE115	#3	300	370	420	628	25461
SUGARLF6 - WISNER	89/993	112	130	137	483	69353
TEALL - ONEIDA	2	116	120	145	939	25895
TREMONT - PARK TR1	R11	215	301	379	350	25473
TREMONT - PARK TR2	R12	215	301	379	351	25474

NYISO WINTER 2001-02 OPERATING STUDY  
WINTER ONLINE RATINGS

LINE NAME	LINE_ID	NORMAL	LTE	STE	MGF_NO	PTID
VOLNEY - MARCY T1	VU-19	1434	1793	1912	909	25345
W.HAV345 - W.HAVERS	BK#194	432	558	623	382	25447
W.WDB115 - W.WDBR69	T152	48	50	50	467	25404
WALDA113 - AM.S-182	923	38	39	42	633	25429
WARREN - FALCONER	171	82	120	136	673	25015
WATRC345 - WATRC230	BK#1	452	584	600	634	25402
WHITMAN - ONEIDA	3	125	143	154	855	25894
WILLIS E - WILL 115	WIL-AT1	150	184	216	984	25388
WILLIS W - WILL 115	WIL-AT2	150	184	216	983	25390
WOODA345 - WOODS115	BK#1	327	409	420	384	25437
WOODB345 - WOODS115	BK#2	325	406	420	383	25438
WOODS115 - AMWLK115	996	215	247	275	327	25574
WYANT115 - REY. RD.	13	186	214	237	1052	69928

**APPENDIX E**  
**INTERFACE DEFINITIONS**  
**AND**  
**GENERATION CHANGES ASSUMED**  
**FOR THERMAL ANALYSIS**



NYISO OPERATING INTERFACES & OASIS TRANSMISSION PATHS

<b>CENTRAL EAST</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Edic-New Scotland*	14	345
Marcy-New Scotland*	UNS-18	345
Porter-Rotterdam*	30	230
Porter-Rotterdam*	31	230
*Plattsburgh - Grand Isle	PV-20	115
East Springfield - Inghams*	942	115
Inghams Bus Tie	PAR	115

<b>TOTAL EAST</b>		
<b>Central-Capital/MidHudson</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Coopers-Shoemaker Tap*	CCRT-34	345
Coopers-Rock Tavern*	CCRT-42	345
Edic-New Scotland*	14	345
*Fraser-Gilboa	35	345
Marcy-New Scotland*	UNS-18	345
Porter-Rotterdam*	30	230
Porter-Rotterdam*	31	230
East Springfield - Inghams*	941	115
Inghams Bus Tie	PAR	115
West Woodbourne*115/69	T152	BK

<b>PJM East-Capital/MidHudson</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Branchburg-Ramapo*	5018	500
*Waldwick- S.Mahwah	J3410	345
* Waldwick-S.Mahwah	K3411	345

<b>PJM East-New York City</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Hudson-Farragut*	C3403	345
Hudson-Farragut*	B3402	345
Linden-Goethals*	A2253	230

<b>Adirondack-ISO-NE</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
*Plattsburgh-Grand Isle	PV-20	115

<b>MOSES SOUTH</b>		
<b>Adirondack-Central</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage (kV)</b>
*Massena-Marcy	MSU1	765
*Moses-Adirondack	MA-1	230
*Moses-Adirondack	MA-2	230
*Dennison-Colton	4	115
*Dennison-Colton	5	115
*Alcoa-N. Ogdensburg	13	115
Malone-Colton*	3	115

\* indicates the metered end of circuit

<b>DYSINGER EAST</b>		
<b>Frontier-Genesee</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage (kV)</b>
*AES Somerset-Rochester (Sta 80)	SR-1/39	345
Niagara-Rochester*	NR2	345
*Stolle-Meyer	67	230
Palmiter - Bennett*	932	115
*Lockport-Batavia	107	115
*Lockport-N. Akron	108	115
*Lockport-Oakfield	112	115
*Lockport-Sweden 1	111	115
*Lockport-Sweden 3	113	115
*Lockport-Telegraph	114	115

<b>WEST CENTRAL</b>		
<b>Genesee-Central</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Pannell Road-Clay	PC-1	345
Pannell Road-Clay*	PC-2	345
*Stolle-Meyer	67	230
Palmiter-Bennett*	932	115
Macedon-Quaker*	930	115
*Mortimer-Elbridge	1	115
*Mortimer-Elbridge	2	115
*Pannell-Farmington	4	115
*Station 121-Sleight Road		115
St. 162 - S. Perry	906	115
*Clyde 199-Sleight Rd		115
Clyde 199-Clinton Corn		115
*Farmington (RGE-NMPC)		
(Farmington 34.5/115kV)	#1	34.5/115
(Farmington 34.5/ 115kV)	#4	34.5/115

<b>UPNY-CONED</b>		
<b>Capital/MidHudson-Westchester</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage(kV)</b>
Ladentown-Buchanan South*	Y88	345
*Pleasant Valley-Wood St.	F30	345
*Pleasant Valley-E. Fishkill	F36	345
*Pleasant Valley-E. Fishkill	F37	345
*Pleasant Valley-Millwood	F31	345
*Ramapo-Buchanan North	Y94	345
Roseton-E. Fishkill*	305	345
*Fishkill Plains - Sylvan Lake	A/990	115
East Fishkill *345/115	F33	345
East Fishkill 115/345		115/345

\* indicates the metered end of circuit

**SPRAINBROOK-DUNWOODIE SOUTH**

Name	Line ID	Voltage(kV)
*Dunwoodie-Rainey	71	345
*Dunwoodie-Rainey	72	345
Sprainbrook-Tremont*	28	345
*Sprainbrook-West 49th Street	M51	345
*Sprainbrook-West 49th Street	M52	345
*Lake Success-Jamaica	903	138
*Valley Stream-Jamaica	901L/M	138
*Dunwoodie-Sherman Creek	99031	138
Dunwoodie-Sherman Creek*	99032	138
*Dunwoodie-East 179th Street	99153	138

**NYISO-ISO-NE**

**Adirondack-ISO-NE**

Name	Line ID	Voltage (kV)
*Plattsburgh-Grand Isle	PV-20	115

**Capital/MidHudson-ISO-NE**

*Alps-Berkshire	393	345
*Pleasant Valley-Long Mnt.	398	345
Rotterdam-Bear Swamp*	E205W	230
North Troy-Bennington*	6	115
*Whitehall-Rutland (Velco)	7/K37	115
*Smithfield-Falls Village		69

**Long Island-ISO-NE**

*Northport-Norwalk	1385	138
--------------------	------	-----

**PJM-NYISO**

**PJM East-New York City**

Name	Line ID	Voltage (kV)
Hudson-Farragut*	C3403	345
Hudson-Farragut*	B3402	345
Linden-Goethals*	A2253	230

**PJM West-Central**

*Homer City-Watercure	30	345
E. Towanda-Hillside*	70	230
Tiffany-Goudey*	952	115
*E. Sayre-N. Waverly	956	115

**PJM West-Frontier**

*Homer City-Stolle Road	37	345
Erie South-South Ripley*	69	230
*Warren-Falconer	171	115

**PJM East-Capital/MidHudson**

Branchburg-Ramapo*	5018	500
*Waldwick-S.Mahwah	J3410	345
*Waldwick-S.Mahwah	K3411	345

\* indicates the metered end of circuit

<b>IMO (Ontario)-NYISO</b>		
<b>Ontario East-Adirondack</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage (kV)</b>
St. Lawrence-Moses*	L33P	240
St.Lawrence-Moses*	L34P	230
<b>Ontario South-Frontier</b>		
Beck-Niagara*	PA301	345
Beck-Niagara*	PA302	345
Beck-Niagara*	PA27	230
*Beck-Packard	BP76	230

<b>CONED - LIPA</b>		
<b>Westchester - Long Island</b>		
<b>Name</b>	<b>Line ID</b>	<b>Voltage (kV)</b>
*Dunwoodie-Shore Road	Y50	345
*Sprainbrook-East Garden City	Y49	345
<b>New York City - Long Island</b>		
Jamaica-Valley Stream*	901L/M	138
Jamaica-Lake Success*	903	138

\* indicates the metered end of circuit

GENERATION PARTICIPATION FOR INTERFACES

DYSINGER EAST, WEST CENTRAL

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
80900	LAKEVWG518.0	43.9	1043.9	1000.0	74190	ROSE GN124.0	343.7	263.7	-80.0
					74702	RAV 3	22.0	0.0	-260.0
					74703	AK 2	20.0	350.0	270.0
					74705	AST 4	20.0	300.0	220.0
					74907	NRTPTG2	22.0	350.0	250.0
					74908	NRTPTG3	22.0	350.0	250.0
					79391	BOWLIN2020.0	592.0	472.0	-120.0
					79546	POLETTI	26.0	855.0	675.0
									-180.0

SPRAINBROOK/DUNWODIE SOUTH

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
80900	LAKEVWG518.0	43.9	493.9	450.0	74702	RAV 3	22.0	0.0	-300.0
81422	LENNOXG220.0	525.0	1075.0	550.0	74703	AK 2	20.0	350.0	250.0
					74705	AST 4	20.0	300.0	200.0
					74907	NRTPTG2	22.0	350.0	250.0
					74908	NRTPTG3	22.0	350.0	250.0
					79546	POLETTI	26.0	855.0	555.0
									-300.0

UPNY-CONED

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
80900	LAKEVWG518.0	43.9	243.9	200.0	74302	ER G7	13.2	70.0	0.0
81422	LENNOXG220.0	525.0	925.0	400.0	74702	RAV 3	22.0	0.0	-300.0
81424	LENNOXG320.0	0.0	400.0	400.0	74705	AST 4	20.0	300.0	100.0
					74706	AST 5	20.0	288.1	188.1
					74707	RAV 1	20.0	259.3	109.3
					74907	NRTPTG2	22.0	350.0	-150.0
									-180.0

GENERATION PARTICIPATION FOR INTERFACES

MOSES - SOUTH

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
79513	MOS17-1813.8	74.6	324.6	250.0	74702	RAV 3	22.0	0.0	-50.0
79516	MOS21-2213.8	114.0	364.0	250.0	76641	DUNKGEN413.8	180.0	130.0	-50.0
					77051	HNTLY68G13.8	190.6	140.6	-50.0
					77951	9M PT 1G23.0	626.0	376.0	-250.0
					79546	POLETTI 26.0	855.0	755.0	-100.0

CONED - LONG ISLAND POWER AUTHORITY

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
74190	ROSE GN124.0	343.7	443.7	100.0	74900	BARETG1	20.0	190.0	100.0
74302	ER G7	13.2	70.0	103.3	74907	NRTPTG2	22.0	350.0	230.0
74700	AK 3	22.0	0.0	66.7	74908	NRTPTG3	22.0	350.0	230.0
74705	AST 4	20.0	300.0	333.3	74909	NRTPTG4	22.0	350.0	230.0
74706	AST 5	20.0	288.1	354.8	74942	NYPA108	13.8	105.7	55.7
74707	RAV 1	20.0	259.3	359.3					-50.0
79546	POLETTI	26.0	855.0	955.0					

ONTARIO - NEW YORK

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
81424	LENNOXG320.0	0.0	500.0	500.0	74190	ROSE GN124.0	344.5	194.5	-150.0
81425	LENNOXG420.0	0.0	500.0	500.0	74702	RAV 3	22.0	0.0	-400.0
					76640	DUNKGEN313.8	180.0	130.0	-50.0
					77051	HNTLY68G13.8	190.6	140.6	-50.0
					78955	ALBY STM13.2	370.7	320.7	-50.0
					79547	JAFITZ1G24.0	848.8	548.8	-300.0

NEW YORK - ONTARIO

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->				
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->				
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE
74190	ROSE GN124.0	342.7	492.7	150.0	80898	LAKEVWG216.0	300.0	50.0	-250.0
74193	DANSK G416.1	241.0	391.0	150.0	80899	LAKEVWG116.0	300.0	50.0	-250.0
78955	ALBY STM13.2	370.7	470.7	100.0	81764	NANTICG722.0	500.0	250.0	-250.0
79390	BOWLINE 20.0	0.0	450.0	450.0	81765	NANTICG622.0	500.0	250.0	-250.0
79546	POLETTI 26.0	855.0	1005.0	150.0					

PJM - NYISO

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->					
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->					
BUS	BUS NAME	BASE	SHIFT	CHANGE	BUS	BUS NAME	BASE	SHIFT	CHANGE	
356	PENNTECH13.8	0.0	23.4	23.4	74700	AK 3	22.0	0.0	-206.0	-206.0
1735	PORT 5CT13.8	0.0	117.4	117.4	74702	RAV 3	22.0	0.0	-206.0	-206.0
2901	GG A1&2 13.8	0.0	16.0	16.0	76641	DUNKGEN413.8	180.0	20.0	-160.0	
2902	GG A3&4 13.8	0.0	32.0	32.0	77950	9M PT 2G25.0	1212.0	612.0	-600.0	
2903	GG B5&6 13.8	0.0	16.0	16.0	77952	OSWGO 5G22.0	394.5	-45.5	-440.0	
2904	GG B7&8 13.8	0.0	32.0	32.0	79546	POLETTI 26.0	651.0	263.0	-388.0	
2918	GILCT1&213.8	0.0	36.0	36.0						
2919	GILCT3&413.8	0.0	36.0	36.0						
2922	RRCT3&4 13.8	0.0	86.7	86.7						
2937	O CRK C113.8	0.0	30.0	30.0						
2938	O CRK C213.8	0.0	30.0	30.0						
3150	MTN CK 324.0	246.5	448.9	202.4						
3151	MTN CK 424.0	246.2	449.4	203.2						
4099	DELWARE713.8	0.0	70.1	70.1						
4100	DELWARE813.8	0.0	68.0	68.0						
4113	EDDYSTN324.0	0.0	25.4	25.4						
4283	SCHYLKL113.8	15.0	22.3	7.3						
4961	BERGEN 138	0.0	12.7	12.7						
5044	COGEN TE 138	0.0	1.1	1.1						
5066	KRNY9&1013.0	0.0	92.7	92.7						
5067	KEARNY1113.0	0.0	80.0	80.0						
5075	LINDN1-424.0	0.0	13.3	13.3						
5076	LINDEN 224.0	0.0	10.0	10.0						
5078	LINDEN I26.0	0.0	48.7	48.7						
5120	SEWAREN113.0	71.4	87.7	16.3						
5121	SEWAREN213.0	97.0	107.2	10.2						
5122	SEWAREN313.0	85.6	93.6	8.0						
5906	GOULD G313.8	0.0	32.5	32.5						

5907	N.C	G1-413.8	0.0	45.4	45.4
5908	N.C	G5-813.8	0.0	45.4	45.4
5914	RVRSD	E413.8	0.0	21.6	21.6
5917	WAGNER	G116.5	87.6	113.0	25.4
5920	WAGNER	G424.0	0.0	202.8	202.8
6843	PENWD	4G13.8	36.3	37.4	1.1
6844	PENWD	3G13.8	36.3	37.4	1.1
6845	PENWD	2G13.8	36.3	37.4	1.1
6846	PENWD	1G13.8	36.3	37.4	1.1
7107	CHALK	U424.0	577.9	580.0	2.1

NYISO - PJM

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->						
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->						
BUS	BUS	NAME	BASE	SHIFT	CHANGE	BUS	BUS	NAME	BASE	SHIFT	CHANGE
74195	DANSK	G213.8	50.0	86.0	36.0	601	HOMER	C122.0	620.0	300.0	-320.0
74196	DANSK	G113.8	50.0	81.8	31.8	3149	MTN	CK 218.0	150.0	50.0	-100.0
74352	NARRGT1	A13.8	0.0	43.5	43.5	3150	MTN	CK 324.0	0.0	-460.0	-460.0
74353	NARRGT1	B13.8	0.0	43.5	43.5	4112	EDDYSTN	220.0	0.0	-200.0	-200.0
74358	NARRGT2	A13.8	0.0	43.5	43.5	4192	MDYRN3	-413.8	230.0	30.0	-200.0
74359	NARRGT2	B13.8	0.0	43.5	43.5	4193	MDYRN5	-613.8	220.0	20.0	-200.0
74727	RNYGT4	-713.8	0.0	34.3	34.3	5055	BERGEN	124.0	216.0	96.0	-120.0
74728	RYYGT	81113.8	0.0	37.3	37.3	5167	HUDSON	224.0	620.0	220.0	-400.0
74777	GRNWD1	GT13.0	0.0	67.1	67.1						
74778	GRNWD2	GT13.0	0.0	67.1	67.1						
74786	RNY	2EGT13.0	0.0	31.8	31.8						
74787	RNY	7EGT13.0	0.0	31.8	31.8						
74788	RNY	7WGT13.0	0.0	31.8	31.8						
74789	RNY	9EGT13.0	0.0	31.8	31.8						
74903	SHRHM	GT13.8	0.0	28.1	28.1						
74910	PTJEFG1	13.8	0.0	25.6	25.6						
74911	PTJEFG2	13.8	0.0	25.6	25.6						
74918	HOLT6	-1013.8	250.0	332.0	82.0						
74919	HOLTS1	-513.8	100.0	176.5	76.5						
74920	WADNGRV	313.8	0.0	49.2	49.2						
74932	GLNWDTG	213.8	0.0	28.1	28.1						
74933	GLNWDTG	313.8	0.0	28.1	28.1						
76548	INDEK-OL	115	79.0	127.9	48.9						
76807	AM BRASS	115	62.0	100.5	38.5						
77121	SENECAP	115	44.0	81.3	37.3						
77450	GERES LK	115	159.0	212.4	53.4						
77952	OSWGO	5G22.0	732.5	1260.3	527.8						
77978	ESYR	GT113.2	0.0	22.4	22.4						

78022	FT.	DRUM	115	32.0	63.0	31.0
79391	BOWLIN	2020.0	592.0	805.1	213.1	
79655	ILION	115	54.7	84.0	29.3	
79657	JAMESTWN	13.2	60.0	106.7	46.7	
79995	KAMIN	1313.8	41.0	75.3	34.3	

#### GENERATION PARTICIPATION FOR INTERFACES

##### NEW YORK - NEW ENGLAND

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->						
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->						
BUS	BUS	NAME	BASE	SHIFT	CHANGE	BUS	BUS	NAME	BASE	SHIFT	CHANGE
74190	ROSE	GN124.0	345.0	645.0	300.0	71063	MYST	G7 22.0	425.0	175.0	-250.0
74700	AK 3	22.0	0.0	200.0	200.0	71252	CANAL	G218.0	160.0	-140.0	-300.0
74702	RAV 3	22.0	0.0	100.0	100.0	72868	NWNGT	G124.0	0.0	-250.0	-250.0
74707	RAV 1	20.0	259.3	359.3	100.0	73563	MILL#3	24.0	1146.0	946.0	-200.0
79391	BOWLIN	2020.0	592.0	692.0	100.0						
79546	POLETTI	26.0	855.0	1055.0	200.0						

##### NEW ENGLAND - NEW YORK

<----- STUDY SYSTEM ----->					<----- OPPOSING SYSTEM ----->						
<---- GENERATOR MW ---->					<---- GENERATOR MW ---->						
BUS	BUS	NAME	BASE	SHIFT	CHANGE	BUS	BUS	NAME	BASE	SHIFT	CHANGE
71063	MYST	G7 22.0	425.0	675.0	250.0	74193	DANSK	G416.1	241.0	41.0	-200.0
71252	CANAL	G218.0	160.0	460.0	300.0	74702	RAV 3	22.0	0.0	-200.0	-200.0
72868	NWNGT	G124.0	0.0	250.0	250.0	78955	ALBY	STM13.2	370.7	170.7	-200.0
73563	MILL#3	24.0	1146.0	1346.0	200.0	79546	POLETTI	26.0	855.0	455.0	-400.0

TABLE 1  
DISTRIBUTION FACTORS FOR DYSINGER EAST CIRCUITS

Winter 2001-2002

		% Pickup of Transfer	KINTI-ROCH	NIAGAR-ROCH	STOLLE-MEYER	LOCKPT-SOUR	LOCKPT-SHEL	NIAGAR-ROCH
STOLE230 230	MEYER230 230	1	12.4%	6.1%	7.4%	TRIP	6.8%	6.2%
GOLA66K66.0	MORT66KV66.0	1		0.3%	0.3%	0.3%	0.8%	0.7%
LOCKPORT 115	NAKR-108 115	1	1.4%	1.3%	1.6%	1.5%	4.1%	3.8%
LOCKPORT 115	OAKFLDTP 115	1	1.7%	1.6%	1.9%	1.8%	4.9%	4.5%
LOCKPORT 115	SOUR-111 115	1	3.5%	3.3%	4.0%	3.7%	TRIP	12.1%
LOCKPORT 115	SHEL-113 115	1	3.7%	3.5%	4.2%	3.9%	14.2%	TRIP
LOCKPORT 115	TELRDTP1 115	1	1.7%	1.6%	1.9%	1.8%	6.2%	6.7%
LOCKPORT 115	TELRDTP1 115	1	3.6%	3.4%	4.1%	3.8%	11.7%	19.3%
KINTI345 345	ROCH 345 345	1	29.2%	TRIP	45.5%	15.0%	14.8%	13.4%
NIAG 345 345	ROCH 345 345	1	42.8%	55.0%	TRIP	21.9%	21.7%	19.7%
<hr/>								
***SUB-TOTALS***								
***L33P-L34P***								
***PJM-NYISO***								
<hr/>								
***TOTALS***								
		100.0%	99.6%	99.5%	97.3%	100.2%	100.2%	99.1%

TABLE 2  
DISTRIBUTION FACTORS FOR WEST CENTRAL CIRCUITS

Winter 2001-2002

			% Pickup of Transfer	PANNEL-CLAY	STOLLE-MEYER	S121-SLEIGH	PANNEL-FARM	PANNEL-CLAY
PANNELL3 345	CLAY	345	1	37.5%	TRIP	9.9%	18.8%	20.0% O/S
PANNELL3 345	CLAY	345	2	37.6%	58.1%	9.9%	18.8%	20.1% TRIP
STOLE230 230	MEYER230 230		1	12.4%	2.9%	TRIP	3.0%	7.7% 6.8%
MORTIMER 115	LAWLER-1 115		1	3.1%	2.5%	1.0%	4.0%	16.9% 6.0%
MORTIMER 115	LAWLER-2 115		1	3.2%	2.9%	0.9%	4.6%	4.0% 6.9%
S121 B#2 115	SLEIG115 115		1	2.9%	3.6%	2.0%	TRIP	11.2% 8.5%
PANNELLI 115	FRMGTN-4 115		1	3.4%	6.1%	8.2%	18.1%	TRIP 14.6%
STA 162 115	S.PER115 115		1	-0.3%	2.4%	21.3%	2.4%	6.4% 5.6%
QUAKER 115	MACDN115 115		1	0.3%	0.4%	0.3%	19.9%	2.6% 1.0%
<hr/>			<hr/>			<hr/>		
***SUB-TOTALS***				78.8%	53.5%	89.6%	89.0%	49.5%
***L33P-L34P***				7.6%	8.6%	3.1%	2.4%	18.3%
***PJM-NYISO***				13.4%	35.1%	6.6%	6.7%	31.9%
<hr/>				<hr/>	<hr/>	<hr/>	<hr/>	<hr/>
***TOTALS***				100.0%	99.8%	97.2%	99.2%	98.2% 99.6%

TABLE 3  
DISTRIBUTION FACTORS FOR TOTAL EAST CIRCUITS  
Winter 2001-2002

		% Pickup of Transfer	PORTER- RTRDM	EDIC34- NSCOT	MARCY3- NSCOT	FRASER- GILBA	BRBURG- RAMPO	WALDWK- SMAWA	HUDSON- FARGT	LINDEN- GOETH	WALDWK- SMAWA	HUDSON- FARGT	
EDIC 345	N.SCOT77 345	1	18.3%	13.7%	TRIP	32.6%	19.4%	3.2%	0.2%	1.5%	2.6%	1.5%	2.2%
MARCY T1 345	N.SCOT99 345	1	19.7%	14.5%	34.4%	TRIP	21.0%	3.5%	0.2%	1.6%	2.8%	1.7%	2.4%
PORTER 2 230	ROTRDM.2 230	1	4.3%	TRIP	5.3%	5.4%	3.1%	0.7%	0.0%	0.3%	0.6%	0.3%	0.5%
PORTER 2 230	ROTRDM.2 230	2	4.4%	34.0%	5.5%	5.5%	3.2%	0.8%	0.0%	0.4%	0.6%	0.4%	0.5%
E.SPR115 115	INGHAM-E 115	1	0.9%	0.9%	-0.2%	-0.2%	2.5%	0.2%	0.0%	0.1%	0.1%	0.1%	0.1%
INGMS-CD 115	INGHAM-E 115	1	0.0%	9.8%	3.7%	3.7%	0.7%	0.4%	0.0%	0.2%	0.3%	0.2%	0.3%
PLAT T#3 115	GRAND IS 115	1	1.3%	3.5%	3.1%	3.3%	1.9%	0.8%	0.0%	0.3%	0.5%	0.4%	0.6%
FRASR345 345	GILB 345 345	1	16.4%	9.2%	22.8%	23.4%	TRIP	3.5%	0.2%	2.3%	3.6%	1.3%	3.4%
BRANCHBG 500	RAMAPO 5 500	1	0.0%	1.9%	3.2%	3.3%	3.0%	TRIP	3.0%	7.4%	20.8%	26.3%	11.5%
COOPC345 345	SHOEMTAP 345	1	17.5%	3.8%	6.9%	7.2%	18.3%	4.8%	0.3%	0.3%	1.5%	3.5%	0.4%
COOPC345 345	ROCK TAV 345	2	16.7%	3.8%	6.9%	7.2%	17.6%	4.5%	0.4%	0.4%	1.5%	3.3%	0.7%
HUDSON1 345	FARRGUT1 345	1	0.0%	1.0%	1.7%	1.7%	2.2%	8.5%	2.8%	TRIP	19.5%	25.3%	O/S
HUDSON2 345	FARRGUT2 345	1	0.0%	1.0%	1.7%	1.7%	2.2%	8.5%	2.9%	31.4%	19.9%	25.8%	TRIP
LINDEN 230	GOETHALS 230	1	0.0%	1.0%	1.7%	1.7%	2.0%	13.5%	1.1%	12.3%	TRIP	9.7%	16.1%
WALDWICK 345	SMAHWAH1 345	1	0.2%	0.8%	1.4%	1.4%	1.0%	23.5%	88.9%	21.2%	13.1%	O/S	31.2%
WALDWICK 345	SMAHWAH2 345	1	0.2%	0.8%	1.4%	1.4%	1.1%	23.3%	TRIP	20.4%	12.5%	TRIP	29.9%
<b>***TOALS***</b>			100.0%	99.6%	99.3%	99.3%	99.1%	99.6%	100.0%	99.9%	99.9%	99.8%	99.8%

TABLE 4  
DISTRIBUTION FACTORS FOR UPNY-CONED CIRCUITS

Winter 2001-2002

		% Pickup of Transfer	PLVLLY- MILLW	PLVLLY- FISHK	RAMAPO- BUCHN	LADNTW- BUCHS	LINDEN- GOETH	HUDSON- FARGT	ROSETN- FISHK	
ROSETON 345	FISHKILL 345	1	20.3%	-11.3%	15.3%	16.0%	22.0%	9.9%	9.0%	TRIP
PLTVLLEY 345	MILLWOOD 345	1	17.4%	TRIP	8.8%	3.1%	12.8%	3.0%	2.0%	-8.9%
PLTVLLEY 345	FISHKILL 345	1	7.6%	24.0%	TRIP	-0.5%	-7.1%	1.1%	0.7%	32.4%
PLTVLLEY 345	FISHKILL 345	2	7.6%	24.0%	66.6%	-0.5%	-7.1%	1.1%	0.7%	32.4%
PLTVLLEY 345	WOOD B 345	1	17.1%	35.3%	9.2%	3.1%	12.3%	3.0%	2.0%	-8.6%
RAMAPO 345	BUCH N 345	1	13.6%	3.3%	-0.2%	TRIP	42.3%	17.2%	17.4%	13.3%
LAIDENTWN 345	BUCH S 345	1	13.6%	17.8%	-3.7%	55.6%	TRIP	24.9%	25.6%	24.0%
FISHKILL 115	SYLVN115 115	1	1.0%	0.8%	0.0%	0.3%	0.6%	0.3%	0.2%	0.5%
E FISH I 115	FISHKILL 345	1	1.7%	-0.5%	2.4%	0.7%	0.8%	0.6%	0.5%	5.9%
<b>***SUB-TOTALS***</b>			93.4%	98.4%	78.0%	76.6%	61.0%	58.2%	91.1%	
<b>***LINDEN-GOETH***</b>			0.9%	0.1%	4.7%	5.2%	TRIP	11.1%	2.2%	
<b>***HUDSON-FAR1***</b>			1.0%	0.1%	7.8%	8.7%	18.8%	29.4%	3.4%	
<b>***HUDSON-FAR2***</b>			1.0%	0.1%	7.9%	8.9%	18.4%	TRIP	3.4%	
<b>***NORHBR-NRPRT***</b>			3.8%	1.2%	1.5%	0.7%	1.7%	1.3%	-0.1%	
<b>***TOTALS***</b>			100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	

DISTRIBUTION FACTORS FOR SPRAINBROOK / DUNWOODIE SOUTH CIRCUITS

Winter 2001-2002

			% Pickup of Transfer	SPRAIN- TRMNT	SPRAIN- W49TH	DUNWDE- RAINY	DUNWDE- SHORE	SPRAIN- DVNPT	SPRAIN- W49TH	DUNWDE RAINY
DUN NO1R 138	S CREEK 138	1		15.2%	0.3%	0.5%	2.1%	4.0%	0.6%	0.9%
DUN NO2R 138	S CREEK 138	1		15.5%	0.3%	0.5%	2.2%	4.1%	0.6%	0.9%
DUN SO1R 138	E179 ST 138	1		22.1%	0.4%	0.7%	3.1%	5.8%	0.8%	1.2%
DUNWODIE 345	RAINEY 345	3	29.0%	8.7%	24.1%	TRIP	10.0%	11.6%	43.8%	O/S
DUNWODIE 345	RAINEY 345	4	29.0%	8.7%	24.1%	45.8%	10.0%	11.6%	43.8%	TRIP
DUNWODIE 345	SHORE RD 345	1					TRIP			
SPRBROOK 345	TREMONT 345	1		TRIP	0.8%	0.7%	4.1%	7.9%	1.4%	1.3%
SPRBROOK 345	W 49 ST 345	1	21.0%	9.1%	TRIP	23.5%	4.7%	13.1%	O/S	43.5%
SPRBROOK 345	W 49 ST 345	2	21.0%	9.1%	45.0%	23.5%	4.7%	13.1%	TRIP	43.5%
REACBUS 345	DVNPT NK 345	1		7.3%	1.0%	0.9%	46.5%	TRIP	1.9%	1.6%
<hr/>										
***SUB-TOTALS***										
***LINDEN-GOETH***										
1.8%										
***HUDSON-FAR#1***										
0.1%										
***HUDSON-FAR#2***										
0.2%										
***NORHRBR-NRPRT***										
2.1%										
<hr/>										
***TOTALS***										
100.0%										

TABLE 6  
DISTRIBUTION FACTORS FOR MOSES SOUTH CIRCUITS

Winter 2001-2002

		% Pickup of Transfer	MASSEN- MARCY	MASSEN- CHAT	MOSES2- ADRON	MOSES2- PORTR
MASS 765 765	MARCY765 765	1	74.1%	TRIP	66.4%	44.1%
DENNISON 115	ANDRWS-4 115	1	2.3%	4.3%	0.9%	1.5%
MOSES W 230	ADRON B1 230	1	9.5%	18.9%	3.3%	TRIP
MOSES W 230	ADRON B2 230	1	9.5%	18.9%	3.3%	36.3%
DENNISON 115	LWRNCE-B 115	1	2.3%	4.3%	0.9%	1.5%
ALCOA-NM 115	BRADY 115	1	1.1%	2.1%	0.4%	0.7%
ALLENS F 115	COLTON 115	1	1.3%			
<hr/>						
***SUB-TOTALS***						
***MOSES-L33P***						
***MOSES-L34P***						
***MOSES-WILLE***						
***MOSES-WILLW***						
<hr/>						
***TOTALS***						
		100.0%	100.0%	100.0%	100.0%	100.0%

TABLE 7  
DISTRIBUTION FACTORS FOR NYISO-ISONE CIRCUITS

Winter 2001-2002

		% Pickup of Transfer	ALPS34-MANY	PV.345-LNGMT	NHHAR-GEN	VTYANK-GEN	YRMTH-GEN	SBRK-GEN	HIGATE-DC	EEL RIVER	MADWAS-DC
ALPS345 345	MANY393 345	1	35.7%	TRIP	40.5%	20.5%	41.9%	36.6%	36.3%	25.5%	36.6%
PLAT T#3 115	GRAND IS 115	1	2.0%	9.5%	5.4%	4.4%	8.5%	7.8%	7.7%	33.9%	7.8%
HOOSICK 115	BNNINGTN 115	1	2.8%	10.2%	2.9%	1.5%	2.4%	2.8%	2.8%	1.3%	2.8%
WHITEHAL 115	BLISSVIL 115	1	4.7%	9.8%	4.3%	2.2%	6.1%	5.0%	4.9%	9.8%	5.0%
ROTRDM.2 230	BRSWAMP 230	1	7.2%	16.1%	7.3%	4.4%	6.3%	7.8%	8.0%	4.0%	7.8%
PLTVLLEY 345	CTNY398 345	1	47.3%	42.4%	TRIP	47.2%	25.8%	29.8%	30.1%	18.7%	29.8%
NRTHPT P 138	NORHR138 138	1	0.0%	10.5%	35.8%	18.4%	8.3%	9.3%	9.4%	6.3%	9.3%
<b>***TOTALS***</b>			<b>99.7%</b>	<b>98.6%</b>	<b>96.2%</b>	<b>98.6%</b>	<b>99.2%</b>	<b>99.1%</b>	<b>99.1%</b>	<b>99.5%</b>	<b>99.1%</b>
<hr/>											

TABLE 8  
DISTRIBUTION FACTORS FOR ONTARIO-NYISO CIRCUITS  
Winter 2001-2002

		% Pickup of Transfer	PA27- NIAGAR	BP76- PACKD2	STLAWR- MOSES	STLAWR- MOSES	BECKB- NIAGAR			
STLAWL34	230	MOSES E	230	1	1.2%	1.2%	TRIP	56.0%	1.4%	
STLAWL33	230	MOSES E	230	1	1.0%	1.1%	52.3%	TRIP	1.2%	
BECK B	345	NIAG	345 345	1	32.2%	33.7%	30.8%	9.5%	8.8%	TRIP
BECK A	345	NIAG	345 345	1	32.2%	33.7%	30.8%	9.5%	8.8%	52.6%
PA27 REG	230	NIAGAR2W	230	1	19.2%	TRIP	31.3%	5.7%	5.3%	23.2%
BP76 REG	230	PACKARD2	230	1	16.5%	26.0%	TRIP	4.9%	4.5%	17.6%
<hr/>										
***SUB-TOTALS***										
***IMO-MICH***										
<hr/>										
***TOTALS***										
			100.0%	99.7%	99.7%	98.6%	98.7%	99.7%		

TABLE 9  
DISTRIBUTION FACTORS FOR PJM-NYISO CIRCUITS

Winter 2001-2002

		% Pickup of Transfer	ERIESO- FALCS	HMRCTY- STOLL	HMRCTY- WATER	E.TOWD- HILLS	BRBURG- RAMPO	WALDWK- SMAWA	HUDSON- FARGT	LINDEN- GOETH	WALDWK- SMAWA	HUDSON- FARGT	
ERIE E 230	S RIPLEY 230	1	18.3%	TRIP	21.6%	7.4%	4.7%	2.4%	0.1%	0.8%	1.5%	1.3%	1.1%
WARREN 115	FALCONER 115	1	6.0%	22.0%	8.3%	1.8%	3.0%	0.8%	0.1%	0.3%	0.5%	0.5%	0.4%
HOMER CY 345	STOLE345 345	1	11.5%	15.5%	TRIP	15.3%	2.0%	1.8%	0.1%	0.6%	1.1%	0.9%	0.8%
HOMER CY 345	WATRC345 345	1	23.2%	6.5%	18.7%	TRIP	13.4%	3.8%	0.2%	1.2%	2.4%	2.0%	1.7%
E.TWANDA 230	HILSD230 230	1	24.7%	6.0%	3.5%	19.5%	TRIP	3.6%	0.3%	1.4%	2.3%	2.4%	2.0%
E.SAYRE 115	N.WAV115 115	1	9.1%	2.0%	1.4%	4.1%	30.7%	1.3%	0.1%	0.5%	0.9%	0.9%	0.7%
LAUREL L 115	GOUDY115 115	1	7.2%	0.9%	0.7%	2.2%	11.4%	1.1%	0.1%	0.4%	0.7%	0.7%	0.6%
BRANCHBG 500	RAMAPO 5 500	1		6.5%	6.7%	11.8%	7.6%	TRIP	3.0%	8.0%	21.1%	26.3%	11.5%
HUDSON1 345	FARRGUT1 345	1		2.3%	2.4%	4.0%	3.2%	8.5%	2.9%	TRIP	18.4%	25.3%	O/S
HUDSON2 345	FARRGUT2 345	1		2.3%	2.4%	4.0%	3.2%	8.5%	2.8%	29.4%	18.8%	25.8%	TRIP
LINDEN 230	GOETHALS 230	1		2.6%	2.7%	4.7%	3.2%	13.5%	1.1%	11.1%	TRIP	10.4%	16.1%
WALDWICK 345	SMAHWAH1 345	1		3.2%	3.3%	5.7%	4.8%	23.5%	88.9%	22.2%	13.8%	O/S	31.2%
WALDWICK 345	SMAHWAH2 345	1		3.0%	3.1%	5.2%	4.4%	23.3%	TRIP	21.3%	13.2%	TRIP	29.9%
<hr/>													
***SUB-TOTALS***													
***IMO-MICH***													
<hr/>													
***TOTALS***													
		100.0%	98.1%	98.1%	98.8%	99.3%	99.1%	99.9%	99.6%	99.5%	100.1%	99.5%	

TABLE 10A  
GENERATION SHIFT FACTORS WITH ALL PAR'S HOLDING MW FLOW

Winter 2001-2002

	WEST-CENTRAL	UTICA-ALBANY	MARCY-SOUTH	CENTRAL-EAST	BBURG-RAMAPO	IMO-NYISO	PJM-NYISO
ALBANY	11.8%	21.7%	-6.5%	24.2%	0.0%	7.2%	14.4%
BB-RAMAPO	13.5%	14.0%	5.6%	14.9%	-100.0%	5.0%	-70.2%
BECK	-49.5%	-24.2%	-13.1%	-25.2%	0.0%	-70.1%	19.2%
BOWEN	-10.4%	-8.3%	-3.6%	-8.8%	0.0%	-6.1%	-13.9%
BOWLINE	7.7%	4.8%	3.8%	5.1%	0.0%	4.7%	9.7%
BRANDON	-14.2%	-13.3%	-5.5%	-14.1%	0.0%	-6.1%	-26.5%
BRAYTON	10.5%	15.4%	-3.7%	18.2%	0.0%	6.5%	12.9%
CHAT	16.3%	-41.7%	-28.0%	-43.7%	0.0%	9.8%	17.9%
CONEMAUGH	-14.8%	-14.0%	-5.7%	-14.8%	0.0%	-5.5%	-28.8%
DUNKIRK	-40.3%	-21.2%	-10.6%	-22.3%	0.0%	14.0%	39.0%
EDDYSTONE	-13.6%	-13.9%	-5.6%	-14.8%	0.0%	-5.1%	-29.4%
GILBOA	11.6%	8.6%	2.8%	8.5%	0.0%	7.2%	15.3%
HATFIELD	-15.4%	-13.3%	-5.6%	-14.1%	0.0%	-7.1%	-25.2%
HUDSON	-13.1%	-14.1%	-5.6%	-15.0%	0.0%	-4.8%	-30.4%
HUNTLEY	-49.7%	-24.0%	-12.7%	-25.1%	0.0%	23.2%	25.6%
INDIANPT2	7.4%	4.8%	3.4%	5.1%	0.0%	4.6%	9.4%
JEAMOS	-15.5%	-12.3%	-5.3%	-13.0%	0.0%	-9.2%	-20.1%
LAMBTON	-30.4%	-17.5%	-8.7%	-18.4%	0.0%	-35.4%	-3.4%
LUDINGTON	-19.7%	-13.6%	-6.3%	-14.3%	0.0%	-16.8%	-14.7%
MONROE	-24.6%	-15.4%	-7.4%	-16.2%	0.0%	-25.0%	-10.1%
MTSTORM	-14.8%	-12.9%	-5.4%	-13.6%	0.0%	-7.1%	-24.1%
NANTICOKE	-41.2%	-21.3%	-11.2%	-22.2%	0.0%	-55.0%	9.4%
NEWTON	-14.3%	-10.9%	-4.8%	-11.5%	0.0%	-9.6%	-16.1%
NIAGARA	-51.0%	-24.6%	-13.2%	-25.7%	0.0%	22.7%	25.2%
NORWALK	8.5%	9.6%	0.1%	10.7%	0.0%	5.2%	10.6%
OSWEGO	19.3%	-37.0%	-23.4%	-38.0%	0.0%	11.5%	19.6%
PORTLAND	-12.8%	-14.2%	-5.6%	-15.2%	0.0%	-4.6%	-31.0%
ROSETON	8.8%	6.6%	3.5%	6.9%	0.0%	5.5%	11.2%
SALEM	-13.7%	-13.9%	-5.6%	-14.8%	0.0%	-5.2%	-29.2%

TABLE 10B  
GENERATION SHIFT FACTORS WITH PAR'S FREE FLOWING

	Summer 2001						
	WEST-CENTRAL	UTICA-ALBANY	MARCY-SOUTH	CENTRAL-EAST	BBURG-RAMAPO	IMO-NYISO	PJM-NYISO
ALBANY	8.6%	19.9%	-7.4%	25.5%	3.1%	9.4%	22.3%
BB-RAMAPO	5.8%	5.8%	4.2%	6.8%	-100.0%	4.8%	24.3%
BECK	-39.4%	-20.6%	-12.8%	-23.7%	-3.8%	-69.3%	7.1%
BOWEN	-4.8%	-4.5%	-2.1%	-5.2%	-6.3%	-5.5%	-31.2%
BOWLINE	3.4%	2.1%	2.5%	2.4%	8.6%	4.2%	34.1%
BRANDON	-4.1%	-4.9%	-1.8%	-5.8%	-13.1%	-2.8%	-63.3%
BRAYTON	7.0%	12.6%	-4.8%	19.7%	3.5%	8.3%	22.2%
CHAT	8.7%	-34.0%	-24.9%	-40.4%	0.8%	16.5%	17.6%
CONEMAUGH	-4.9%	-5.9%	-2.3%	-6.8%	-12.6%	-2.4%	-64.3%
DUNKIRK	-32.0%	-16.4%	-9.3%	-18.9%	-5.7%	15.6%	21.8%
EDDYSTONE	-1.6%	-3.2%	-0.7%	-3.8%	-16.8%	-0.1%	-76.8%
GILBOA	8.7%	8.8%	2.8%	9.0%	3.0%	9.0%	22.9%
HATFIELD	-6.4%	-6.5%	-2.8%	-7.6%	-10.7%	-5.0%	-55.2%
HUDSON	2.0%	0.7%	1.2%	0.9%	-1.3%	2.9%	-106.0%
HUNTLEY	-41.1%	-19.9%	-12.0%	-22.9%	-4.1%	24.4%	12.7%
INDIANPT2	3.4%	2.2%	2.2%	2.6%	7.5%	4.1%	30.7%
JEAMOS	-7.5%	-6.8%	-3.3%	-7.9%	-8.8%	-8.3%	-44.3%
LAMBTON	-17.9%	-13.4%	-8.0%	-15.7%	-6.3%	-34.2%	-22.5%
LUDINGTON	-11.1%	-9.0%	-4.9%	-10.6%	-7.6%	-17.3%	-35.5%
MONROE	-14.5%	-11.3%	-6.5%	-13.2%	-7.0%	-25.6%	-29.5%
MTSTORM	-5.8%	-6.0%	-2.6%	-7.0%	-10.8%	-4.9%	-54.4%
NANTICOKE	-26.0%	-18.5%	-11.7%	-21.9%	-4.4%	-55.6%	-4.5%
NEWTON	-7.4%	-6.5%	-3.3%	-7.6%	-7.3%	-9.6%	-36.0%
NIAGARA	-42.8%	-20.5%	-12.5%	-23.5%	-3.8%	24.0%	13.0%
NORWALK	4.9%	7.0%	-0.6%	9.6%	4.0%	5.8%	21.4%
OSWEGO	17.9%	-32.6%	-22.4%	-36.1%	0.5%	14.6%	19.3%
PORLTAND	-0.2%	-2.6%	-0.2%	-3.0%	-11.6%	1.2%	-88.7%
ROSETON	5.4%	4.9%	3.0%	5.5%	5.1%	6.0%	25.2%
SALEM	-1.7%	-3.2%	-0.7%	-3.8%	-16.7%	-0.1%	-76.4%

## **APPENDIX F**

### **ANNOTATED TLTG OUTPUT**

**This Section Is Available  
On Computer Diskette If Requested**




**APPENDIX G**  
**TRANSFER LIMIT SENSITIVITY GRAPHS**

NYISO OPERATING STUDY  
WINTER 2001-02


## INDEX

1. Total East vs HQ-NY	.....	G-2
2. Central East vs HQ-NY	.....	G-3
3. Total East vs Ramapo Par Flow	.....	G-4
4. Central East vs Ramapo Par Flow	.....	G-5
5. UPNY ConEd vs Ramapo Par Flow	.....	G-6
6. Moses South vs HQ Export to New York	.....	G-7
7. NE-NY vs Norwalk-Northport Par flow for Normal Transfer	.....	G-8
8. NE-NY vs Norwalk-Northport Par flow for Emergency Transfer	.....	G-9
9. NY-NE vs Norwalk-Northport Par flow for Normal Transfer	.....	G-10
10. NY-NE vs Norwalk-Northport Par flow for Emergency Transfer	.....	G-11
11. NYISO-IMO (ONTARIO) Transfer vs L33 & L34	.....	G-12
12. IMO (ONTARIO)-NYISO Transfer vs L33 & L34	.....	G-13


**Total East vs. HQ**  
**For Normal Transfer Criteria**  
**Winterer 2001**




**Central East vs. HQ**  
**For Normal Transfer Criteria**  
**Winter 2001**




**Total East vs. RAMAPO PAR Flow**  
**For Normal Transfer Criteria**  
**Winter 2001**




**Central East vs. RAMAPO PAR Flow**  
**For Normal Transfer Criteria**  
**Winter 2001**




**UPNY CONED vs. RAMAPO PAR Flow**  
**For Normal Transfer Criteria**  
**Winter 2001**




**Moses South vs. HQ Export to New York**  
**For Normal Transfer Criteria**  
**Winter 2001**




**NE-NY vs. NORWALK-NORTHPORT PAR Flow**  
**For Normal Transfer Criteria**  
**Winter 2001**




**NE-NY vs. NORWALK-NORTHPORT PAR Flow**  
**For Emergency Transfer Criteria**  
**Winter 2001**




**NY-NE vs. NORTHPORT-NORWALK PAR Flow**  
**For Normal Transfer Criteria**  
**Winter 2001**




**NY-NE vs. NORTHPORT-NORWALK PAR Flow**  
**For Emergency Transfer Criteria**  
**Winter 2001**



**NY- IMO (Ontario) Transfer vs. L33 & L34**  
**For Normal Transfer Criteria**  
**Winter 2001**



**IMO (Ontario)-NY Transfer vs. L33 & L34**  
**For Normal Transfer Criteria**  
**Winter 2001**



## **APPENDIX H**

### **COMPARISON OF TRANSFER LIMITS WINTER 2001-02 vs. WINTER 2000-01**

NYISO OPERATING STUDY  
WINTER 2001-02

# WINTER 2001-02

## Comparison of Winter 2001-02 to Winter 2000-01 Thermal Limits

		WINTER 2001-02		WINTER 2000-01		Delta
Interface	Rating	Limit (MW)	Contingency	Limit (MW)	Contingency	
<b>Dysinger East</b>	Normal	3375	1	3275	2	100
	Emergency	3650	3	3575	4	75
<b>West Central</b>	Normal	2550	5	2500	2	50
	Emergency	2600	6	2800	4	-200
<b>Upny - ConEd</b>	Normal	5175	7	4625	20	550
	Emergency	5625	8	5300	8	325
<b>Sprn/Dun-South</b>	Normal	3300	9	3600	10	-300
	Emergency	3925	11	3950	12	-25
<b>Con Ed - LIPA</b>	Normal	675	13	975	14	-300
	Emergency	925	13	1675	15	-750
<b>Central East</b>						
HQ > NY 400 MW	Normal	3275	16	3125	16	150
	Emergency	3575	6	3150	6	425
HQ > NY 0 MW	Normal	3175	16	2925	5	250
	Emergency	3575	6	2950	6	625
<b>Total East</b>						
HQ > NY 400 MW	Normal	6000	16	5625	16	375
	Emergency	6450	6	5700	6	750
HQ > NY 0 MW	Normal	5850	16	5225	5	625
	Emergency	5950	6	5300	6	650
<b>Moses - South</b>						
HQ > NY 400 MW	Normal	1650	17	1675	17	25
	Emergency	2250	18	2250	18	0
HQ > NY 0 MW	Normal	1300	17	1325	17	-25
	Emergency	2125	19	2125	19	0

**NYISO WINTER 2001-02 CROSS-STATE THERMAL LIMIT CONTINGENCY LIST**

<b>Limiting Element</b>					<b>Contingency</b>
(1)	Niagara - Rochester (NR-2) 345kV	@LTE	1591 MW	L/O	AES/Somerset - Rochester (SR-1) 345kV
(2)	Stolle Rd. – Meyer 230 kV	@LTE	564 MW	L/O	Niagara-Rochester 345kV Rochester – Pannell 345kV
(3)	Niagara - Rochester (NR-2) 345kV	@STE	1744 MW	L/O	AES/Somerset - Rochester (SR-1) 345kV
(4)	Stolle Rd. – Meyer 230 kV	@STE	606 MW	L/O	Niagara – Rochester 345kV
(5)	Clay – Edic 345kV	@LTE	1434 MW	L/O	Clay – Edic 345kV Clay 345/115kV
(6)	Clay – Edic 345kV	@STE	1434 MW	L/O	Clay – Edic 345kV
(7)	Leeds - Pleasant Valley (91) 345kV	@LTE	1783 MW	L/O	Leeds - Pleasant Valley (92) 345kV
(8)	Leeds - Pleasant Valley (91) 345kV	@STE	1912 MW	L/O	Leeds - Pleasant Valley (92) 345kV
(9)	Dunwoodie - Rainey 345 kV	@LTE	871 MW	L/O	Dunwoodie – Rainey 345kV Sprain Brook – Dunwoodie 345kV
(10)	Sprain Brook – W. 49 <sup>th</sup> St. 345kV	@ LTE	968 MW	L/O	Sprain Brook – Dunwoodie 345kV Sprain Brook 345/138kV
(11)	Dunwoodie - Rainey 345 kV	@LTE	1113 MW	L/O	Dunwoodie – Rainey 345kV
(12)	Sprain Brook – W. 49 <sup>th</sup> 345 kV	@NOR	736 MW		Pre-Contingency Loading
(13)	Sprain Brook – E.G.C. 345 kV	@NOR	693 MW		Pre-Contingency Loading
(14)	Sprain Brook – E.G.C. 345 kV	@LTE	940 MW	L/O	Dunwoodie – Shore Rd. 345kV Dunwoodie – Pleasantville 345kV Dunwoodie No. 345/138kV
(15)	Dunwoodie – Shore Rd. 345 kV	@NOR	721 MW		Pre-Contingency Loading
(16)	Oakdale - Fraser 345 kV	@LTE	1380 MW	L/O	Marcy – Coopers Corners 345kV Edic – Fraser 345kV
(17)	Adirondack -Porter 230kV	@LTE	376 MW	L/O	Moses - Massena MMS-1 230kV Moses - Massena MMS-2 230kV

NYISO OPERATING STUDY  
WINTER 2001-02

(18)	Marcy 765/345kV	@STE	1654 MW	L/O	Marcy 765/345kV
(18)	Adirondack -Porter 230kV	@STE	449 MW	L/O	Adirondack – Porter 230 kV
(19)	Moses – Massena MMS-1 230kV	@STE	1404 MW	L/O	Moses - Massena MMS-2 230kV
(20)	Hudson - Farragut 345 kV	@LTE	737 MW	L/O	Buchanan So. – Ladentown 345 kV Buchanan No. – Ramapo 345 kV Buchanan 345/138 kV

This Page Intentionally Left Blank.

## APPENDIX I

### SUMMARY OF EXISTING STABILITY LIMITS



**APPENDIX I**  
**NYISO STABILITY LIMITS**

	<b>LIMIT</b>	<b>REPORT</b>	<b>DATE</b>
<b>TOTAL-EAST</b>			
SEASONAL LIMIT	6500	TE-2	1995
5018 BRANCHBURG-RAMAPO 500 KV O/S	6400	TE-3	3/95
5018 BRANCHBURG-RAMAPO 500 KV O/S WITH ANY SVC O/S	6300	TE-3	3/95
<b>UPNY-CONED</b>			
SEASONAL LIMIT	5100	TE-1	1988
Y88 LADENTOWN-BUCHANAN 345 KV O/S	4150	UC-2	1/93
Y94 RAMAPO-BUCHANAN N. 345 KV O/S	4150	UC-2	1/93
RFK-305 ROSETON-E. FISHKILL 345 KV O/S	4100	UC-2	1/93
5018 BRANCHBURG-RAMAPO 500 KV O/S	4000	UC-1	1/93
<b>CENTRAL-EAST</b>			
SEASONAL LIMIT WITH 3 OSWEGO & 5 SITHE UNITS, SVCs and STATCOM in service	3100	CE-14	4/2001
4 LAFAYETTE-OAKDALE 345 KV O/S	2900	CE-8	6/95
32 OAKDALE-FRASER 345 KV O/S	3050	CE-8	6/95
<i>Oswego Complex, Sithe and Marcy STATCOM, Leeds and Fraser SVC Limits have been revised as a result of the addition of the Marcy STATCOM Please refer to the NYISO Report: “Marcy FACTS Project – Phase I Voltage and Stability Limits April 11, 2001”</i>			
		CE-14	4/2001

<i>Both Chateauguay HVdc poles O/S, or 1 Chateauguay HVdc pole I/S &lt;100 MW, or both Chateauguay HVdc poles &lt;150 MW (net), then: Limit Oswego Complex to 3200 MW for 4 Units I/S &amp; Sithe O/S Limit Oswego Complex to 3500 MW for 5 Units I/S &amp; Sithe O/S or 4600 for 5-Units I/S &amp; Sithe I/S</i>		CE-3	9/20/93
NEW SCOTLAND 77 OR 99 BUS O/S	2050	CE-1	5/10/89
14 EDIC-NEW SCOTLAND 345 KV O/S	2050	CE-1	5/10/89
UNS-18 MARCY-NEW SCOTLAND 345 KV O/S	2050	CE-1	5/10/89
MSU-1 MASSENA-MARCY 765 KV O/S	2000	CE-1	7/12/90
<b>MOSES-SOUTH</b>			
SEASONAL LIMIT WITH 2 HVDC POLES I/S (MAX CHAT-MASSENA = 2370)	2900	MS-6	5/6/93
R8105 ALCOA BUS TIE 115 KV O/S	2600	MS-1	1/23/91
3 CHAT BANKS 765/120 KV I/S, (MAX CHAT-MASSENA = 1800)	2500		
ONE MOSES-ADIRONDACK-PORTER 230 KV CKT O/S	2450	MS-2	1/9/88
4 CHAT 765/120 kV BANKS I/S - SPLIT BUS & 1 HVDC POLE I/S (MAX CHAT - MASSENA = 1870 MW)	2600	MS-7	3/15/94
2 CHAT 765/120 KV BANKS I/S & 1 HVDC POLE I/S (MAX CHAT-MASSENA = 1650 MW)	2350	MS-5	1/14/94
3 CHAT 765/120 KV BANKS I/S & 1 HVDC POLE I/S (MAX CHAT-MASSENA = 1400)	2150	MS-5	1/14/94
2 HVDC POLES O/S (MAX CHAT-MASSENA = 1170)	2000	MS-4	1990
MSU-1 I/S WITH NO DIRECT TRANSFER TRIP FOR GEN REJECTION AT QUEBEC (MAX CHAT-MASSENA = 650)	1100	MS-2	11/29/84
MSU-1 MASSENA-MARCY 765KV O/S (MAX CHAT-MASSENA= 475)	675		2/9/84
MSU-1 MASSENA-MARCY 765 KV AND ONE MOSES-ADIRONDACK-PORTER 230 KV O/S	500		

<b>MOSES-NORTH</b>			
SEASONAL LIMIT	1600	MN-1	12/1/89
ONE OR TWO MOSES-ADIRONDACK-PORTER 230 KV CKTS O/S	1600	MN-2	2/10/90
MSU-1 MASSENA-MARCY 765 KV O/S	1100	MN-2	
<b>WEST-CENTRAL</b>			
SEASONAL LIMIT	2350	WC-1	9/18/89
NR-2 NIAGARA-ROCHESTER 345 KV OR SR-1 KINTIGH-ROCHESTER 345 KV O/S	2150	WC-2	10/14/91
<b>DYSINGER-EAST</b>			
SEASONAL LIMIT	2850	DE-1	7/27/92
67 STOLLE ROAD-MEYER 230 KV OR 68 MEYER-HILLSIDE 230 KV O/S	2650	DE-1	7/27/92
NR-2 NIAGARA - ROCHESTER 345 KV OR SR-1 KINTIGH - ROCHESTER 345 KV O/S	2500	DE-1	7/27/92
<b>NYISO-PJM</b>			
SEASONAL LIMIT	3600	NP-1	9/94
<b>PJM-NYISO</b>			
SEASONAL LIMIT	3600	NP-1	9/94
<b>NYISO-IMO</b>			
SEASONAL LIMIT	2500	NOH-1	11/10/93
PA301 OR PA302 BECK-NIAGARA 345 KV O/S	2300	NOH-1	11/10/93
PA27 OR BP76 OR L33P OR L34P O/S	2300	NOH-1	11/10/93
PA301 & PA302 BECK-NIAGARA 345 KV O/S	500	NOH-3	1995
<b>IMO-NYISO</b>			
SEASONAL LIMIT	2500	NOH-1	11/10/93
PA301 OR PA302 BECK-NIAGARA 345 KV O/S	2300	NOH-1	11/10/93
PA27 OR BP76 OR L33P OR L34P O/S	2300	NOH-1	11/10/93
PA301 & PA302 BECK-NIAGARA 345 KV O/S	800	NOH-3	1995

<b>WESTERN NY EXPORT</b>			
BOTH BECK-NIAGARA 345 KV CKTS O/S W/ NIAGARA GEN REJ I/S	1700	NOH-3	2/95
BOTH BECK-NIAGARA 345 KV CKTS O/S W/ NIAGARA GEN REJ O/S OR BOTH BECK-NIAGARA 345 KV CKTS O/S & PA27 CKT O/S OR ONE BECK-NIAGARA 345KV CKT O/S & PA27 & BP76 CKTS O/S	1100	NOH-3	2/95
<b>NYISO-ISO-NE</b>			
SEASONAL LIMIT	2200	NE-1	10/92- 1996
2 NEW SCOTLAND - ALPS 345 KV O/S	2150	NE-1	10/92
329 FROST BRIDGE - SOUTHBURG 345 KV O/S	2100	NE-1	10/92
312 BERKSHIRE - NORTHFIELD 345 KV O/S	1950	NE-1	10/92
352 LONG MOUNTAIN - FROST BRIDGE 345 KV O/S	1850	NE-1	10/92
393 ALPS - BERKSHIRE 345 KV O/S	1600	NE-1	10/92
393/312 ALPS-BERKSHIRE-NORTHFIELD 345 KV O/S	1500	NE-1	10/92
398 PLEASANT VALLEY - LONG MOUNTAIN 345 KV O/S	1150	NE-1	10/92
<b>ISO-NE-NYISO</b>			
THIS LIMIT IS SET BY NE, NYISO SPD MUST CALL FOR LIMIT		NE-1	10/92

**NYISO STABILITY REPORT  
SUMMARY**

REPORT	REPORT TITLE	LAST REVISED DATE
TE-2	TOTAL EAST STABILITY ANALYSIS WITH SITHE GENERATION O/S	1/95
TE-3	NYISO TOTAL EAST ANALYSIS - A. HARGRAVE	3/95
UC-1	REVISED MAINTENANCE STABILITY TRANSFER LIMITS FOR BRANCH- RAMAPO O/S-NYPP	1/93
UC-2	RWW ANALYSIS - NYPP	1/93
CE-1	REVISED CENTRAL EAST STABILITY LIMITS BASED ON SVC RESERVE - K. TAMMAR TO C. COREY	5/10/89
CE-2	CENTRAL EAST STABILITY LIMIT W/ 765 KV SYSTEM O/S - NYPA TO K. TAMMAR	7/12/90
CE-3	CE & OSWEGO COMPLEX STABILITY LIMITS FOR THE CHATEAUGUAY HVDC O/S-NYPP/NYPA	9/20/93
CE-5	NYISO CE STABILITY LIMITS FOR LEEDS OR FRASER SVC O/S	4/12/94
CE-6	CENTRAL EAST STABILITY ANALYSIS PRE-SITHE CONFIGURATION	10/94
CE-7	CENTRAL EAST STABILITY ANALYSIS POST SITHE CONFIGURATION	2/95
CE-8	CENTRAL EAST STABILITY LIMITS FOR THREE OSWEGO UNITS I/S	6/1/95
CE-9	CENTRAL EAST STABILITY LIMITS FOR TWO OSWEGO UNITS I/S	4/17/96
CE-10	CENTRAL EAST STABILITY LIMITS FOR ONE OSWEGO UNIT I/S	4/17/96
CE-11	CENTRAL EAST STABILITY LIMITS FOR ZERO OSWEGO UNITS I/S	6/27/97
CE-12	CENTRAL EAST STABILITY LIMITS FOR 4/5 OSWEGO UNIT I/S	11/99
CE-14	CENTRAL EAST VOLTAGE AND STABILITY ANALYSIS FOR MARCY FACTS PROJECT – PHASE I	04/11/2001
MS-2	RT GONZALES ANALYSIS	1/9/88
MS-3	RW WALDELE ANLAYSIS	11/29/84
MS-4	NYPA ANALYSIS W/2 HVDC POLES O/S	1990
MS-5	OPERATION OF THE MSC-7040 LINE W/1650 MW IMPORT FROM HYDRO QUEBEC & ONE HVDC CONVERTER I/S	12/20/93
MS-6	CHATEAUGUAY 2370MW IMPORT ANAYLSIS	5/6/93
MS-7	SPLIT 120 KV BUS OPERATION OF THE CHAT/BEAU COMPLEX W/ ONE HVDC CONVERTER O/S -NYPA	3/15/94
MN-1	RWW ANALYSIS 12/13/89 KT MEMO TO JEK	12/1/89
MN-2	JAM ANALYSIS #89030S MOSES-SOUTH W/MAP OS	2/10/90

WC-1	AWH ANALYSIS - NYISO	9/18/89
WC-2	WEST CENTRAL TRANSIENT STABILITY LIMITS FOR LINE OUTAGE CONDITIONS - NYISO	10/14/91
DE-1	DYSINGER EAST TRANSIENT STABILITY LIMITS FOR LINE OUTAGE CONDITIONS - NYISO	7/27/92
NOH-1	NYISO-OH DIRECT TIE STUDY OCTOBER 1993 SEE CA KING LETTER TO SOAS DATED 11/10/93	10/93
NOH-2	OH-NYISO TS STUDY GROUP ANALYSIS	1983-1984
NOH-3	NYISO STABILITY ANALYSIS WITH PA301/PA303 O/S	2/95
NE-1	1992-1996 NYISO-NEPOOL TRANSFER LIMIT STUDY	10/92
NP-1	NYISO-PJM STABILITY ANALYSIS ON THE DIRECT TIE TRANSFER CAPABILITY	9/94

