

2022 RNA Base Case Inclusion Rules Application - Updates

Laura Popa

Manager, Resource Planning

TPAS/ESPWG

April 26, 2022, KCC

Agenda

- **A preliminary inclusion rules application was presented at the April 1 TPAS/ESPWG**
- **This is to provide a final application for the 1st pass RNA Base Case**
 - Proposed projects
 - Deactivations
 - Generation status changes due to DEC Peaker Rule

2022 RNA Base Cases and the Inclusion Rules Application

2022-2023 RPP Background

- **The 2022 Reliability Planning Process (RPP) starts with the 2022 Reliability Needs Assessment (2022 RNA) followed by the 2023-2032 Comprehensive System Plan (CRP)**
 - 2022 RNA Study Period: year 4 = 2026 through year 10 = 2032
 - Note: year 1 through year 5 are assessed quarterly in the Short-Term Reliability Process (STRP)
- **The RPP is part of the Comprehensive System Planning Process and is performed pursuant to the Attachment Y of the NYISO OATT; see Section 31.2.**
 - Additional implementation details, including recently updated RNA Base Case inclusion rules, are captured in the RPP Manual
- **2022 RNA will be based on the information from the Gold Book 2022, the 2022 FERC 715 filing (power flow cases and auxiliary files), historical data, and market participant data**
- **Reliability evaluations on the 2022 RNA Base Case: transmission security and resource adequacy**
 - NERC, NPCC, NYSRC Reliability Rules application on the Bulk Power Transmission Facilities (BPTFs)

2022 RNA Base Case Development Background

- **Based on the RNA Base Case, the NYISO identifies Reliability Needs of the New York State Bulk Power Transmission Facilities (BPTFs) in accordance with applicable Reliability Criteria (*i.e.*, NERC, NPCC, and NYSRC)**
- **2022 RNA Base Case:**
 - For the transmission security evaluations, the NYISO uses the 2022 FERC Form 715 filing and the information from the 2022 Gold Book as a starting point for developing the base case system models with the application of the inclusion rules.
 - For the resource adequacy evaluation, the models are developed starting with prior resource adequacy models, and are updated with information from the 2022 Gold Book and historical data, with the application of the inclusion rules. Information on modeling of neighboring systems is based on the input received from the NPCC CP-8 working group.
- **The inclusion rules reside in the Reliability Planning Process Manual [[link](#)], and are used as guidelines to determine what proposed projects will be included in the RNA Base Case, and also how to treat generator deactivations**

2022 RNA: Inclusion Rules Application

- **Proposed generation and transmission to be included:**
 - next slide contains a list of projects
- **Generation deactivations: all plant deactivations listed in the 2022 Gold Book Section IV -3, -4, -5 will be out of service**
- **The peakers listed in the 2022 Gold Book Table IV-6 will be modeled with a status reflecting their latest compliance plans the owners filed with DEC under the Peaker Rule**
 - List in this presentation
- **Proposed Local Transmission Owner Plans (LTP) to be included:**
 - All BPTF LTPs listed in the 2022 GB Section VII as firm, with consideration for the in-service date
 - All non-BPTF LTPs listed by the Transmission Owner as firm
- **Existing transmission facilities modeled out-of-service include:**
 - Con Edison's B3402 and C3403 345 kV cables for the entire study period

Proposed Projects Inclusion: Regulated Transmission

| NYISO Interconnection Queue # | Project Name/(Owner) | Summer Peak MW | POI | Zone | Type | Queue COD or I/S | Interconnection Status / Class Year | Reliability Base Case Inclusion Status |
|-------------------------------|--|----------------|---|------|-----------------|------------------|---|--|
| 0545A | Empire State Line (NextEra) | n/a | Dysinger - Stolle 345kV | A | Transmission | 06/2022 | TIP Facility Study and Interconnection Agreement completed (Western NY PPTPP) | 2018-2019 RPP |
| 0543 | Segment B Knickerbocker-Pleasant Valley 345 kV (National Grid, NY Transco, O&R, ConEdison) | n/a | Greenbush - Pleasant Valley 345kV | F,G | Transmission | 12/2023 | TIP Facility Study and Interconnection Agreement completed (AC PPTPP) | 2020-2021 RPP |
| 0556 | Segment A Double Circuit (LS Power, National Grid, NYPA) | n/a | Edic - New Scotland 345kV | E, F | Transmission | 12/2023 | TIP Facility Study and Interconnection Agreement completed (AC PPTPP) | |
| 0430 | Cedar Rapids Transmission Upgrade (HQ Energy Services US) | +80 | Dennison - Alcoa 115kV | D | Transmission | I/S | CY2017 | |
| 0631 | NS Power Express (CHPE LLC) | 1000 | Hertel 735kV (Quebec)-Astoria Annex 345kV (NYC) | J | DC Transmission | 12/2025 | CY21 in progress | 2022 RNA |
| 0887 | CH Uprate (CHPE LLC) | 250 | | | | | | 2022 RNA |
| 1125 | Northern New York Priority Transmission Project (NNYPTP) (NYPA, National Grid) | n/a | Moses/Adirondack/Porter Path | D, E | Transmission | 12/2025 | TIP Facility Study in progress | 2022 RNA |

Note: brown color shows projects added since the April 1 TPAS/ESPWG presentation

Proposed Projects Inclusion: Large Generation

| Project Category | NYISO In terconnection Queue # | Project Name/(Owner) | Summer Peak MW | POI | Zone | Type | Queue COD or I/S | Interconnection Status/ Class Year | Reliability Base Case Inclusion Starting With |
|------------------|---------------------------------|--|-----------------------------------|--|------|--------|------------------|------------------------------------|---|
| Large Gens | 678 | Calverton Solar Energy Center (LI Solar Generation, LLC) | 22.9 | Edwards Substation 138kV | K | S | Jun-22 | CY2019 | 2020-2021 RPP |
| | 422 | Eight Point Wind Energy Center (NextEra Energy Resources, LLC) | 101.8 | Bennett 115kV | B | W | Sep-22 | CY2017 | 2020-2021 RPP |
| | 505 | Ball Hill Wind (Ball Hill Wind Energy, LLC) | 100.0 | Dunkirk - Gardenville 230kV | A | W | Nov-22 | CY2017 | 2020-2021 RPP |
| | 396 | Baron Winds (Baron Winds, LLC) | 238.4 | Hillside - Meyer 230kV | C | W | Dec-23 | CY2017 | 2020-2021 RPP |
| | 531 | Number 3 Wind Energy (Invenergy Wind Development LLC) | 103.9 | Taylorville - Boonville 115kV | E | W | Oct-22 | CY2019 | 2021 Q3 STAR |
| | 758 | Independence GS1 to GS4 (Dynegy Marketing and Trade, LLC) | +9 | Scriba 345 kV | C | Gas | I/S | CY21 in progress - ERIS only | 2022 RNA |
| | 579 | Bluestone Wind (Bluestone Wind, LLC) | 111.8 | Afton - Stilesville 115kV | E | W | Oct-22 | CY2019 | 2022 RNA |
| | 721 | Excelsior Energy Center (Excelsior Energy Center, LLC) | 280.0 | N. Rochester - Niagara 345 kV | A | S | Nov-22 | CY2019 | 2022 RNA |
| | 618 | High River Solar (High River Energy Center, LLC) | 90.0 | Inghams - Rotterdam 115kV | F | S | Nov-22 | CY2019 | 2022 RNA |
| | 619 | East Point Solar (East Point Energy Center, LLC) | 50.0 | Cobleskill - Marshville 69kV | F | S | Nov-22 | CY2019 | 2022 RNA |
| | 612 | South Fork Wind Farm (South Fork Wind, LLC) | 96.0 | East Hampton 69kV | K | OSW | Aug-23 | CY2019 | 2022 RNA |
| | 695 | South Fork Wind Farm II (South Fork Wind, LLC) | 40.0 | East Hampton 69kV | K | OSW | Aug-23 | CY2019 | 2022 RNA |
| | 637 | Flint Mine Solar (Flint Mine Solar LLC) | 100.0 | LaFarge - Pleasant Valley 115kV, Feura Bush - North Catskill 115kV | G | S | Sep-23 | CY2019 | 2022 RNA |
| | 720 | Trelina Solar Energy Center (Trelina Solar Energy Center, LLC) | 80.0 | Border City - Station 168 115 KV | C | S | Nov-23 | CY2019 | 2022 RNA |
| | 617 | Watkins Glen Solar (Watkins Glen Energy Center, LLC) | 50.0 | Bath - Montour Falls 115kV | C | S | Nov-23 | CY2019 | 2022 RNA |
| 495 | Mohawk Solar (Mohawk Solar LLC) | 90.5 | St. Johnsville - Marshville 115kV | F | W | Nov-24 | CY2019 | 2022 RNA | |

Note: all of the proposed Large Gens in this table have both Capacity Resource Interconnection Service (CRIS) and Energy Resource Interconnection Service (ERIS), unless otherwise noted

Proposed Projects Inclusion: Small Generation

| NYISO Interconnection Queue # | Project Name/(Owner) | Summer Peak MW | POI | Zone | Type | Queue COD or I/S | Interconnection Status/Class Year | Reliability Base Case Inclusion Status |
|-------------------------------|--|----------------|----------------------------------|------|------|------------------|-----------------------------------|--|
| 572 | Greene County 1 (Hecate Energy Greene 1 LLC) | 20 | Coxsackie - North Catskill 69kV | G | S | 01/2023 | IA Executed* | 2021 Q3 STAR |
| 573 | Greene County 2 (Hecate Energy Greene 2 LLC) | 10 | Coxsackie Substation 13.8kV | G | S | 03/2023 | IA Executed* | 2021 Q3 STAR |
| 768 | Janis Solar (Janis Solar, LLC) | 20 | Willet 34.5kV | C | S | 04/2022 | IA Executed* | 2021 Q3 STAR |
| 775 | Puckett Solar (Puckett Solar, LLC) | 20 | Chenango Forks Substation 34.5kV | E | S | 04/2022 | IA Executed* | 2021 Q3 STAR |
| 670 | Skyline Solar (SunEast Skyline Solar LLC) | 20 | Campus Rd - Clinton 46kV | E | S | 04/2022 | IA Executed* | 2021 Q3 STAR |
| 584 | Dog Corners Solar (SED NY Holdings LLC) | 20 | Aurora Substation 34.5kV | C | S | 05/2022 | IA Executed* | 2021 Q3 STAR |
| 592 | Niagara Solar (Duke Energy Renewables Solar, LLC) | 20 | Bennington 34.5kV Substation | B | S | 05/2023 | IA Executed | 2021 Q3 STAR |
| 590 | Scipio Solar (Duke Energy Renewables Solar, LLC) | 18 | Scipio 34.5kV Substation | C | S | 05/2023 | IA Executed | 2021 Q3 STAR |
| 682 | Grissom Solar (Grissom Solar, LLC) | 20 | Ephratah - Florida 115kV | F | S | 06/2022 | IA Executed* | 2021 Q3 STAR |
| 748 | Regan Solar (Regan Solar, LLC) | 20 | Market Hill - Johnstown 69kV | F | S | 06/2022 | IA Executed* | 2021 Q3 STAR |
| 545 | Sky High Solar (Sky High Solar, LLC) | 20 | Tilden -Tully Center 115kV | C | S | 06/2023 | IA Executed* | 2021 Q3 STAR |
| 586 | Watkins Road Solar (SED NY Holdings LLC) | 20 | Watkins Rd - Ilion 115kV | E | S | 06/2023 | IA Executed* | 2021 Q3 STAR |

- Note: the proposed Small Gens have Energy Resource Interconnection Service (ERIS) rights; those labeled with a “*” also have Capacity Resource Interconnection Service (CRIS) rights

Proposed Projects Inclusion: Small Generation (cont.)

| NYISO Interconnection Queue # | Project Name/(Owner) | Summer Peak MW | POI | Zone | Type | Queue COD or I/S | Interconnection Status/Class Year | Reliability Base Case Inclusion Status |
|-------------------------------|--|----------------|--|------|------|------------------|-----------------------------------|--|
| 735 | ELP Stillwater Solar (ELP Stillwater Solar LLC) | 20 | Luther Forest - Mohican 115kV | F | S | 09/2022 | IA Executed | 2021 Q3 STAR |
| 666 | Martin Solar (Martin Solar LLC) | 20 | Arcade - Five Mile 115kV | A | S | 10/2022 | IA Executed* | |
| 667 | Bakerstand Solar (Bakerstand Solar LLC) | 20 | Machias - Maplehurst 34.5kV | A | S | 10/2022 | IA Executed* | |
| 565 | Tayandenega Solar (Tayandenega Solar, LLC) | 20 | St. Johnsville - Inghams 115kV | F | S | 10/2022 | IA Executed* | |
| 570 | Albany County 1 (Hecate Energy Albany 1 LLC) | 20 | Long Lane - Lafarge 115kV | F | S | 12/2022 | IA Executed* | |
| 598 | Albany County 2 (Hecate Energy Albany 2 LLC) | 20 | Long Lane - Lafarge 115kV | F | S | 12/2022 | IA Executed* | |
| 638 | Pattersonville (Pattersonville Solar Facility, LLC) | 20 | Rotterdam - Meco 115kV | F | S | 12/2022 | IA Executed* | |
| 730 | Darby Solar (Darby Solar, LLC) | 20 | Mohican - Schaghticoke 115kV | F | S | 12/2022 | IA Executed* | |
| 564 | Rock District Solar (Rock District Solar, LLC) | 20 | Sharon - Cobleskill 69kV | F | S | 12/2022 | IA Executed* | |
| 731 | Branscomb Solar (Branscomb Solar, LLC) | 20 | Battenkill - Eastover 115kV | F | S | I/S | IA Executed* | |
| 759 | KCE NY6 | 20 | Gardenville - Bethlehem Steel Wind 115kV | A | ES | 04/2022 | IA Executed* | 2022 RNA |
| 734 | Ticonderoga Solar (ELP Ticonderoga Solar LLC) | 20 | ELP Ticonderoga Solar LLC | F | S | 8/1/2022 | IA Executed* | |
| 848 | Fairway Solar (SunEast Fairway Solar LLC.) | 20 | McIntyre - Colton 115kV | E | S | 10/1/2023 | IA Executed | |
| 855 | NY13 Solar (Bald Mountain Solar LLC) | 20 | Mohican - Schaghticoke 115kV | F | S | 11/1/2023 | IA Executed | |
| 769 | North County Energy Storage (New York Power Authority) | 20 | Willis 115kV | D | ES | 03/2022 | IA Executed | |
| 807 | Hilltop Solar (SunEast Hilltop Solar LLC) | 20 | Eastover - Schaghticoke 115kV | E | S | 07/2023 | IA Executed | |
| 581 | Hills Solar (SunEast Hills Solar LLC) | 20 | Fairfield - Inghams 115kV | E | S | 08/2023 | IA Executed | |

Note: the proposed Small Gens have ERIS rights; those labeled with a “*” also have CRIS rights

DEC's Peaker Rule Impacts on the 2022 RNA Base Case

DEC Peaker Rule Background

- New York State Department of Environmental Conservation (DEC) adopted a regulation to limit nitrogen oxides (NOx) emissions from simple-cycle combustion turbines (“Peaking Units”) (referred to as the “Peaker Rule”)
- The Peaker Rule required all impacted plant owners to file compliance plans by March 2, 2020
- NYISO has been considering generators’ compliance plans in the development of the 2020 Reliability Needs Assessment Base Case, and will continue to consider and update the assumptions for the 2022 RNA Base Cases

Status Changes Due to DEC Peaker List

| Owner/Operator | Station | Zone | Nameplate (MW) | CRIS (MW) (1) | | Capability (MW) (1) | | Status Change Date (2) | STAR Evaluation or Other Assessment |
|-------------------------------------|-------------------------------|------|----------------|---------------|--------|---------------------|--------|------------------------|-------------------------------------|
| | | | | Summer | Winter | Summer | Winter | | |
| National Grid | West Babylon 4 | K | 52.4 | 49.0 | 64.0 | 41.2 | 63.0 | 12/12/2020 (R) | Other (6) |
| Astoria Generating Company, L.P. | Gowanus 1-8 | J | 20.0 | 16.1 | 21.0 | 16.0 | 21.0 | 2/1/2021 (IIFO) | 2021 Q1/2022 Q2 (5) |
| National Grid | Glenwood GT 01 (4) | K | 16.0 | 14.6 | 19.1 | 13.0 | 15.3 | 2/28/2021 (R) | 2020 Q3 |
| Helix Ravenswood, LLC | Ravenswood 11 | J | 25.0 | 20.2 | 25.7 | 16.1 | 22.4 | 12/1/2021 (IIFO) | 2022 Q1 |
| Helix Ravenswood, LLC | Ravenswood 01 | J | 18.6 | 8.8 | 11.5 | 7.7 | 11.1 | 1/1/2022 (IIFO) | 2022 Q1 |
| Astoria Generating Company, L.P. | Gowanus 1-1 through 1-7 | J | 140.0 | 122.6 | 160.1 | 117.1 | 161.2 | 11/1/2022 (R) | 2022 Q2 |
| Astoria Generating Company, L.P. | Gowanus 4-1 through 4-8 | J | 160.0 | 140.1 | 182.9 | 138.8 | 183.4 | 11/1/2022 (R) | 2022 Q2 |
| Central Hudson Gas & Elec. Corp. | Coxsackie GT | G | 21.6 | 21.6 | 26.0 | 19.2 | 24.0 | 5/1/2023 | |
| Central Hudson Gas & Elec. Corp. | South Cairo | G | 21.6 | 19.8 | 25.9 | 18.9 | 23.0 | 5/1/2023 | |
| Consolidated Edison Co. of NY, Inc. | 74 St. GT 1 & 2 | J | 37.0 | 39.1 | 49.2 | 39.3 | 45.2 | 5/1/2023 | 2022 Q2 |
| Astoria Generating Company, L.P. | Astoria GT 01 | J | 16.0 | 15.7 | 20.5 | 13.6 | 19.0 | 5/1/2023 | |
| NRG Power Marketing, LLC | Astoria GT 2-1, 2-2, 2-3, 2-4 | J | 186.0 | 165.8 | 204.1 | 141.6 | 183.7 | 5/1/2023 (R) | 2022 Q2 |
| NRG Power Marketing, LLC | Astoria GT 3-1, 3-2, 3-3, 3-4 | J | 186.0 | 170.7 | 210.0 | 140.5 | 182.8 | 5/1/2023 (R) | 2022 Q2 |
| NRG Power Marketing, LLC | Astoria GT 4-1, 4-2, 4-3, 4-4 | J | 186.0 | 167.9 | 206.7 | 138.3 | 180.3 | 5/1/2023 (R) | 2022 Q2 |

Notes

1. MW values are from the draft 2022 Load and Capacity Data Report
2. Unless otherwise noted, these dates are those identified by generators in their DEC Peaker Rule compliance plan submittals for transitioning the facility to Retired, Blackstart, or will be out-of-service in the summer ozone season or the date in which the generator entered (or proposed to enter in their Generator Deactivation Notice) Retired (R) or Mothball Outage (MO) or the date on which the generator entered ICAP Ineligible Forced Outage (IIFO)
3. Long Island Power Authority (LIPA) has submitted notifications to the DEC per part 227-3 of the peaker rule stating that these units are needed for reliability allowing these units to operate until at least May 1, 2025. Due to the future nature of these units being operated only as designated by the operator as an emergency operating procedure the NYISO will continue to plan for these units be unavailable starting May 2023
4. These units have indicated they will be out-of-service during the ozone season (May through September) in their compliance plans in response to the DEC peaker rule.
5. The IIFO status for this unit was evaluated in the 2021 Q1 STAR. The proposed Retirement for this unit will be evaluated in the 2022 Q2 STAR.
6. This unit was evaluated in a stand-alone generator deactivation assessment prior to the creation of the Short-Term Reliability Process

Status Changes Due to DEC Peaker List

| Owner/Operator | Station | Zone | Nameplate (MW) | CRIS (MW) (1) | | Capability (MW) (1) | | Status Change Date (2) | STAR Evaluation or Other Assessment |
|-------------------------------------|-----------------------------|------|----------------|---------------|---------|---------------------|---------|------------------------|-------------------------------------|
| | | | | Summer | Winter | Summer | Winter | | |
| Consolidated Edison Co. of NY, Inc. | Hudson Ave 3 | J | 16.3 | 16.0 | 20.9 | 12.3 | 15.6 | 5/1/2023 | 2022 Q2 |
| Consolidated Edison Co. of NY, Inc. | Hudson Ave 5 | J | 16.3 | 15.1 | 19.7 | 15.3 | 18.6 | 5/1/2023 | 2022 Q2 |
| Helix Ravenswood, LLC | Ravenswood 10 | J | 25.0 | 21.2 | 27.0 | 16.0 | 22.3 | 5/1/2023 | |
| National Grid | Glenwood GT03 (3) | K | 55.0 | 54.7 | 71.5 | 44.7 | 66.5 | 5/1/2023 | |
| National Grid | Northport GT | K | 16.0 | 13.8 | 18.0 | 12.0 | 15.7 | 5/1/2023 | |
| National Grid | Port Jefferson GT01 | K | 16.0 | 14.1 | 18.4 | 12.6 | 17.3 | 5/1/2023 | |
| National Grid | Shoreham 1 (3) | K | 52.9 | 48.9 | 63.9 | 44.7 | 64.6 | 5/1/2023 | |
| National Grid | Shoreham 2 (3) | K | 18.6 | 18.5 | 23.5 | 15.7 | 20.0 | 5/1/2023 | |
| Consolidated Edison Co. of NY, Inc. | 59 St. GT1 | J | 17.1 | 15.4 | 20.1 | 13.1 | 18.8 | 5/1/2025 | |
| NRG Power Marketing, LLC | Arthur Kill GT1 | J | 20.0 | 16.5 | 21.6 | 12.1 | 15.1 | 5/1/2025 | |
| Astoria Generating Company, L.P. | Gowanus 2-1 through 2-8 (4) | J | 160.0 | 152.8 | 199.6 | 145.5 | 186.9 | 5/1/2025 | |
| Astoria Generating Company, L.P. | Gowanus 3-1 through 3-8 (4) | J | 160.0 | 146.8 | 191.7 | 137.4 | 183.5 | 5/1/2025 | |
| Astoria Generating Company, L.P. | Narrows 1-1 through 2-8 (4) | J | 352.0 | 309.1 | 403.6 | 291.5 | 382.0 | 5/1/2025 | |
| | Prior to May 2023 | | 432.0 | 371.4 | 484.3 | 349.9 | 477.4 | | |
| | 2023 Total | | 870.3 | 802.9 | 1,005.3 | 684.7 | 898.6 | | |
| | 2025 Total | | 709.1 | 640.6 | 41.7 | 599.6 | 33.9 | | |
| | Total | | 2,011.4 | 1,814.9 | 1,531.3 | 1,634.2 | 1,409.9 | | |

Notes

- MW values are from the draft 2022 Load and Capacity Data Report
- Unless otherwise noted, these dates are those identified by generators in their DEC Peaker Rule compliance plan submittals for transitioning the facility to Retired, Blackstart, or will be out-of-service in the summer ozone season or the date in which the generator entered (or proposed to enter in their Generator Deactivation Notice) Retired (R) or Mothball Outage (MO) or the date on which the generator entered ICAP Ineligible Forced Outage (IIFO)
- Long Island Power Authority (LIPA) has submitted notifications to the DEC per part 227-3 of the peaker rule stating that these units are needed for reliability allowing these units to operate until at least May 1, 2025. Due to the future nature of these units being operated only as designated by the operator as an emergency operating procedure the NYISO will continue to plan for these units be unavailable starting May 2023
- These units have indicated they will be out-of-service during the ozone season (May through September) in their compliance plans in response to the DEC peaker rule.
- The IIFO status for this unit was evaluated in the 2021 Q1 STAR. The proposed Retirement for this unit will be evaluated in the 2022 Q2 STAR.
- This unit was evaluated in a stand-alone generator deactivation assessment prior to the creation of the Short-Term Reliability Process

Other Proposed Deactivations

Does not include status changes due to DEC Peaker Rule

| Owner/ Operator | Plant Name | Zone | PTID | Nameplate | CRIS (MW) | | Capability (MW) | | Status | Deactivation date |
|---------------------------------|-------------------------------|------|--------|-----------|-----------|--------|-----------------|--------|--------|-------------------|
| | | | | (MW) | Summer | Winter | Summer | Winter | | |
| Seneca Power Partners. L.P. | Allegheny Cogen (1) | B | 23514 | 67 | 62.9 | 82.2 | 62.0 | 62.7 | R | 05/02/2022 |
| Seneca Power Partners. L.P. | Sithe Batavia (1) | B | 24024 | 67.3 | 57.1 | 71.7 | 48.7 | 59.0 | R | 05/02/2022 |
| Seneca Power Partners. L.P. | Sithe Sterling (1) | B | 23777 | 65.3 | 57.4 | 72.1 | 49.2 | 61.9 | R | 05/02/2022 |
| ENGIE Energy Marketing NA, Inc. | Nassau Energy Corporation (2) | K | 323695 | 55 | 51.6 | 60.1 | 38.5 | 51.0 | R | 03/31/2022 |
| Exelon Generation Company, LLC. | Madison County LF (2) | E | 323628 | 1.6 | 1.6 | 1.6 | 1.6 | 1.6 | IIFO | 04/01/2022 |
| | | | Total | 256.2 | 230.6 | 287.7 | 200 | 236.2 | | |

Notes

(1) This deactivation is assessed in the 2022 Quarter 1 Short-Term Assessment of Reliability

(2) This deactivation is assessed in the 2022 Quarter 2 Short-Term Assessment of Reliability

Questions?

Our Mission & Vision



Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation