

2022 Quarter 2 Short-Term Assessment of Reliability Generator Deactivations

Generating Unit	Submitting Entity	PTID	Responsible Transmission Owner	Zone	Nameplate MW	Current Generator Status	Retire/Mothball Outage/ICAP Ineligible Forced Outage (IIFO)	Proposed Deactivation/IIFO Date
Trigen CC (2)	Nassau Energy, LLC	323695	LIPA	K	55	In Service	Retire	3/31/2022 (1)
Madison County LF (2)	Exelon Generation Company, LLC	323628	National Grid	E	1.6	IIFO	IIFO	4/1/2022
Gowanus 1-1	Eastern Generation, LLC	24077	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-2	Eastern Generation, LLC	24078	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-3	Eastern Generation, LLC	24079	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-4	Eastern Generation, LLC	24080	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-5	Eastern Generation, LLC	24084	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-6	Eastern Generation, LLC	24111	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-7	Eastern Generation, LLC	24112	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 1-8 (3)	Eastern Generation, LLC	24113	Con Edison	J	20	IIFO	Retire	11/1/2022
Gowanus 4-1	Eastern Generation, LLC	24130	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-2	Eastern Generation, LLC	24131	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-3	Eastern Generation, LLC	24132	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-4	Eastern Generation, LLC	24133	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-5	Eastern Generation, LLC	24134	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-6	Eastern Generation, LLC	24135	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-7	Eastern Generation, LLC	24136	Con Edison	J	20	In Service	Retire	11/1/2022
Gowanus 4-8	Eastern Generation, LLC	24137	Con Edison	J	20	In Service	Retire	11/1/2022
Hudson Ave 3	Consolidated Edison Company of New York, Inc	23810	Con Edison	J	16.3	In Service	Retire	11/1/2022
Hudson Ave 5	Consolidated Edison Company of New York, Inc	23657	Con Edison	J	16.3	In Service	Retire	11/1/2022
74th Street GT 1	Consolidated Edison Company of New York, Inc	24260	Con Edison	J	18.5	In Service	Retire	5/1/2023
74th Street GT 2	Consolidated Edison Company of New York, Inc	24261	Con Edison	J	18.5	In Service	Retire	5/1/2023
Astoria GT 2-1	Astoria Gas Turbine Power LLC	24094	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 2-2	Astoria Gas Turbine Power LLC	24095	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 2-3	Astoria Gas Turbine Power LLC	24096	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 2-4	Astoria Gas Turbine Power LLC	24097	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 3-1	Astoria Gas Turbine Power LLC	24098	Con Edison	J	46.5	In Service	Retire	5/1/2023

<i>Generating Unit</i>	<i>Submitting Entity</i>	<i>PTID</i>	<i>Responsible Transmission Owner</i>	<i>Zone</i>	<i>Nameplate MW</i>	<i>Current Generator Status</i>	<i>Retire/Mothball Outage/ICAP Ineligible Forced Outage (IIFO)</i>	<i>Proposed Deactivation/IIFO Date</i>
Astoria GT 3-2	Astoria Gas Turbine Power LLC	24099	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 3-3	Astoria Gas Turbine Power LLC	24100	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 3-4	Astoria Gas Turbine Power LLC	24101	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 4-1	Astoria Gas Turbine Power LLC	24102	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 4-2	Astoria Gas Turbine Power LLC	24103	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 4-3	Astoria Gas Turbine Power LLC	24104	Con Edison	J	46.5	In Service	Retire	5/1/2023
Astoria GT 4-4	Astoria Gas Turbine Power LLC	24105	Con Edison	J	46.5	In Service	Retire	5/1/2023

Notes

1. The submitting entity has proposed to deactivate the generator on March 31, 2022, which is less than the 90 days after the Generator Deactivation Notice was determined to be complete. The earliest possible retirement date for the generator is July 15, 2022. See OATT Section 38.3.7 for additional requirements.
2. This unit is not a DEC peaker unit
3. The Gowanus 1-8 unit has been IIFO since February 1, 2021. The IIFO for this generator was evaluated in the 2021 Quarter 1 Short-Term Assessment of Reliability