

2022-23 Winter Assessment & Winter Preparedness

Aaron Markham

VICE PRESIDENT OPERATIONS, New York ISO

NYISO Management Committee

November 30, 2022

Agenda

- **Key Observations**
- **Winter 2022-23 Capacity Assessment**
- **Winter 2022-23 Preparedness**
- **Infrastructure Updates**
- **Appendix A: Regional and Local Fuel Inventories & Fuel Prices**
- **Appendix B: Short Term Fuel and Energy Security Assessment**
- **Appendix C: Fuel & Energy 2024 Study; Update Tracking & Monitoring**


Key Observations – 2022-23 Winter Capacity Assessment

- The NYISO expects sufficient winter capacity margins assuming all firm and non-firm fuel generation available under normal and extreme weather conditions
 - 10,296 MW - capacity margin for 50-50 peak forecast conditions
 - 9,067 MW - capacity margin for 90-10 peak forecast conditions
 - 8,103 - capacity margin for 99-1 peak forecast conditions
- Winter capacity margins assuming all firm and non-firm fuel generation available are declining (1,140 MW reduction since Winter 2018-19)
 - Non-firm fuel generation includes gas-only fired generation without firm gas transportation contract arrangements.
 - Firm fuel generation includes all generation types other than non-firm fuel generation (e.g., nuclear, hydro, wind, solar, oil fired only, dual fuel capable, gas only with firm gas transportation)

Key Observations – 2022-23 Winter Capacity Assessment

- The NYISO expects sufficient winter capacity margins assuming only firm fuel generation available under normal and extreme weather conditions
 - 3,813 MW - capacity margin for 50 -50 peak forecast conditions
 - 2,584 MW - capacity margin for 90-10 peak forecast conditions
 - 1,620 MW - capacity margin for 99-1 peak forecast conditions
- Winter capacity margins assuming only firm fuel generation available has declined significantly (3,007 MW reduction since Winter 2018-19)
- Continued reductions in winter capacity margins, disruptions in fuel supplies or other winter operational concerns may result in operational challenges given the reliance on firm fuel generation during extreme cold weather events. NYISO and stakeholders have prioritized a 2023 project to update the 2019 Energy and Fuel Security Assessment to evaluate operational reliability needs

Winter 2018-19 to Winter 2022-23 Capacity Margins



| | 18-19 | 19-20 | 20-21 | 21-22 | 22-23 |
|--------------------------------|--------|--------|-------|-------|--------|
| 50/50 - Firm and Non-Firm Fuel | 11,436 | 10,900 | 9,638 | 9,080 | 10,296 |
| 50/50 - Only Firm Fuel | 6,820 | 5,668 | 4,447 | 2,730 | 3,813 |
| 90/10 - Firm and Non-Firm Fuel | 9,821 | 9,299 | 8,309 | 7,916 | 9,067 |
| 90/10 - Only Firm Fuel | 5,205 | 4,067 | 3,118 | 1,566 | 2,584 |
| 99/1 - Firm and Non-Firm Fuel | | | | 6,875 | 8,103 |
| 99/1 - Only Firm Fuel | | | | 525 | 1,620 |

Winter Assessment Summary

- Capacity included from NYISO Gold Book
- Capacity is adjusted for projected and actual additions and deactivations
- Two Fuel Cases: Base Case & Loss of Gas
- Three Weather Scenarios: Normal, 90/10 Cold Weather, 99/1 Cold Weather

2021-22 & 2022-23 Winter Capacity Assessment & Comparison

| Line | Item | 2021-22 | | 2022-23 | | |
|------------------|---|-------------------|--------------------------|-------------------|--------------------------|--------------------------|
| | | Baseline Forecast | 90th Percentile Forecast | Baseline Forecast | 90th Percentile Forecast | 99th Percentile Forecast |
| 1a | Winter Generation Capacity ¹ | 40,239 | 40,239 | 40,393 | 40,393 | 40,393 |
| 1b | SCR - ICAP Values | 630 | 630 | 694 | 694 | 694 |
| 1c | Net Purchases & Sales | 1,546 | 1,546 | 2,097 | 2,097 | 2,097 |
| 1 | Total Capacity Resources | 42,415 | 42,415 | 43,184 | 43,184 | 43,184 |
| 2 | Assumed Unavailable Capacity (Gen+SCR)² | -6,690 | -6,690 | -6,375 | -6,375 | -6,375 |
| 3 = 1 + 2 | Net Capacity Resources | 35,725 | 35,725 | 36,809 | 36,809 | 36,809 |
| 4 | Peak Load Forecast | 24,025 | 25,189 | 23,893 | 25,122 | 26,086 |
| 5 | Operating Reserve Requirement | 2,620 | 2,620 | 2,620 | 2,620 | 2,620 |
| 6 = 4 + 5 | Total Capacity Requirement | 26,645 | 27,809 | 26,513 | 27,742 | 28,706 |
| 7 = 3 - 6 | Capacity Margin | 9,080 | 7,916 | 10,296 | 9,067 | 8,103 |

1. Reflects the 2022 Gold Book existing capacity with projected and actual deactivations and additions during 2022-23
2. Derates: 2,073 MW for wind, 515 MW for Hydro, 2,472 MW for thermal units, 82 MW for other renewables, and 326 MW for SCRs.

- 2021-2022 actual winter peak load was 23,235 MW on January 11 HB 17.
- The all-time winter peak was 25,738 MW, set on January 7, 2014

2022-23 Winter Capacity Assessment - Gas Scenarios

| Line | Item | Baseline Forecast | 90th Percentile Forecast | 99/1 Forecast |
|--------------------|--|-------------------|--------------------------|---------------|
| 1a | Installed Capacity Resources | 40,393 | 40,393 | 40,393 |
| 1b | SCR - ICAP Values | 694 | 694 | 694 |
| 1c | Net ICAP External Imports | 2,097 | 2,097 | 2,097 |
| 1 | NYCA Resource Capability | 43,184 | 43,184 | 43,184 |
| 2 | Total Projected Capacity Outages | -6,375 | -6,375 | -6,375 |
| 3 = (1-2) | Net Installed Capacity Resources | 36,809 | 36,809 | 36,809 |
| 4 | Load Forecast | 23,893 | 25,122 | 26,086 |
| 5 | Operating Reserve Requirement | 2,620 | 2,620 | 2,620 |
| 6 = (3-4-5) | Capacity Margin | 10,296 | 9,067 | 8,103 |
| 7a | Subtract All Gas Only Units and Duct Burner Capabilities | -8,968 | -8,968 | -8,968 |
| 7 = (6-7a) | Capacity Margin, Loss of Gas | 1,328 | 99 | -865 |
| 8a | Add Back Units with Firm Gas Contracts | 2,484 | 2,484 | 2,484 |
| 8 = (7-8a) | Expected Capacity, Loss of Non-Firm Gas Case | 3,813 | 2,584 | 1,620 |

- Duct Burner derates account for approximately 500 MW

Winter 2022-23 Operational Preparedness

- ISO Operations is monitoring regional fuel supplies as indications are these could be limited in supply this winter. US Energy Information Administration (EIA) indicates oil inventories both regionally and throughout the United States are below historical values.
- Seasonal and weekly fuel surveys indicate oil and dual fuel capability generation have lower than normal start-of-winter oil inventories. Outreach to generators whose inventory level was significantly lower than 1 year ago generally indicates replenishments are planned prior to winter. See Appendix B “Total weekly oil inventory in MWh”
- ISO Operations has surveyed most generating stations to discuss past winter operations, preparations for the upcoming winter, including last dual fuel operation, cold-weather preventative maintenance, fuel procurement arrangements, and fuel switching capabilities.
- ISO Operations’ coordination of transmission and generation maintenance outages helps mitigate the reliability impact of such outages during extreme cold weather periods.

Winter 2022-23 Operational Preparedness

- Participated in various communications and coordination efforts with NERC, state agencies (DPS, NYSERDA), other ISOs/RTOs, and gas industry personnel, including Interstate Natural Gas Association of America (INGAA), Natural Gas Supply Association (NGSA), Northeast Gas Association (NGA), NY pipelines, and NY LDCs
- **NERC Project 2019-06 Cold Weather was completed and approved resulting in changes to the EOP-011, IRO-010, and TOP-003 Standards, effective April 1, 2023**
 - EOP-011-2 requires generators to have a cold weather preparedness plan for its generators and to provide this information to their Transmission Operator (TOP). NYISO is performing an analysis of the minimum operating temperatures provided via the annual GFER survey to use in future efforts.

<https://www.nerc.com/pa/Stand/Pages/Project%202019-06%20Cold%20Weather.aspx>

Winter 2022-23 Operational Preparedness

- The NYISO continues to monitor and evaluate important events and ongoing industry actions in response to potential winter reliability concerns and provided its review of the final FERC-NERC joint inquiry report at the March 17, 2022 Operating Committee meeting
- NYISO led a review of load shedding processes/procedures and coordination of the gas-electric critical infrastructure survey with the New York Transmission Owner Planning Working Group (TOPWG)
- Defined and implemented Tariff modifications to support Critical Electric System Infrastructure Load (CESIL) being excluded from NYISO Demand Response Programs

Gas-Electric Coordination

- **A communications protocol is in place with NY state agencies to improve the speed and efficiency of generator requests to state agencies for emissions waivers if needed for reliability**
 - Protocol was leveraged in January 2018 and proved effective in facilitating communications between parties
- **An emergency communications protocol is in place to communicate electric reliability concerns to pipelines and gas LDCs during tight electric operating conditions**
 - Cooperative process with interstate pipelines and LDCs for providing OFO information to the NYISO
- **FERC Order No. 787**
 - The NYISO modified its Code of Conduct (ISO OATT Att F) per the Order to accommodate pipeline requests for reliability information

Situational Awareness

- **Control Room gas-electric support**
- **Video boards**
 - Northeast interstate pipeline system is displayed
 - Operational Flow Orders are displayed with readily detectable visualization techniques
 - Continuously enhancing weather displays to analyze potential impacts on NY generation and loads
- **A web-based, fuel survey “portal” provides generator fuel information to the operators**
 - Updated weekly by generators
 - Updated daily during cold weather conditions, upon request by the NYISO

Other Winter Operational Challenges

- **Intra-day Gas Procurement-** Gas only fired generating resources are likely to be unavailable for operation if not scheduled in the ISO's day-ahead energy market due to the difficulty in procuring intra-day gas
- **Alternate Fuel Replenishment-** Generator burn rates of alternative fuels can exceed replacement rates during extreme cold weather conditions
- **Emissions Limitations-** Use of alternate distillate fuels by oil or dual fuel capable generation may be further restricted by emission limits
- **Retail Gas LDC Priority -** Gas Local Distribution Company (LDC) retail gas demand has priority over electric power generation

Generation Deactivations*

| StationName | Nameplate MW |
|-------------------------------------|--------------|
| Ravenswood GT 11 (IIFO) | 25 |
| Sterling (proposed retirement) | 65 |
| Nassau Energy Corporation (retired) | 55 |
| Hudson Avenue 3 | 16 |
| Hudson Avenue 5 | 16 |
| Gowanus 1-1 through 1-7 | 140 |
| Gowanus 4-1 through 4-8 | 160 |
| TOTAL | 477 |

* Since the 2022 Summer Assessment

Generation Additions*

| Station Name | Nameplate MW |
|-------------------------------|--------------|
| Ball Hill Wind | 100 |
| Eight Point Energy Center | 101 |
| Baron Wind (Phase 1) | 118 |
| Calverton Solar Energy Center | 23 |
| Number 3 Wind Energy | 106 |
| Bluestone Wind | 124 |
| Bear Ridge Solar | 100 |
| TOTAL | 672 |

* Since the 2022 Summer Assessment

Transmission Operations


| Equipment | Voltage (kV) | Status |
|--|--------------|--|
| Hudson-Farragut B3402 | 345 | Out-of-Service |
| Marion-Farragut C3403 | 345 | Out-of-Service |
| St. Lawrence-Moses L34 PAR | 230 | Out-of-Service |
| Warren-Falconer 171 | 115 | Operated Normally Open |
| Sprain Brook/Dunwoodie Series Reactors | 345 | Bypassed |
| Marcy South Series Capacitors | 345 | Bypassed |
| Moses-Adirondack MA-1 or MA-2 | 230 | Out-of-Service for rebuild, 48 hour recall |
| Sprainbrook-East Garden City Y49 | 345 | Out-of-Service until May 31 |
| Moses-Willis MW1 | 230 | Out-of-Service for rebuild, 24 hour recall |

Appendix A


Regional and Local Fuel Inventories

Natural gas underground storage levels

Lower 48 weekly working gas in underground storage




East region weekly working gas in underground storage




Distillate Inventories

U.S. distillate stocks
million barrels




Data source: U.S. Energy Information Administration

Mid-Atlantic Ultra-low Sulfur Diesel Stocks
(0-15 ppm) (source: US EIA)



Mid-Atlantic Total Distillate Stocks
(source: US EIA)




LNG export capability exposing domestic natural gas markets to global dynamics



U.S. Natural Gas Prices Exponentially Lower Than EU, Asia

Global LNG price


\$/MMBTU



2022-2023 Winter Outlook | 13

Source: ICE. Future curves are based on 8/17/2022 settlements






NYISO Fuel Prices

September 2020 thru November 2, 2022

including Crude Oil price, data sources: SNL and EIA (oils thru 10/31/2022)

- NY ULSD \$/mMBTU
- Niagara \$/mMBTU
- Algon Gates \$/mMBTU
- TGP Z 5 \$/mMBTU
- Iroquois Zone2 \$/mMBTU
- Transco Z6 NY \$/mMBTU
- Cushing OK Crude Oil \$/bbl



NYISO Fuel Price November 2021 thru November 2, 2022

including Crude Oil price, data sources: SNL and EIA (oils thru 10/31/2022)

- NY ULSD \$/mmBTU
- Niagara \$/mmBTU
- Algon Gates \$/mmBTU
- TGP Z5 \$/mmBTU
- Iroquois Zone2 \$/mmBTU
- Transco Z6 NY \$/mmBTU


2021


2022

Thu, 07/21/2022, 29.35

USD and gas
\$/mmBTU

11/04/2021 12/01/2021 01/01/2022 02/01/2022 03/01/2022 04/01/2022 05/01/2022 06/01/2022 07/01/2022 08/01/2022 09/01/2022 10/01/2022 11/01/2022





Appendix B

Day 1-14


Fuel and Energy Assessments

Operations Internal Energy Assessment Tool

- **Different from the Analysis Group (“AG”) Fuel and Energy Security model, this Internal Energy Assessment tool gives NYISO the ability to:**
 - Observe the reported fuel inventory levels and scheduled replenishments
 - Monitor the load forecast up to 30 days in the future
 - Apply commitment/dispatch assumptions to monitor fuel/energy shortfalls
 - Model scenarios and disruptions similar to the 2019 FES study



Internal Energy Assessment Tool – Forecast (Typical Spring or Fall Day)

- No/minor scheduled deliveries (1.5 million MWh)
- Low shoulder season loads (19,500 MW peak)
- Gas available for firm and gas only units, 50% dual fuel capable MWs from gas




Internal Energy Assessment Tool – Forecast, Cold Snap assumptions

- No/minor scheduled deliveries (1.5 million MWh)
- Low shoulder season loads (19,500 MW peak)
- **Limited gas only generation (4,500 MW), no gas for dual fuel units**





Internal Energy Assessment model – Extreme Cold, Cold Snap assumptions

- No/minor scheduled deliveries (1.5 million MWh)
- **Extreme Cold Weather Load Forecast (Similar to 17-18, - 25,200 MW)**
- Limited gas only generation (4,500 MW), no gas for dual fuel units




Internal Energy Assessment model – Extreme Cold, Cold Snap assumptions

- No/minor scheduled deliveries (1.5 million MWh)
- Extreme Cold Weather Load Forecast (Similar to 17-18, - 25,200 MW)
- **Gas available for firm and gas only units, 25% dual fuel capable MWs from gas**




Internal Energy Assessment model – Extreme Cold, Cold Snap assumptions

- **Generic refill assumptions similar to AG 2019 FES model**
- **Extreme Cold Weather Load Forecast (Similar to 17-18, - 25,200 MW)**
- **Limited gas only generation (4,500 MW), no gas for dual fuel units**



Total Weekly Oil Inventory in MWh from 11/02/2021 to 11/01/2022



Appendix C

2024 Fuel & Energy

Assessment Tracking

of Actual

Developments

Fuel Security Study Tracking

- Fuel Security monitoring will be updated at least twice each year and compared to the assumptions in the 2019 FES study
- Identification of large deviations between (1) actual conditions and the conditions assessed in the 2019 FES study and/or (2) the assumptions used by the 2019 FES study that could adversely impact reliability would trigger a need to collaborate with stakeholders on refreshing the study

Fall 2022 Fuel Security

Monitoring page 1

| Item | Actual 2019/20 | Actual 2020/21 | Actual 2021/22 | Actual/ Forecast 2022/23 | Forecast 2023/24 | Forecast 2025/26 | Study 2023/24 | Assumptions |
|---|-------------------|-------------------|-------------------|--------------------------------|---------------------|---------------------|-------------------------------------|-------------|
| <u>Deployment of new renewable and clean energy resources</u> | | | | | | | | |
| 1) Wind | 1,739 MW | 1,739 MW | 1,818 MW | 1,818 MW | 2,763 MW | 3,340 MW | 2,531 - 5,274 MW | |
| 2) Solar (Utility scale) | 32 MW | 32 MW | 32 MW | 52 MW | 882 MW | 1,786 MW | 2,728 - 7,086 MW (BTM & Utility) | |
| 2a) Solar (BTM) | 2,244 MW | 2,786 MW | 3,523 MW | 4,269 MW | 5,152 MW | 6,826 MW | 2,728 - 7,086 MW (BTM & Utility) | |
| 3) Energy Storage | 207 MW | 292 MW | 638 MW | 882 MW | 1,395 MW | 1,778 MW | 350 MW (4 hr) | |
| 4) Offshore Wind | 0 MW | 0 MW | 0 MW | 0 MW | 136 MW | 136 MW | 0 MW 1,696 MW (2024) | |
| NYSDEC "Peaker Rule" impact | 0 MW | 100 MW | 131 MW | 131 MW | 1,241 MW | 1,276 MW | 1,350 MW | |
| Pollution Justice Act of 2021 | - | - | - | - | N/A | N/A | N/A | |
| Winter Peak & 90/10 Forecast | 23,253 MW | 22,542 MW | 23,235 MW | - | 25,535 MW | 26,007 MW | 26,458 MW | |
| Nuclear Nameplate Capacity | 5,424 MW | 4,405 MW | 3,358 MW | 3,358 MW | 3,358 MW | 3,358 MW | 1,435 - 3,356 MW | |
| SCR/EDRP Capability (Winter) | 853 MW | 839 MW | 630 MW | 694 | 694 MW | 694 MW | 893 MW | |

Fall 2022 Fuel Security Monitoring page 2

Status Key:

Well aligned with FES study

Trending towards bounds FES study

Deviating from FES study with potential impact to reliability

| Item | Actual | Actual | Actual | Actual | Actual/Forecast | Study Assumptions |
|--|--------------------------------------|-------------------------------------|-------------------------------------|-----------------------------------|-----------------------------------|--------------------------------------|
| <i>System Metrics</i> | 2018/19 | 2019/20 | 2020/21 | 2021/22 | 2022/23 | 2023/24 |
| Largest Hydro and Thermal Forced Outages | 3,169 MW (1/22/19) | 2,299 MW (12/19/19) | 4,704 MW (1/29/21) | 2,645 MW (1/29/22) | - | 2,576 - 5,152 MW |
| Gas only generator outages due to lack of fuel | 632 MW | 160 MW | 2,110 MW | 1,905 MW | - | 3,196 MW |
| Change in oil nameplate capacity | - | -73 MW | 137 MW | 4 MW | 0 MW | 0 to -2,185 MW |
| Winter starting/ending oil inventory (MWh) | 2,008,788 MWh 2,040,097 MWh | 2,038,589 MWh 1,948,550 MWh | 1,971,746 MWh 1,795,308 MWh | 1,874,101 MWh 1,225,457 MWh | 1,518,432 MWh - | Approx. 1,000,000 - 2,000,000 MWh |
| Interchange over Winter Peak | 2,890 MW | 3,806 MW | 3,541 MW | 3,387 MW | - | -1,600MW to 900MW |
| Winter Peak Real Time Fuel Mix: | | | | | | |
| Natural Gas (NG) | 3,935 MW | 4,454 MW | 3,856 MW | 3,216 MW | - | NG 3,500 - 2,000 (A-F) |
| Dual Fuel (DF) | 5,651 MW | 4,426 MW | 5,430 MW | 8,768 MW | | NG 2,500 - 1,000 (G-K), 0MW (J-K) |
| Firm Gas Generators | 1,915 MW | 1,911 MW | 371 MW | 2,484 MW | 2,484 MW | 1,915 MW |
| Pipeline Capacity | I: 13,963 MMcf/d Ex: 6,827 MMcf/d | I:13,978 MMcf/d Ex: 6,827 MMcf/d | I:13,978 MMcf/d Ex: 6,827 MMcf/d | I:13,978 Bcf/d Ex: 6,827 Bcf/d | I:13,978 Bcf/d Ex: 6,827 Bcf/d | I: 13,923 MMcf/d Ex: 7,136 MMcf/d |
| WNY PPTN transmission project | AC transmission projects selected | 2020 RNA COD 12/2023 | 2020 RNA COD 12/2023 | In-Service 12/23 (expected) | In-Service 12/23 (expected) | In-Service |
| AC Transmission project (A&B) | | | | | | |
| SCR/EDRP Activations | 0 | 0 | 0 | 0 | - | 5 activations/4 hours |

Our Mission & Vision



Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

Questions?