



2023 Locality Bulk Power Transmission Capability Report

**For Use in Establishing the Transmission
Security Limits (TSL) for NYISO Locational
Capacity Requirements (LCRs)**

**A Report by the
New York Independent System Operator**

Table of Contents

INTRODUCTION	3
SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS	4
Analysis Tool and System Representation	4
Base Case Study Modeling Assumptions	5
SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS	7
TABLE 1 – Zone K Locality Limit	8
TABLE 2 – G-J Locality Limit	8
TABLE 3 – Zone J Locality Limit	8
TABLE 4 – Comparison of 2022 & 2023 Locality Limits	8
APPENDIX A – TSL INTERFACE DEFINITIONS	9

Introduction

In support of the NYISO's administration of its Installed Capacity (ICAP) market and pursuant to Section 5.11.4 of the Market Services Tariff, the NYISO annually determines Transmission Security Limits (TSLs) that are used to establish Locational Minimum Installed Capacity Requirements (LCRs). The TSLs are used in the determination of the Capability Year LCRs for the ICAP Localities (*i.e.*, G-J Locality, Zone J, and Zone K).¹ They act as hard limits when establishing the LCRs for each Locality. This report documents the bulk power transmission capability inputs that the NYISO will use to determine the TSLs.

The transmission interfaces for each of the three Localities are defined for the purposes of determining the bulk power transmission capabilities. Each transmission interface is represented by specific transmission elements as shown in Appendix A.

The bulk power transmission capability determinations for the G-J and Zone K Locality interfaces utilize NYS Reliability Council Planning Criteria. For the interfaces for each of these Localities, generation and phase angle regulator schedules for the N-1 outage case are developed to maximize the respective Locality import capabilities while maintaining all bulk power system transmission element power flows related to the respective interfaces within Normal ratings (*i.e.*, N-1-0). The NYISO then evaluated NPCC criteria contingencies for the N-1 outage case so that all bulk power system transmission element power flows related to the respective interfaces are within applicable Long Term Emergency (LTE) ratings (*i.e.*, N-1-1).

For the Zone J Locality limit, the bulk power transmission capability determination uses NYS Reliability Council Local Reliability Rule G.1-R1. The G.1-R1 Rule states that "Certain areas of the Con Edison system are designed and operated for the occurrence of a second contingency." Consistent with the G.1-R1 Rule, generation and phase angle regulator schedules for the N-2 outage cases are developed to maximize the Locality import capability while maintaining all bulk power system transmission element power flows related to the Zone J interface within Normal ratings (*i.e.*, N-2-0).

¹ On October 5, 2018, FERC issued an Order accepting revisions to the NYISO's Market Services Tariff that became effective October 9, 2018. These changes establish the methodology used to determine LCRs. This method is based upon an economic optimization algorithm to minimize the total cost of capacity for the NYCA at the capacity markets design condition, *New York Independent System Operator, Inc.*, 154 FERC ¶ 61,001 (2018).

SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS

The following section discusses evaluations performed to identify the transmission capability inputs for the G-J, Zone J, and Zone K Locality interfaces.

The bulk power transmission capabilities provided in this report are based on the forecasted load and generation and phase angle regulator schedule assumptions.

Analysis Tool and System Representation

The Siemens PTI PSS®E and PowerGEM's Transmission Adequacy and Reliability Assessment "TARA" software packages were used to calculate the bulk power transmission capability thermal limits based on Normal Transfer Criteria defined in the "NYSRC Reliability Rules for Planning and Operating the New York State Power System."

The NYISO developed the system representation from the modified 2022 Summer Operating Study base case. The primary differences between the system representation in the 2022 Summer Operating Study base case and the 2023-2024 TSL base case employed in this analysis relate to planned or forced power system outages. The 2022 Summer Operating Study base case included transmission equipment outages that were expected through the Summer 2022 Capability Period. The TSL base case employed in this analysis restored all transmission and generation elements to service, creating an all-equipment-in-service base case. Significant transmission facility changes compared to the 2022 Summer Operating Study base case include:

- Leeds – Hurly Ave. 345 kV Smart Wire Project
- Portions of the Segment A Double Circuit Project
- Portions of the 115kV system upgrades related to the Segment B project

The Leeds to Hurley Avenue 345 kV Smart Wire Project consists of the installation of Smart Wires SmartValve technology utilizing a bank design instead of a traditional series capacitor installation. The SmartValve installation will be located at the Hurley Avenue Substation. The SmartValve technology is a modular Static Synchronous Series Compensator (SSSC) that uses variable voltage injection to synthesize a capacitive or inductive reactance.

The Segment A Double Circuit Project modifications that will be in-service for the summer 2023 Capability Period were modeled in-service. These modifications consist of:

- Retiring the two Porter – Rotterdam 230 kV #30 and #31 lines
- The addition of the Edic – Gordon Road 345 kV 14 line

- The addition of the Princetown 345 kV station
- The addition of the Princetown – Gordon Rd 345 kV 371 line
- The addition of the two Gordon Road 345/230 kV transformers.
- Modeling the Rotterdam – New Scotland (13) 115 kV line out-of-service.
- The addition of the Princetown – New Scotland 345 kV 55, 361 and 362 lines

The Segment B 115 kV modifications include changes to the Churchtown 115kV station topology.

Base Case Study Modeling Assumptions

There are two transmission facilities that are included in the ICAP Locality interface definitions controlled by phase angle regulators. For both the Zone J and Zone K Localities, the Jamaica-Lake Success and the Jamaica- Valley Stream 138kV transmission facilities assume a net flow of 300 MW from the Zone K Locality to the Zone J Locality.

The phase angle regulator schedules used in the base case power flow for this analysis assumed a net flow of 0 MW from Public Service Electric & Gas (PSE&G) to Con Edison via the PAR transformer controlling the Linden – Goethals interconnection and 0 MW on the South Mahwah – Waldwick circuits from Consolidated Edison to PSE&G, controlled by the PARs at Waldwick. For the Summer 2022 Capability Period used in the base case, the NYISO included a 360 MW schedule for the Hopatcong – Ramapo 500 kV (5018) tie from PJM to New York.

The four Ontario – Michigan PARs are modeled in-service and scheduled to a 0 MW transfer. These phase angle regulator schedules are consistent with the scenarios developed in the RFC-NPCC Inter-Regional Reliability Assessment for Summer 2021, and the MMWG Summer 2020 power flow base cases.

The series reactors on the Dunwoodie – Mott Haven (71 and 72), the Sprain Brook – W. 49th St. (M51 and M52) 345 kV cables, are in-service in the base case. The series reactors on the Sprain Brook – East Garden City (Y49) 345 kV and the Farragut – Gowanus (41 and 42) 345 kV cables are by-passed. This is a change from the 2022-2023 base case. The Packard – Sawyer (77 and 78) 230 kV cables, as well as the E. 179th St. – Hell Gate (15055) 138 kV feeder are in-service. The series capacitors on the Marcy – Coopers Corners (UCC2-41) 345 kV, the Edic – Fraser (EF24-40) 345 kV and the Fraser – Coopers Corners (33) 345 kV cables are in-service in the base case. The Leeds – Hurley Ave. 345 kV static synchronous series compensator is modeled in-service in the base case.

Consistent with NYS Reliability Council Transmission Planning criteria, the TSL base case model utilizes MVA ratings for the transmission elements identified in Appendix A.

SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS

- **Table 1 – Zone K Locality Limit**
- **Table 2 – G-J Locality Limit**
- **Table 3 – Zone J Locality Limit**
- **Table 4 – Comparison of 2022 & 2023 Locality Limits**

TABLE 1 – Zone K Locality Limit

	Limit
N-1 Outage applied (Sprain Brook – East Garden City (Y49) 345 kV)	325 MW (1)

LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1) Dunwoodie – Shore Road (Y50) 345 kV	@LTE 964 MVA ₁ L/O	Neptune HVDC (660MW)

Note:

1: LIPA rating for Y50 circuit is based on 70 % loss factor and rapid oil circulation.

TABLE 2 – G-J Locality Limit

	Limit
N-1 Outage applied (Athens – Pleasant Valley (91) 345 kV)	3425 MW (1)

LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1) Leeds – Pleasant Valley (92) 345 kV	@LTE 1538 MVA L/O	(T:34&44) Dolson – Rock Tavern (DART44) 345 kV Coopers Corners – Middletown TAP (CCRT34) 345 kV Middletown TAP – Rock Tavern (CCRT34) 345 kV Middletown TAP 345/138 kV Transformer

TABLE 3 – Zone J Locality Limit

	Limit
N-2 Outages applied (Dunwoodie - Mott Haven (72) 345 kV & Ravenswood 3(980MW))	2875 MW (1)

LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1) Dunwoodie – Mott Haven (71) 345 kV	@NORM 785 MVA	Pre-Contingency Loading

TABLE 4 – Comparison of 2022 & 2023 Locality Limits

Locality	2023 Limit	2022 Limit	Difference
Zone K Locality	325 MW	325 MW	0 MW
G-J Locality	3425 MW	3425 MW	0 MW
Zone J Locality	2875 MW	2900 MW	-25 MW

Appendix A – TSL INTERFACE DEFINITIONS

G-J Locality		
Mohawk (Zone E) – Hudson Valley (Zone G)		
Name	Line ID	Voltage (kV)
Coopers Corners-Dolson Ave*	CCDA42	345
Middletown-Rock Tavern*	CCRT34	345
Middletown 345/138	BK 114	345/138
West Woodbourne 115/69	T152	115/69
Capital (Zone F) – Hudson Valley (Zone G)		
*Athens-Pleasant Valley	91	345
*Leeds-Pleasant Valley	92	345
*Leeds-Hurley Ave.	301	345
Blue Stores E-Milan*	T7	115
*Churchtown-North Catskill	5	115
*Feura Bush/Flint Mine-North Catskill	2	115

Zone J Locality		
Dunwoodie (Zone I) – NYC (Zone J)		
Name	Line ID	Voltage (kV)
*Dunwoodie-Mott Haven	71	345
*Dunwoodie-Mott Haven	72	345
Sprain Brook-Tremont*	X28	345
*Sprain Brook-West 49 th Street	M51	345
*Sprain Brook-West 49 th Street	M52	345
*Sprain Brook-Academy	M29	345
*Dunwoodie-Sherman Creek	99031	138
*Dunwoodie-Sherman Creek	99032	138
*Dunwoodie-East 179 th Street	99153	138
Long Island (Zone K) – NYC (Zone J)		
*Lake Success-Jamaica	903	138
*Valley Stream-Jamaica	901L_M	138

Zone K Locality		
Dunwoodie (Zone I) – Long Island (Zone K)		
Name	Line ID	Voltage (kV)
*Dunwoodie-Shore Road	Y50	345
*Sprain Brook-East Garden City	Y49	345
NYC (Zone J) – Long Island (Zone K)		
Jamaica-Valley Stream*	901L_M	138
Jamaica-Lake Success*	903	138

* indicates the metered end of the circuit