



# **NYISO Operating Study Winter 2024-2025**

**A Report by the  
New York Independent System Operator**

October 2024

---

## Table of Contents

|   |           |
|---|-----------|
| <b>EXECUTIVE SUMMARY .....</b>  | <b>4</b>  |
| <b>INTRODUCTION.....</b>  | <b>5</b>  |
| <b>PURPOSE .....</b>  | <b>5</b>  |
| <b>SYSTEM OPERATING LIMIT (SOL) METHODOLOGY .....</b>                                     | <b>5</b>  |
| <b>STUDY PARTICIPANTS .....</b>   | <b>6</b>  |
| <b>SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS.....</b>                              | <b>7</b>  |
| System Representation .....   | 7         |
| <i>Generation Resource Changes .....</i>  | <i>8</i>  |
| <i>Transmission Facilities Changes.....</i>   | <i>9</i>  |
| System Representation .....   | 9         |
| <b>DISCUSSION .....</b>   | <b>11</b> |
| Resource Assessment .....   | 11        |
| Load and Capacity Assessment.....   | 11        |
| Cross-State Interfaces .....  | 11        |
| Transfer Limit Analysis .....   | 11        |
| West Woodbourne Transformer.....  | 13        |
| ConEd – LIPA Transfer Analysis .....  | 13        |
| Transfer Limits for Outage Conditions.....  | 14        |
| Transient Stability and Voltage transfer Limits .....                                     | 14        |
| Thermal Transfer Capabilities with Adjacent Balancing Areas.....                          | 15        |
| <i>New York – New England Analysis .....</i>  | <i>16</i> |
| <i>New York - PJM Analysis.....</i>   | <i>17</i> |
| <i>Ontario – New York Analysis .....</i>  | <i>18</i> |
| <i>TransÉnergie–New York Interface .....</i>  | <i>19</i> |
| <b>SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS .....</b>                         | <b>21</b> |
| TABLE 1.a – NYISO CROSS-STATE INTERFACE THERMAL drftTRANSFER LIMITS - WINTER 2024-25..... | 22        |
| TABLE 1.b – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25.....     | 23        |
| TABLE 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25.....       | 24        |
| TABLE 2.b – ISO-NE to NYISO INTERFACE THERMAL LIMITS - WINTER 2024-25.....                | 25        |
| TABLE 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25 .....         | 26        |

TABLE 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS – Winter 2024-25..... 27

TABLE 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25..... 28

TABLE 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS – WINTER 2024-25 ..... 29

## Executive Summary

This study is conducted as a seasonal review of the projected thermal transfer capability for the Winter 2024-25 period. The study evaluates the projected internal and external thermal transfer capabilities for the forecasted load and dispatch conditions studied. The evaluated limits are shown in Tables 1 through 5. Differences in the evaluated internal interface limits from Winter 2023-24 to Winter 2024-25 are shown in Figure 1 on page 11. Internal limits have changed due to network alterations in the New York Control Area (NYCA) and modeling assumptions.

- **Dysinger East** interface thermal transfer limit decreased by 125 MW due to redistribution of flows from change in load pattern in West and Genesee areas.
- **West Central Reverse** interface thermal transfer limit increased by 50 MW mainly due to redistribution of flows from change in load pattern in West and Genesee areas.
- **UPNY-ConEd** interface thermal transfer limit increased by 1,025 MW due to Pleasant Valley– Wood St. (F31) 345 kV line & Wood St. – Millwood (W81) 345 kV line coming back in-service.
- **UPNY-SENY** interface thermal transfer limit increased by 550 MW mainly due to Pleasant Valley– Wood St. (F31) 345 kV line & Wood St. – Millwood (W81) 345 kV line coming back in-service.
- **Sprain Brook Dunwoodie S.** interface thermal transfer limit increased by 125 MW due to Pleasant Valley – Wood St. (F31) 345 kV line & Wood St. – Millwood (W81) 345 kV line coming back in-service.
- **Total East** interface thermal transfer limit decreased by 75 MW mainly due to changes in external area dispatch.
- **Moses South** interface thermal transfer limit increased by 50 MW mainly due to modeling of St. Lawrence – Moses (L34P) 230 kV PAR in-service.

Differences in the evaluated external interface limits from Winter 2023-2024 to Winter 2024-2025 are shown in Figure 2 on page 14.

## INTRODUCTION

The following report, prepared by the Operating Studies Task Force (OSTF) at the direction and with the guidance of the System Operations Advisory Subcommittee (SOAS), highlights the thermal transfer analysis evaluation for the Winter 2024-2025 capability period. This analysis indicates that, for the Winter 2024-2025 capability period, the New York interconnected bulk power system can be operated reliably in accordance with the New York State Reliability Council Reliability Rules and the NYISO System Operating Procedures.

Thermal transfer limits cited in this report are based on the forecasted load and dispatch assumptions and are intended as a guide to system operation. Changes in generation dispatch or load patterns that significantly change pre-contingency line loadings may change limiting contingencies or limiting facilities, resulting in higher or lower interface transfer capabilities.

System Operators should monitor the critical facilities noted in the included tables along with other limiting conditions while maintaining bulk power system transfers within secure operating limits.

## PURPOSE

The purpose of the study is to determine:

- The total transfer capabilities (TTC) between NYISO and adjacent areas including IESO, PJM and ISO-NE for normal conditions in the summer/winter periods. The TTC is calculated based on NERC TPL-001-4 Category P1 and P2 contingencies and a set of selected Category P4, P5 and P7 contingencies.
- The TTC between NYISO and adjacent areas including IESO, PJM and ISO-NE for emergency conditions in the summer/winter periods. The TTC is calculated based on NERC TPL-001-4 Category P1 and P2 contingencies.

## System Operating Limit (SOL) Methodology

As identified in “FAC-011-4\_Methodology for Establishing SOL for the Operations Horizon\_20240401”, the NYSRC Reliability Rules provide the documented methodology for use in developing System Operating Limits (SOLs) within the NYISO Reliability Coordinator Area. NYSRC Reliability Rules require compliance with all North American Electric Reliability Corporation

(NERC) Standards and Northeast Power Coordinating Council (NPCC) Standards and Criteria. NYSRC Rule C.1, Tables C-1 and C-2 address the contingencies to be evaluated and the performance requirements to be applied. Rule C.1 also incorporates by reference Attachment H, NYISO Transmission Planning Guideline #3-1, “Guideline for Stability Analysis and Determination of Stability-Based Transfer Limits” of the NYISO Transmission Expansion and Interconnection Manual.

## STUDY PARTICIPANTS

| First Name | Last Name    | Company Name      | First Name | Last Name      | Company |
|------------|--------------|-------------------|------------|----------------|---------|
| Hao        | Fu           | PSEG Long Island* | Raj        | Dontireddy     | NYISO   |
| John       | Koziatek     | PSEG Long Island* | Declan     | Cahill         | NYISO   |
| Daniel     | Head         | ConEd             | David      | Zhang          | NYISO   |
| Mohammed   | Rahman       | ConEd             | Francisco  | Sandoval       | NYISO   |
| Brent      | Blanchard    | NYPA              | Elvin      | D'Souza        | IESO    |
| Frank      | Grimaldi     | NYPA              | Sasa       | Mizdrak        | IESO    |
| John       | Hastings     | National Grid     | Robert     | Dropkin        | PJM     |
| Jeffery    | Maher        | National Grid     | Nicole     | Scott          | PJM     |
| Phil       | Nichols      | National Grid     | Mark       | Dettrey        | PJM     |
| Eric       | Remolona     | O&R               | Gabriel    | Dion Marcotte  | HQ      |
| Caroline   | Kucher       | Central Hudson    | Jonathan   | Landry-Leclerc | HQ      |
| Leen       | Almadani     | Central Hudson    |            |                |         |
| Robert     | Gollogly     | NYSEG             |            |                |         |
| Brian      | Gordon       | NYSEG             |            |                |         |
| Jin        | Hao          | NYSEG             |            |                |         |
| John       | McDonald     | NextEra Energy    |            |                |         |
| Jeffrey    | Mullen       | NextEra Energy    |            |                |         |
| Jason      | Kampschaefer | LS Power          |            |                |         |
| Matthew    | Senus        | LS Power          |            |                |         |
| Phil       | Tatro        | Transco           |            |                |         |
| Jim        | McCloskey    | Transco           |            |                |         |
| Alex       | Parsell      | ISO-NE            |            |                |         |
| Joseph     | Koltz        | ISO-NE            |            |                |         |

\*Agent for LIPA

## SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS

### System Representation

The representation was developed from the NYISO Data Bank and assumes the forecast winter coincident peak load of 23,800 MW. The other NPCC Balancing Areas and adjacent Regional representations were obtained from the RFC-NPCC Winter 2024-2025 Reliability Assessment power flow base case and have been updated to reflect the Winter 2024-2025 capability period.

The base case model includes:

- The NYISO Transmission Operator area
- All Transmission Operator areas contiguous with NYISO
- All system elements modeled as in-service
- All generation represented
- Phase shifters in the regulating mode in accordance with the NYISO Available Transfer Capability Implementation Document (ATCID)
- The NYISO Load Forecast
- Transmission Facility additions and retirements
- Generation Facility additions and retirements
- Remedial Action Scheme (RAS) models where currently existing or projected for implementation within the studied time horizon
- Series compensation for each line at the expected operating level unless specified otherwise in the ATCID.
- Facility Ratings as provided by the Transmission Owner and Generator Owner

### Generation Resource Changes

The status and dispatch level of generation represented in this analysis is a reasonable expectation based on the information available at the time of the study. Those modeling assumptions incorporate known unit outage status. The inter-Area schedules represented in the study base case are summarized in Appendix A. The following table shows generation deactivations and additions since the Winter 2023-24 capability period:

| <b>Deactivations</b>     |               |
|--------------------------|---------------|
| Freeport 1-4             | -6 MW         |
| Northport GT             | -16 MW        |
| Port Jefferson GT 01     | -16 MW        |
| Coxsackie GT             | -21.6 MW      |
| <b>Total Retirements</b> | <b>-60 MW</b> |
| <b>Additions</b>         |               |
| Pattersonville Solar     | 20 MW         |
| Rock District Solar      | 20 MW         |
| Mohawk Solar             | 91 MW         |
| Morris Ridge Solar EC    | 177 MW        |
| SunEast Scipio Solar     | 18 MW         |
| North Side Solar         | 180 MW        |
| Watkins Glen Solar       | 50 MW         |
| Trelinia Solar EC        | 80 MW         |
| KCE NY 6                 | 20 MW         |
| Ball Hill Wind           | 107 MW        |
| BlueStone Wind           | 112 MW        |
| Stillwater Solar         | 20 MW         |
| Albany County Solar 1    | 20 MW         |
| <b>Total Additions</b>   | <b>935 MW</b> |



### Transmission Facilities Changes

Significant facility changes since the Winter 2023-24 capability period include:

- Lovett 345 kV Addition
- Pleasant Valley – Wood Street (F31) 345 kV returned in-service
- Wood Street – Millwood (W81) 345 kV returned in-service
- West 49th Street (TR4) 345/138 kV Transformer returned in-service
- East 13th Street (TR4) 138/69 kV transformer returned in-service
- East 13th Street (BK17) 345/69 kV transformer returned in-service
- St. Lawrence – Moses (L34P) 230 kV PAR modeled in-service
- Moses – Reynold (MR3) 115 kV modeled out-of-service
- Marcy STATCOM (CSC) modeled out-of-service
- Edic (BK3) 345/115 kV transformer modeled out-of-service
- Gowanus – Greenwood (42G24 & 42G51) 138 kV modeled out-of-service
- West 49<sup>th</sup> Street (TR2) 345/115 kV transformer modeled out-of-service
- West 49<sup>th</sup> Street (38M44 & 38M75) 345/138 kV transformer modeled out-of-service
- E13th St (BK 14) 345/138 kV transformer modeled out-of-service
- E13th – East River (37041) 138 kV modeled out-of-service
- East River (BK 111) 138/69 kV modeled out-of-service
- Hellgate – Astoria West (24054) 138 kV modeled out-of-service

Lovett station 345 kV addition includes a new 345 kV station that taps on the previous Ladentown – Buchanan (Y88) 345 kV line. The line is now split into Ladentown – Lovett (Y66) 345kV & Lovett – Buchanan (Y88) 345kV. There is a new 345/138 kV transformer connecting Lovett 345 kV station to the existing 138 kV station.

### System Representation

The Siemens PTI PSS™E and PowerGEM's Transmission Adequacy and Reliability Assessment "TARA" software packages were used to calculate the thermal limits based on Normal and Emergency Transfer Criteria as defined in the NYSRC Reliability Rules. The thermal transfer limits presented have been determined for all transmission facilities scheduled in-service during the Winter 2024-2025 period.

The schedules used in the base case power flow for this analysis assumed a net flow of 0 MW from Public Service Electric & Gas (PSE&G) to Consolidated Edison via the PAR transformers controlling the Hudson – Farragut and Linden – Goethals interconnections, and 0 MW on the South Mahwah – Waldwick circuits from Consolidated Edison to PSE&G, controlled by the PARs at Waldwick. The Hopatcong – Ramapo (5018) 500 kV circuit is scheduled to 202 MW from PJM to New York. The four Ontario – Michigan PARs are modeled in-service and scheduled to a 0 MW transfer. These schedules are consistent with the scenarios developed in the RFC-NPCC Inter-Regional Reliability Assessment for Winter 2024-2025, and the MMWG Winter 2024-2025 power flow base cases. The Dysinger – East Stolle Rd. PAR is scheduled to 400 MW from Dysinger to East Stolle Rd. The series reactors on the Sprain Brook – East Garden City (Y49) 345 kV cable, Farragut – Gowanus (41 and 42) 345 kV cables, Packard – Sawyer (77 and 78) 230 kV feeders, as well as the E. 179th St. – Hell Gate (15055) 138 kV feeder are in-service in the base case. The series reactors on the Dunwoodie – Mott Haven (71 and 72) and the Sprain Brook – W. 49th St. (M51 and M52) 345 kV are by-passed. The series capacitors on the Marcy – Coopers Corners (UCC2-41) 345 kV, the Edic – Fraser (EF24-40) 345 kV, and the Fraser – Coopers Corners (33) 345 kV and the Knickerbocker to Pleasant Valley (Y57) 345 kV lines are by-passed in the base case.

Smart Wire SmartValve, a modular static synchronous series compensator is installed at the Hurley 345 kV substation on the Leeds – Hurley (301) 345 kV line. This device injects voltage in quadrature with the line current to synthesize a capacitive or inductive reactance. The device is expected to be operated in capacitive reactance mode and will be changed as deemed necessary by the NYISO.

The NYISO Niagara generation was modeled using a 50-50 split on the 230 kV and 115 kV generators. The total output for the Niagara facility was modeled at 2,100 MW. The Ontario Beck generation was modeled at an output of 1,300 MW.

## DISCUSSION

### Resource Assessment

#### Load and Capacity Assessment

The forecast peak demand for the Winter 2024-2025 capability period is 23,800 MW<sup>1</sup>. This forecast is approximately 420 MW (1.73%) lower than the forecast of 24,220 MW for the Winter 2023-24 capability period, and 1,938 MW (7.53%) lower than the all-time New York Control Area (NYCA) seasonal peak of 25,738 MW, which occurred on January 7, 2014.

The Installed Capacity (ICAP) requirement for the Winter capability period is 38,480 MW based on the NYSRC 22.0% Installed Reserve Margin (IRM) requirement for the 2024 Capability Year. NYCA generation capacity for Winter 2024-2025 is 40,562 MW, and net external capacity purchases of 759 MW have been secured for the Winter period. The combined capacity resources represent a 73.6% margin above the forecast peak demand of 23,800 MW. These values were taken from the 2024 Load & Capacity Data report produced by the NYISO and updated with known changes at the time of this writing.

The equivalent forced outage rate is 3.21%, and includes forced outages and de-ratings based on historical performance of all generation in the NYCA. For Winter 2023-24, the equivalent forced outage rate assumed was 3.79%.

### Cross-State Interfaces

#### Transfer Limit Analysis


This report summarizes the results of thermal transfer limit analyses performed on power system representation modeling the forecast peak load conditions for Winter 2024-2025. Normal and emergency thermal limits were calculated according to Normal and Emergency Transfer Criteria definitions in the NYSRC Reliability Rules. For this assessment period the most severe single generation contingency is Nine Mile Point 2 at 1,310 MW. Facility ratings applied in the analysis were from the online MW ratings in the EMS, and are detailed in Appendix D.

Figure 1 presents a comparison of the Winter 2024-2025 thermal transfer limits to Winter 2023-24 thermal transfer limits. Changes in these limits from previous years are due to changes in the base case load flow generation and load patterns that result in different pre-contingency line

---

<sup>1</sup> Forecast Coincident Peak Demand (50th percentile baseline forecast)

loadings, changes in limiting contingencies, changes in circuit ratings, or line status. Appendix H presents a summary comparison of Cross-State thermal transfer limits between Winter 2024-2025 and 2023-2024, with limiting element/contingency descriptions. Significant differences in these thermal transfer limits are discussed below.



**Figure 1 – Cross-State Thermal Transfer Limits**

**Dysinger East** interface thermal transfer limit decreased by 125 MW mainly due to redistribution of flows from change in load pattern in West and Genesee areas.

**West Central Reverse** interface thermal transfer limit increased by 50 MW mainly due to redistribution of flows from change in load pattern in West and Genesee areas.

**UPNY-ConEd** interface thermal transfer limit increased by 1,025 MW mainly due to Pleasant Valley– Wood St. (F31) 345 kV & Wood St. – Millwood (W81) 345 kV coming back in-service.

**UPNY-SENY** interface thermal transfer limit increased by 550 MW mainly due to Pleasant Valley– Wood St. (F31) 345 kV & Wood St. – Millwood (W81) 345 kV coming back in-service.

**Sprain Brook Dunwoodie S.** interface thermal transfer limit increased by 125 MW due to Pleasant Valley – Wood St. (F31) 345 kV & Wood St. – Millwood (W81) 345 kV coming back in-

service.

**Total East** interface thermal transfer limit decreased by 75 MW mainly due to changes in external area dispatch.

**Moses South** Moses South interface thermal transfer limit increased by 50 MW mainly due to modeling of St. Lawrence – Moses (L34P) 230 kV PAR in-service.

#### **West Woodbourne Transformer**

The Total-East interface may be limited at significantly lower transfer levels for certain contingencies that result in overloading of the West Woodbourne 115/69 kV transformer. Should the West Woodbourne tie be the limiting facility, it may be removed from service to allow higher Total-East transfers. Over-current relays are installed at West Woodbourne and Honk Falls to protect for contingency overloads.

#### **ConEd – LIPA Transfer Analysis**

Normal transfer capabilities were determined using the base case generation dispatch and PAR settings as described in Appendix B. Emergency limits are dispatch dependent, and can vary based on generation and load patterns in the LIPA system.

For emergency transfer capability analysis, the PARs controlling the LIPA import were adjusted to allow for maximum transfer capability into LIPA:

#### ConEd – LIPA PAR Settings

|                                      | Normal  | Emergency |
|--------------------------------------|---------|-----------|
| Jamaica – Lake Success 138 kV        | -200 MW | 190 MW    |
| Jamaica – Valley Stream 138 kV       | -100 MW | 108 MW    |
| Sprain Brook – E. Garden City 345 kV | 637 MW  | 637 MW    |

#### ISO-NE – LIPA PAR Settings

|                                   |        |        |
|-----------------------------------|--------|--------|
| Norwalk Harbor – Northport 138 kV | 100 MW | 286 MW |
|-----------------------------------|--------|--------|

The PAR schedules referenced above and the ConEd - LIPA transfer assessment assume the following loss factors and oil circulation modes in determination of the facility ratings for the 345 kV cables:

- Y49 has a 70% loss factor in slow oil circulation mode.
- Y50 has a 70% loss factor in rapid circulation mode.

#### **Emergency Transfer via the 138 kV PAR-controlled Jamaica ties between Con Edison and LIPA**

Con Edison and LIPA have determined possible emergency transfer levels via the Jamaica - Valley Stream (901) 138 kV and Jamaica - Lake Success (903) 138 kV PAR-controlled ties that could be used to transfer emergency power between the two entities during peak conditions. The emergency transfer levels were calculated in both directions, for system peak load conditions with all transmission lines in-service and all generation available at full capacity.

#### **ConEd to LIPA emergency assistance**

Based on load flow analysis performed by Con Edison, Con Edison anticipates being able to supply a total flow up to 320 MW of emergency transfer from Con Edison to Long Island, if requested, via the ties for the coming Winter season.

#### **LIPA to ConEd emergency assistance**

LIPA anticipates being able to supply a total flow up to 497 MW of emergency transfer from Long Island to Con Edison, if requested, via the ties under ideal conditions (i.e. all lines and generation in-service, imports via Neptune, Norwalk Harbor to Northport Cable - NNC and Cross Sound Cable - CSC).


#### **Transfer Limits for Outage Conditions**

Transfer limits for scheduled outage conditions are determined by the NYISO Scheduling and Market Operations groups. The NYISO Real-Time Dispatch system monitors the EHV transmission continuously to maintain the secure operation of the interconnected EHV system.

#### **Transient Stability and Voltage transfer Limits**

The interface transfer limits shown in “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section are the results of a thermal transfer limit analysis only. Transient stability and voltage interface transfer limits for all lines in-service and line outage conditions are summarized and available through the NYISO website located under “Interface Limits & Op Studies” at the following link: <https://www.nyiso.com/reports-information>

## Thermal Transfer Capabilities with Adjacent Balancing Areas



**Figure 2 – Inter-Area Thermal Transfer Capabilities<sup>2</sup>**

Thermal transfer limits between New York and adjacent Balancing Areas also are determined in this analysis. These transfer limits supplement, but do not change, existing internal operating limits. There may be facilities internal to each system that may reduce the transfer limits between Balancing Areas. Reductions due to these situations are considered to be the responsibility of the respective reliability authority. Some of these potential limitations are indicated in the summary tables by “Reliability Coordinating Facility” limits, which supplement the “Direct Tie” limits between the Balancing Areas. Transfer conditions within and between neighboring Balancing Areas can have a significant effect on inter- and intra-Area transfer limits. Coordination between Balancing Areas is necessary to provide optimal transfer while maintaining the reliability and security of the interconnected systems.

<sup>2</sup> TE-NY transfer capabilities shown in Figure 2 are not thermal transfer limits; for more information see page 18

## **New York – New England Analysis**

### **New England Transmission/Capacity Additions**

#### **Transmission**

For the Winter 2024-2025 (October through May) study period, there are no major transmission projects coming into service that will significantly impact the New York – New England transmission capability.

#### **Capacity**

In the New England Control Area, for the Winter 2024-2025 study period, five major generation projects are expected to become commercial. This includes Vineyard Wind (800 MW Offshore Wind), Downeast Wind (126 MW Onshore Wind), Western Maine Renewables (58.8 MW Onshore Wind), Carver Energy Storage (150 MW Battery Energy Storage System), and Gravel Pit Solar (125 MW Solar Photovoltaic).

Approximately 219 MW of Solar Photovoltaic, 800 MW of Offshore Wind, 185 MW of Onshore Wind, and 239 MW of Battery Energy Storage Systems are anticipated to become commercial during this period.

There are no planned retirements anticipated during this period.

#### **Thermal Transfer Limit Analysis**

The transfer limits between the NYISO and ISO New England for normal and emergency transfer criteria are summarized in Tables 2.a and 2.b.

#### **Cross-Sound Cable**

The Cross-Sound Cable (CSC) is an HVDC merchant transmission facility connecting the New Haven Harbor 345 kV (United Illuminating, ISO-NE) station and Shoreham 138 kV (LIPA, NYISO) station. It has a design capacity of 330 MW. This facility is not metered as part of the NYISO – ISO-NE interface, and HVDC transfers are independent of transfers between the NYISO and ISO-NE.

#### **Smithfield – Salisbury 69 kV**

CHG&E and Eversource will normally operate the Smithfield - Salisbury 69 kV (FV/690) line closed. The maximum allowable flow on this line is 31 MVA based on limitations in the Eversource 69 kV system. When the ISO-NE to NYISO transfer is greater than approximately 400 MW, the line will be opened due to post contingency limits within the Eversource system. The FV/690 line has directional over-current protection that will trip the FV/690 line in the event of an overload when the flow is into ISO-NE. No protection exists to trip the FV/690 line in the event of an overload when the flow is into NYISO.

#### **Northport – Norwalk Harbor Cable Flow**

Flow on the NNC Norwalk Harbor to Northport facility is controlled by PAR transformer at Northport. As system conditions vary, the scheduled flow on the NNC may be used to optimize transfer capability between



the Balancing Areas. The thermal transfer limits are presented in Table 2 for different PAR schedule assumptions on the Northport – Norwalk Harbor interconnection.

#### **Whitehall – Blissville 115 kV**

The PAR transformer on the K7 line at the VELCO Blissville substation will control pre-contingency flow between the respective stations. For the analyses, the pre-contingency schedule is 25 MW from Blissville (ISO-NE) to Whitehall (NYISO). The scheduled flow may be adjusted to protect the National Grid local 115 kV transmission south of Whitehall for 345 kV contingency events in southern Vermont pursuant to joint operating procedure developed by VELCO, National Grid, ISO-NE and NYISO.

#### **Plattsburgh – Sand Bar 115 kV (i.e. PV20)**

The PAR transformer on the PV20 line at the VELCO Sand Bar substation was modeled holding a pre-contingency flow of approximately 100 MW on the PV20 tie. This modeling assumption was premised upon common operating understandings between ISO-NE and the NYISO given local operating practice on the Moses – Willis – Plattsburgh 230 kV transmission corridor. ISO-NE's analysis examined and considered New England system limitations given this modeling assumption and did not examine generation dispatch or system performance on the New York side of the PV20 tie.

### **New York - PJM Analysis**

#### **Thermal Transfer Limit Analysis**

The transfer limits for the NYISO – PJM and PJM – NYISO interfaces are summarized in Tables 3a and 3b respectively of the “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section of this report. The Marion-Farragut 345 kV B and C cables are expected to remain open and the Waldwick E, F, O and Goethals A paths are expected to deliver a percentage of the scheduled interchange as referenced in the NYISO-PJM JOA. The Hopatcong – Ramapo 500 kV (5018) circuit is scheduled in accordance with the “TCC Market PJM -NYISO Interconnection Scheduling Protocol”, February 28th, 2020.

#### **Opening of PJM - New York 115 kV Ties as Required**

The normal criteria thermal transfer limits presented in “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section were determined for an all lines in-service condition. The 115 kV interconnections between First Energy East and New York (Warren – Falconer, North Waverly – East Sayre, and Laurel Lake – Westover) may be opened in accordance with NYISO and PJM

Operating Procedures provided that this action does not cause unacceptable impact on local reliability in either system. Over-current protection is installed on the Warren - Falconer and the North Waverly – East Sayre 115 kV circuits; either of these circuits would trip by relay action for an actual overload condition. This North Waverly-East Sayre scheme is expected to be designated as a RAS in the future and hence the line could be expected to be operated as in-service more often. There is no overload protection on the Laurel Lake - Westover circuit, but it may be opened by operator action if there is an actual or post-contingency overload condition. However, opening the Laurel Lake – Westover tie could potentially cause local thermal and pre- and post-contingency voltage violations for the 34.5 kV distribution system within First Energy East transmission zone. Sensitivity analysis performed indicated that the thermal and voltage conditions were exacerbated for conditions that modeled high simultaneous interface flows from NY to PJM and NY to Ontario.

#### **DC Ties**

Neptune DC tie is expected to be available. Hudson Transmission Project (HTP) DC tie is expected to be available.

#### **Variable Frequency Transformer (VFT) Tie**

The Variable Frequency Transformer Tie is a transmission facility connecting the Linden 230 kV (PSEG, PJM) to Linden 345 kV (ConEd, NYISO). For the Winter 2024-2025, Linden VFT will have 330 MW non-firm withdrawal right and 300 MW firm injection rights into PJM market.

### **Ontario – New York Analysis**

#### **Thermal Transfer Limit Analysis**

The thermal transfer limits between the NYISO and Ontario's Independent Electricity System Operator (IESO) Balancing Areas for normal and emergency transfer criteria are presented in tables 4 and 5. The NYISO Niagara generation was modeled at an output of 2,100 MW.

The Ontario – New York ties at St. Lawrence, L33P and L34P PARs were controlling to 0 MW in all four scenarios. The interconnection flow limit across these ties is 300 MW, as presented in Table B3 “Interconnection Flow Limits” from the document “Reliability Outlook Tables” available at:

[https://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables\\_2024Jun.xlsx](https://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables_2024Jun.xlsx)

### **Transient Stability Limitations**

Transient stability limits for the NYISO - IESO interconnection are reported in "NYPP-OH TRANSIENT STABILITY TESTING REPORT on DIRECT TIE TRANSFER CAPABILITY - OCTOBER 1993" available at:

[https://www.nyiso.com/documents/20142/3694079/NYPP-OH\\_1993-2.pdf/2e21484a-22cf-739a-7a10-69dfd69f5d58](https://www.nyiso.com/documents/20142/3694079/NYPP-OH_1993-2.pdf/2e21484a-22cf-739a-7a10-69dfd69f5d58)

### **Ontario – Michigan PARs**

All of the PARs on the four transmission lines interconnecting Ontario and Michigan are in-service and regulating. For this study, the PARs were scheduled to regulate at 0 MW.

### **Impact of the Queenston Flow West (QFW) Interface on the New York to Ontario Transfer Limit**

The QFW interface is defined as the sum of the power flows through the 230 kV circuits out of Beck. QFW is the algebraic sum of the following:

- Total generation in the Niagara zone of Ontario including the units at the Beck #1, #2 & Pump Generating Stations, Thorold CGS and Decew Falls GS
- The total load in the Niagara zone
- The import from New York through the Niagara Interties.

For a given QFW limit, the import capability from New York depends on the generation dispatch and the load in the Niagara zone. The Ontario Niagara generation is set to 1,300 MW. The import capability from New York can be increased by decreasing generation in the Ontario Niagara zone contingent on water and tourism regulations, and increasing demand in the Ontario Niagara zone, or both.

### **TransÉnergie–New York Interface**

Thermal transfer limits between TransÉnergie (Hydro-Quebec) and New York are not analyzed as part of this study. Respecting the NYSRC and NYISO operating reserve requirements, the maximum allowable delivery into the NYCA from TransÉnergie on the Chateauguay – Massena (MSC-7040) 765 kV tie is 1310 MW. However in real-time the total flow is limited to 1800 MW; the additional flow is a “wheel-through” transaction to another Balancing Authority Area. Maximum delivery from NYCA to Quebec on the 7040 line is 1000 MW.

The Dennison Scheduled Line represents a 115 kV dual-circuit transmission line that interconnects the New York Control Area to the Hydro-Quebec Control Area at the Dennison Substation, near Massena, NY. The Dennison Line has a nominal north to south capacity of 279 MW in winter, into New York, and a nominal south to north capacity of 200 MW into Quebec. The south to north capacity will be limited to 100 MW into Quebec until such time as the HQ-Cedars Export Study report is approved by the Operating Committee and conditions outline in the report are satisfied.

## SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS

Table 1 – NYISO CROSS STATE INTERFACE THERMAL TRANSFER LIMITS

- Table 1.a
  - Dysinger East
  - West Central Reverse
  - UPNY – SENY
  - UPNY – ConEd
  - Sprain Brook – Dunwoodie So.
  - ConEd – LIPA Transfer Capability
- Table 1.b – MSC-7040 Flow Sensitivity
  - Central East
  - Total East
  - Moses South

Table 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS

- Northport-Norwalk Flow Sensitivity
- Cricket Valley Energy Center I/S and O/S

Table 2.b – ISO-NE to NYISO INTERFACE THERMAL TRANSFER LIMITS

- Northport-Norwalk Flow Sensitivity
- Cricket Valley Energy Center I/S and O/S

Table 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS

- 3-115 kV Ties I/S and O/S
- Hudson – Farragut (B3402) 345 kV and Marion – Farragut (C3403) 345 kV lines and associated PARs I/S and O/S

Table 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS

- 3-115 kV Ties I/S and O/S
- Hudson – Farragut (B3402) 345 kV and Marion – Farragut (C3403) 345 kV lines and associated PARs I/S and O/S

Table 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS

Table 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS

**TABLE 1.a – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25**
**ALL LINES IN-SERVICE**

|                  | Dysinger East | West Central Reverse | UPNY - ConEd | UPNY - SENY | Sprain Brook Dunwoodie - So. | ConEd – LIPA |
|------------------|---------------|----------------------|--------------|-------------|------------------------------|--------------|
| <b>NORMAL</b>    | 2100 MW (1)   | 1850 MW (3)          | 7275 MW (5)  | 4750 MW (5) | 3975 MW (7)                  | 1000 MW (9)  |
| <b>EMERGENCY</b> | 2175 MW (2)   | 2525 MW (4)          | 8575 MW (6)  | 5950 MW (6) | 4125 MW (8)                  | 1425 MW (10) |

| LIMITING ELEMENT |  | RATING            |                     | LIMITING CONTINGENCY |  |
|------------------|--|-------------------|---------------------|----------------------|--|
| (1)              | Niagara – Dysinger (ND1) 345 kV                | @LTE <sub>3</sub> | 1745 MW             | L/O                  | Niagara – Dysinger (ND2) 345 kV  |
| (2)              | Niagara – Dysinger (ND1) 345 kV                | @STE              | 1793 MW             | L/O                  | Niagara – Dysinger (ND2) 345 kV  |
| (3)              | Clay – Pannell (1) 345 kV                      | @LTE              | 1315 MW             | L/O                  | Clay – Pannell (2) 345 kV<br>Clay – Edic (2-15) 345 kV                           |
| (4)              | Clay – Pannell (2) 345 kV                      | @STE              | 1673 MW             | L/O                  | Pannell – Clay (1) 345 kV  |
| (5)              | Lovett – Buchanan (Y88) 345 kV                 | @LTE              | 2015 MW             | L/O                  | Buchanan – Ramapo (Y94) 345 kV   |
| (6)              | Coopers Corner –Middletown Tap (CCRT34) 345 kV | @STE              | 1792 MW             | L/O                  | Dolson Ave – Rock Tavern (DART44) 345 kV   |
| (7)              | Dunwoodie – Mott Haven (71) 345 kV             | @MTE <sub>1</sub> | 1083 MW             | L/O                  | Dunwoodie – Mott Haven (72) 345 kV   |
| (8)              | Dunwoodie – Mott Haven (71) 345 kV             | @NORM             | 741 MW              |                      | Pre-Contingency Loading  |
| (9)              | Dunwoodie – Shore Rd. (Y50) 345 kV             | @LTE              | 977 MW <sub>2</sub> | L/O                  | Sprainbrook – East Garden City (Y49) 345kV<br>Sprainbrook – Academy (M29) 345 kV |
| (10)             | Newbridge – Locust Grove (558) 138 kV          | @NORM             | 354 MW              |                      | Pre-Contingency Loading  |

**Note**

- 1: The rating used for cable circuits during SCUC reliability analysis is the average of the LTE and STE rating (MTE Rating).
- 2: LIPA rating for Y50 circuit is based on 70 % loss factor and rapid oil circulation.
- 3: The Dysinger – E. Stolle PAR controller schedule has direct impact on the Dysinger East limit.

**TABLE 1.b – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25**
**ALL LINES IN-SERVICE**

|                     | 7040 FLOW<br>HQ->NY 600 MW | 7040 FLOW<br>0 MW | 7040 FLOW<br>NY->HQ 600 MW |
|---------------------|----------------------------|-------------------|----------------------------|
| <b>Central East</b> |                            |                   |                            |
| <b>NORMAL</b>       | 4200 MW (1)                | 4200 MW (1)       | 4175 MW (1)                |
| <b>EMERGENCY</b>    | 4700 MW (2)                | 4700 MW (2)       | 4700 MW (2)                |
| <b>Total East</b>   |                            |                   |                            |
| <b>NORMAL</b>       | 5350 MW (3)                | 5325 MW (3)       | 5325 MW (3)                |
| <b>EMERGENCY</b>    | 6100 MW (4)                | 6075 MW (4)       | 6000 MW (4)                |
| <b>Moses South</b>  |                            |                   |                            |
| <b>NORMAL</b>       | 1450 MW (5)                | 1025 MW (6)       | 525 MW (6)                 |
| <b>EMERGENCY</b>    | 2375 MW (7)                | 1325 MW (8)       | 825 MW (8)                 |

| ID  | LIMITING ELEMENT                                 | RATING |         | LIMITING CONTINGENCY   |
|-----|--|--------|---------|--|
| (1) | New Scotland – Leeds (93) 345 kV                 | @LTE   | 1692 MW | L/O New Scotland – Leeds (94) 345 kV   |
| (2) | New Scotland – Leeds (93) 345 kV                 | @STE   | 1912 MW | L/O New Scotland – Leeds (94) 345 kV   |
| (3) | Roseton – East Fishkill (RFK305)                 | @LTE   | 2772 MW | L/O Lovett – Buchanan (Y88) 345 kV<br>Ramapo – Buchanan (Y94) 345 kV                                 |
| (4) | Coopers Corners – Middletown TAP (CCRT34) 345 kV | @STE   | 1792 MW | L/O Dolson Ave – Rock Tavern (DART44) 345 kV   |
| (5) | Chases Lake – Porter (11) 230 kV                 | @LTE   | 564 MW  | L/O Chateaugay – Massena (7040) 765 kV<br>Massena – Marcy (MSU1) 765 kV<br>and TransÉnergie delivery |
| (6) | Chases Lake – Porter (11) 230 kV                 | @LTE   | 564 MW  | L/O Moses – Massena (MMS1 & MMS2) 345 kV   |
| (7) | Willis – Malone (1-910) 115 kV                   | @STE   | 173 MW  | L/O Alcoa PA – Alcoa (R8105) 115 kV  |
| (8) | Willis – Malone (1-910) 115 kV                   | @STE   | 173 MW  | L/O Sandbar – Plattsburgh (PV-20) 115 kV   |

**Note**

- 1: Moses South limit used the NYSRC Rules Exception No. 10 – Post Contingency Flows on Marcy AT1 Transformer
- 2: Moses South limit used the NYSRC Rules Exception No. 12 – Post Contingency Flows on Marcy AT2 Transformer

**TABLE 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25**
**ALL LINES IN-SERVICE**

|   | DIRECT TIE | NYISO FACILITY | ISO-NE FACILITY | DIRECT TIE  | NYISO FACILITY | ISO-NE FACILITY |
|---|------------|----------------|-----------------|---|----------------|-----------------|
| Cricket Valley Energy Center Out of Service |            |                |                 | Cricket Valley Energy Center in Service (1105 MW) |                |                 |

*Northport – Norwalk 0MW*

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 2375 MW (1) | 5825 MW (3) | 3050 MW (5) | 2275 MW (1) | 6050 MW (3) | 2900 MW (5) |
| <b>EMERGENCY</b> | 2875 MW (2) | 6100 MW (4) | 3750 MW (6) | 2700 MW (2) | 6350 MW (4) | 2550 MW (6) |

*Northport – Norwalk 100MW*

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 2400 MW (1) | 5775 MW (3) | 3100 MW (5) | 2250 MW (2) | 5500 MW (3) | 2950 MW (5) |
| <b>EMERGENCY</b> | 2450 MW (2) | 6050 MW (4) | 3850 MW (6) | 2250 MW (2) | 5825 MW (4) | 3650 MW (6) |

*Northport – Norwalk 200 MW*

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 2000 MW (2) | 5725 MW (3) | 3100 MW (5) | 1800 MW (2) | 5950 MW (3) | 3000 MW (5) |
| <b>EMERGENCY</b> | 2000 MW (2) | 6000 MW (4) | 3950 MW (6) | 1800 MW (2) | 6250 MW (4) | 3750 MW (6) |

| LIMITING ELEMENT |  | RATING |         | LIMITING CONTINGENCY |   |
|------------------|--|--------|---------|----------------------|---|
| (1)              | Long Mountain – Cricket Valley (398) 345 kV    | @LTE   | 1935 MW | L/O                  | Northfield Mount – Berkshire (312) 345 kV<br>Berkshire – Alps (393) 345 kV<br>Northfield 345/13.8/13.8 kV Transformer |
| (2)              | Northport – Norwalk Harbor (NNC) 138 kV        | @STE   | 569 MW  | L/O                  | Long Mountain – Cricket Valley (398) 345 kV   |
| (3)              | North Troy – Hoosick (5) 115 kV                | @STE   | 317 MW  | L/O                  | Northfield Mount – Berkshire (312) 345 kV<br>Berkshire – Alps (393) 345 kV<br>Northfield 345/13.8/13.8 kV Transformer |
| (4)              | North Troy – Hoosick (5) 115 kV                | @STE   | 317 MW  | L/O                  | Berkshire – Alps (393) 345 kV   |
| (5)              | Norwalk Junction – Archers Lane (3403D) 345 kV | @LTE   | 922 MW  | L/O                  | Long Mountain – Frost Bridge (352) 345 kV   |
| (6)              | Norwalk Junction – Archers Lane (3403D) 345 kV | @NORM  | 1823 MW |                      | Pre-Contingency Loading   |

**NOTE**

- 1: The Northport – Norwalk Harbor (NNC) flow is positive in the direction of transfer
- 2: The Northport – Norwalk Harbor (NNC) line is no longer part of the New York – New England Interface Definition



**TABLE 2.b – ISO-NE to NYISO INTERFACE THERMAL LIMITS - WINTER 2024-25**
**ALL LINES IN-SERVICE**

|  | DIRECT TIE | NYISO FACILITY | ISO-NE FACILITY | DIRECT TIE   | NYISO FACILITY | ISO-NE FACILITY |
|--|------------|----------------|-----------------|--|----------------|-----------------|
| <b>Cricket Valley Energy Center Out of Service</b> |            |                |                 | <b>Cricket Valley Energy Center in Service (1105 MW)</b> |                |                 |

**Norwalk –Northport @ 0 MW**

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 2250 MW (1) | 2225 MW (3) | 1550 MW (6) | 2425 MW (1) | 1850 MW (3) | 1950 MW (6) |
| <b>EMERGENCY</b> | 2475 MW (2) | 2225 MW (3) | 2875 MW (7) | 2850 MW (4) | 1850 MW (3) | 3250 MW (7) |

**Norwalk –Northport @ 100 MW**

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 1950 MW (2) | 2175 MW (3) | 1600 MW (6) | 2350 MW (5) | 1775 MW (3) | 2000 MW (6) |
| <b>EMERGENCY</b> | 1950 MW (2) | 2175 MW (3) | 2875 MW (8) | 2350 MW (2) | 1775 MW (3) | 3250 MW (8) |

**Norwalk–Northport @ 200 MW**

|                  |             |             |             |             |             |             |
|------------------|-------------|-------------|-------------|-------------|-------------|-------------|
| <b>NORMAL</b>    | 1425 MW (2) | 2100 MW (3) | 1650 MW (6) | 1825 MW (2) | 1725 MW (3) | 2050 MW (6) |
| <b>EMERGENCY</b> | 1425 MW (2) | 2100 MW (3) | 2750 MW (8) | 1825 MW (2) | 1725 MW (3) | 3100 MW (8) |

| LIMITING ELEMENT |  | RATING |         | LIMITING CONTINGENCY |   |
|------------------|--|--------|---------|----------------------|---|
| (1)              | Cricket Valley – Long Mountain (398) 345 kV                    | @LTE   | 1935 MW | L/O                  | Northfield Mountain – Berkshire 345 kV<br>Berkshire – Alps (393) 345 kV<br>Berkshire 115/345 kV |
| (2)              | Northport – Norwalk Harbor (NNC) 138 kV                        | @STE   | 569 MW  | L/O                  | Long Mountain – Cricket Valley (398) 345 kV   |
| (3)              | Reynolds Road 345/115 kV Transformer                           | @STE   | 699 MW  | L/O                  | Knickerbocker – Alps (6) 345 kV   |
| (4)              | Cricket Valley – Long Mountain (398) 345 kV                    | @NORM  | 1533 MW |                      | Pre-Contingency Loading   |
| (5)              | Northport – Norwalk Harbor (NNC) 138 kV                        | @STE   | 569 MW  | L/O                  | Long Mountain – Cricket Valley (398) 345 kV<br>Cricket Valley GT3&ST3                           |
| (6)              | Norwalk Junction – Archers Lane (3403D) 345 kV                 | @LTE   | 922 MW  | L/O                  | Long Mountain – Frost Bridge (352) 345 kV   |
| (7)              | Norwalk Junction – Archers Lane (3403D) 345 kV                 | @NORM  | 1823 MW |                      | Pre-Contingency Loading   |
| (8)              | Norwalk – Singer (3290) 345kV<br>Norwalk – Singer (3921) 345kV | @NORM  | 1392 MW |                      | Pre-Contingency Loading   |

**NOTE**

1: The Northport – Norwalk Harbor (NNC) flow is positive in the direction of transfer

2: The Northport – Norwalk Harbor (NNC) line is no longer part of the New England – New York Interface Definition

**TABLE 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25**  
**ALL LINES IN-SERVICE**

|                                | DIRECT TIE  | NYISO FACILITY | PJM FACILITY | DIRECT TIE                         | NYISO FACILITY | PJM FACILITY |
|--------------------------------|-------------|----------------|--------------|------------------------------------|----------------|--------------|
| <b>B&amp;C PARs In-Service</b> |             |                |              | <b>B&amp;C PARs Out-Of-Service</b> |                |              |
| <b>NORMAL</b>                  | 2125 MW (1) | 2525 MW (4)3   | 3350 MW (8)  | 1825 MW (1)                        | 2175 MW (2)3   | 2900 MW (8)  |
| <b>3-115-O/S</b>               | 2725 MW (3) | 2725 MW (2)3   | 3700 MW (9)  | 2425 MW (3)                        | 2450 MW (2)3   | 3425 MW (9)  |
| <b>EMERGENCY</b>               | 2150 MW (7) | 2525 MW (4)3   | 3350 MW (8)  | 1875 MW (7)                        | 2250 MW (2)3   | 2900 MW (8)  |
| <b>3-115-O/S</b>               | 2900 MW (6) | 2975 MW (5)3   | 3700 MW (9)  | 2625 MW (6)                        | 2900 MW (5)3   | 3425 MW (9)  |

| LIMITING ELEMENT |   | RATING |        | LIMITING CONTINGENCY |   |
|------------------|---|--------|--------|----------------------|---|
| (1)              | East Sayre – North Waverly (956) 115 kV | @STE   | 127 MW | L/O                  | East Towanda – Hillside (70) 230 kV<br>Hillside 115/69 kV                   |
| (2)              | Oakdale Transformer (BK2) 345kV/115kV   | @LTE   | 557 MW | L/O                  | Oakdale – Watercure (31) 345kV<br>Oakdale 3-Winding (BK3)<br>345/115/34.5kV |
| (3)              | East Towanda – Hillside (70) 230 kV     | @LTE   | 594 MW | L/O                  | Mainesburg – Watercure (30) 345 kV  |
| (4)              | Oakdale – Goudey (939) 115 kV           | @STE   | 292 MW |                      | Pre-Contingency Loading   |
| (5)              | S. Oswego – Goudey (961) 115 kV         | @STE   | 167 MW | L/O                  | Oakdale – Watercure (31) 345kV  |
| (6)              | East Towanda – Hillside (70) 230 kV     | @STE   | 670 MW | L/O                  | Mainesburg – Watercure (30) 345 kV  |
| (7)              | East Sayre – North Waverly (956) 115 kV | @STE   | 127 MW | L/O                  | East Towanda – Hillside (70) 230 kV   |
| (8)              | Tiffany – Laurel Lake 115 kV            | @STE   | 151 MW |                      | Pre-Contingency Loading   |
| (9)              | S. Troy – Evert Drive 115 kV            | @STE   | 310 MW | L/O                  | Hillside – East Towanda (70) 230 kV   |

**NOTE**

- 1: Emergency Transfer Capability Limits may have required line outages as described in the New York - PJM Analysis section.
- 2: PAR schedules have been adjusted in the direction of transfer.
- 3: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets (typically 115 kV)

**TABLE 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS – Winter 2024-25**
**ALL LINES IN-SERVICE**

|                                | DIRECT<br>TIE | NYISO<br>FACILITY | PJM<br>FACILITY | DIRECT<br>TIE                      | NYISO<br>FACILITY | PJM<br>FACILITY |
|--------------------------------|---------------|-------------------|-----------------|------------------------------------|-------------------|-----------------|
| <b>B&amp;C PARs In-Service</b> |               |                   |                 | <b>B&amp;C PARs Out-Of-Service</b> |                   |                 |
| <b>NORMAL</b>                  | 1925 MW (1)   | 2350 MW (2)3      | 2600 MW (3)     | 1925 MW (1)                        | 2300 MW (2)3      | 2600 MW (4)     |
| <b>3-115-O/S</b>               | 2600 MW (5)   | 2600 MW (6)3      | 3250 MW (8)     | 2400 MW (5)                        | 2600 MW (7)3      | 3500 MW (8)     |
| <b>EMERGENCY</b>               | 1950 MW (9)   | 2925 MW (10)3     | 2600 MW (3)     | 1950 MW (9)                        | 2750 MW (10)3     | 2825 MW (11)    |
| <b>3-115-O/S</b>               | 2600 MW (12)  | 2925 MW (13)3     | 3450 MW (14)    | 2575 MW (12)                       | 2925 MW (13)3     | 3700 MW (14)    |

| LIMITING ELEMENT |   | RATING |        | LIMITING CONTINGENCY |  |
|------------------|---|--------|--------|----------------------|--|
| (1)              | North Waverly – East Sayre (956) 115 kV | @STE   | 127 MW | L/O                  | Hillside – East Towanda (70) 230 kV<br>Hillside – Watercure (69) 230 kV<br>Hillside 230/115 kV Transformer |
| (2)              | North Waverly – Lounsberry 115 kV       | @STE   | 167 MW | L/O                  | Watercure – Oakdale (31) 345 kV<br>Clarks Corners – Oakdale (36) 345kV                                     |
| (3)              | Lenox – Tiffany 115 kV                  | @NORM  | 151 MW |                      | Pre-Contingency Loading  |
| (4)              | Lenox – Tiffany 115 kV                  | @LTE   | 190 MW | L/O                  | Oakdale – Clarks Corners (36) 345 kV<br>Watercure – Oakdale (31) 345 kV                                    |
| (5)              | Hillside – East Towanda (70) 230 kV     | @LTE   | 594 MW | L/O                  | Watercure – Mainseburg (30) 345 kV   |
| (6)              | Chemung – Hillside (962) 115 kV         | @STE   | 155 MW | L/O                  | Watercure – Oakdale (31) 345 kV<br>Clarks Corners – Oakdale (36) 345kV                                     |
| (7)              | Oakdale 230/115 kV (BK1)                | @LTE   | 398 MW | L/O                  | Oakdale – Clarks Corners (36) 345 kV<br>Watercure – Oakdale (31) 345 kV                                    |
| (8)              | Everett Drive – Mainseburg 115 kV       | @LTE   | 286 MW | L/O                  | Hillside – East Towanda (70) 230 kV<br>Hillside – Stoney Ridge (72) 230 kV                                 |
| (9)              | North Waverly – East Sayre (956) 115 kV | @STE   | 127 MW | L/O                  | Hillside – East Towanda (70) 230 kV  |
| (10)             | Gridle Rd. – Stolle Rd. (706) 115 kV    | @STE   | 239 MW | L/O                  | Five Mile (BK1) 345/115kV Transformer  |
| (11)             | Lenox – Tiffany 115 kV                  | @STE   | 205 MW | L/O                  | Hillside – East Towanda (70) 230 kV  |
| (12)             | Hillside – East Towanda (70) 230 kV     | @STE   | 670 MW | L/O                  | Watercure – Mainseburg (30) 115kV  |
| (13)             | Oakdale – Watercure (31) 345 kV         | @STE   | 717 MW | L/O                  | Oakdale – Watercure (71) 345 kV  |
| (14)             | Everett Drive – Mainseburg 115 kV       | @STE   | 307 MW | L/O                  | Hillside – East Towanda (70) 230 kV  |

**NOTE**

- 1: Emergency Transfer Capability Limits may have required line outages as described in New York – PJM Analysis Section.
- 2: PAR schedules have been adjusted in the direction of transfer.
- 3: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets.

**TABLE 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25**
**ALL LINES IN-SERVICE**

|                  | DIRECT TIE  | NYISO FACILITY   | IESO FACILITY1 |
|------------------|-------------|------------------|----------------|
| <b>NORMAL</b>    | 2500 MW (1) | 3150 MW (3)1, 2, | 4275 MW (5)    |
| <b>EMERGENCY</b> | 3100 MW (2) | 3175 MW (4)1, 2, | 4450 MW (6)    |

| LIMITING ELEMENT |                                  | RATING      |     | LIMITING CONTINGENCY   |
|------------------|----------------------------------|-------------|-----|--|
| (1)              | Beck - Niagara (PA27) 230 kV     | @LTE 540 MW | L/O | Beck - Niagara (PA301) 345 kV  |
| (2)              | Beck - Niagara (PA27) 230 kV     | @STE 685 MW | L/O | Beck - Niagara (PA301) 345 kV  |
| (3)              | Lockport – Hinman (100) 115 kV   | @STE 317 MW | L/O | Robinson Road – Stolle Road (65) 230 kV<br>Gardenville – Stolle Road (66) 230 kV Stolle<br>Road – High Sheldon (67) 230 kV |
| (4)              | Lockport – Hinman (100) 115 kV   | @STE 371 MW | L/O | Robinson – Stolle Road (65) 230 kV   |
| (5)              | Mt Hope – Allanburg (Q30M) 230kV | @LTE 426 MW | L/O | Beck – Middleport (Q26M) 230 kV<br>Beck – Middleport (Q35M) 230 kV   |
| (6)              | Mt Hope – Allanburg (Q30M) 230kV | @STE 450 MW | L/O | Beck – Middleport (Q26M) 230 kV  |

**Note**

1: Ontario - NYISO limit used the NYSRC Rules Exception No. 13 – Post Contingency Flows on Niagara Project Facilities

2: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets

**TABLE 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS – WINTER 2024-25**  
**ALL LINES IN-SERVICE**

|                  | DIRECT TIE  | NYISO FACILITY  | IESO FACILITY <sup>1</sup> |
|------------------|-------------|-----------------|----------------------------|
| <b>NORMAL</b>    | 1875 MW (1) | 4575 MW (2) 2,3 | 1100 MW (5)                |
| <b>EMERGENCY</b> | 2250 MW (4) | 4750 MW (3) 2,3 | 1750 MW (6)                |

| LIMITING ELEMENT |                                      | RATING |        | LIMITING CONTINGENCY |   |
|------------------|--------------------------------------|--------|--------|----------------------|---|
| (1)              | Beck – Niagara (PA27) 230 kV         | @LTE   | 540 MW | L/O                  | Beck - Niagara (PA301) 345 kV                                       |
| (2)              | Hamilton – Farmington (7-983) 115 kV | @STE   | 209 MW | L/O                  | Clay – Pannell (2) 345 kV<br>Rochester – Pannell (RP2) 345 kV       |
| (3)              | Hamilton – Farmington (7-983) 115 kV | @STE   | 209 MW | L/O                  | Pannell – Clay (2) 345 kV   |
| (4)              | Beck – Niagara (PA27) 230 kV         | @NORM  | 480 MW |                      | Pre-Contingency loading   |
| (5)              | Beck – Hannon (Q24) 220 kV           | @LTE   | 561 MW | L/O                  | Beck – Middleport (Q25M) 230 kV<br>Beck – Middleport (Q29HM) 230 kV |
| (6)              | Beck – Hannon (Q24) 220 kV           | @NORM  | 501 MW |                      | Pre-Contingency Loading   |

**Note**

- 1: This limit can be increased by reducing generation or increasing demand in the Niagara zone of Ontario contingent on water and tourism regulations. See Ontario – New York Analysis for discussion.
- 2: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets.
- 3: This limit can be increased by adjusting the PAR schedule on the Dysinger – East Stolle Rd (DES-1) 345 kV line, reducing the flows into East Stolle Rd. 345 kV substation.