



NYISO Operating Study Winter 2025-2026

**A Report by the
New York Independent System Operator**

October 2025

Table of Contents

EXECUTIVE SUMMARY	4
INTRODUCTION	5
PURPOSE	5
SYSTEM OPERATING LIMIT (SOL) METHODOLOGY	5
STUDY PARTICIPANTS	6
SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS	7
System Representation	7
<i>Generation Resource Changes</i>	8
<i>Transmission Facilities Changes</i>	9
System Representation	9
DISCUSSION	11
Resource Assessment	11
Load and Capacity Assessment	11
Cross-State Interfaces	11
Transfer Limit Analysis	11
West Woodbourne Transformer	13
ConEd – LIPA Transfer Analysis	13
Transfer Limits for Outage Conditions	14
Transient Stability and Voltage transfer Limits	14
Thermal Transfer Capabilities with Adjacent Balancing Areas	15
<i>New York – New England Analysis</i>	16
<i>New York - PJM Analysis</i>	17
<i>Ontario – New York Analysis</i>	18
<i>TransÉnergie–New York Interface</i>	20
SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS	21
TABLE 1.a – NYISO CROSS-STATE INTERFACE THERMAL drftTRANSFER LIMITS - WINTER 2024-25	22
TABLE 1.b – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25	23
TABLE 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25	24
TABLE 2.b – ISO-NE to NYISO INTERFACE THERMAL LIMITS - WINTER 2024-25	25
TABLE 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25	26

TABLE 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS – Winter 2024-25.....	27
TABLE 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS - WINTER 2024-25.....	28
TABLE 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS – WINTER 2024-25	29

Executive Summary

This study is conducted as a seasonal review of the projected thermal transfer capability for the Winter 2025-26 period. The study evaluates the projected internal and external thermal transfer capabilities for the forecasted load and dispatch conditions studied. The evaluated limits are shown in Tables 1 through 5. Differences in the evaluated internal interface limits from Winter 2024-25 to Winter 2025-26 are shown in Figure 1 on page 11. Internal limits have changed due to network alterations in the New York Control Area (NYCA) and modeling assumptions.

- **Dysinger East** interface thermal transfer limit decreased by 50 MW mainly due to redistribution of flows from change in load pattern in West and Genessee areas.
- **West Central Reverse** interface thermal transfer limit increased by 175 MW mainly due to a rating increase on the Clay – Pannell (1) 345 kV and Clay – Pannell (2) 345 kV lines.
- **Sprain Brook Dunwoodie S.** interface thermal transfer limit increased by 50 MW mainly due to the modeling of Y49 Series Reactor as bypassed.
- **Total East** interface thermal transfer limit increased by 500 MW mainly due to the modeling of Knickerbocker series compensation in-service.
- **Central East** interface thermal transfer limit increased by 125 MW mainly due to the modeling of Knickerbocker series compensation in-service.
- **Moses South** Moses South interface thermal transfer limit increased by 475 MW mainly due to the modeling of the Smart Path Connect project as in-service.

Differences in the evaluated external interface limits from Winter 2024-2025 to Winter 2025-2026 are shown in Figure 2 on page 14 and all the external thermal transfer limits remain unchanged.

INTRODUCTION

The following report, prepared by the Operating Studies Task Force (OSTF) at the direction and with the guidance of the System Operations Advisory Subcommittee (SOAS), highlights the thermal transfer analysis evaluation for the Winter 2025-2026 capability period. This analysis indicates that, for the Winter 2025-2026 capability period, the New York interconnected bulk power system can be operated reliably in accordance with the New York State Reliability Council Reliability Rules and the NYISO System Operating Procedures.

Thermal transfer limits cited in this report are based on the forecasted load and dispatch assumptions and are intended as a guide to system operation. Changes in generation dispatch or load patterns that significantly change pre-contingency line loadings may change limiting contingencies or limiting facilities, resulting in higher or lower interface transfer capabilities.

System Operators should monitor the critical facilities noted in the included tables along with other limiting conditions while maintaining bulk power system transfers within secure operating limits.

PURPOSE

The purpose of the study is to determine:

- The total transfer capabilities (TTC) between NYISO and adjacent areas including IESO, PJM and ISO-NE for normal conditions in the summer/winter periods. The TTC is calculated based on NERC TPL-001-5 Category P1 and P2 contingencies and a set of selected Category P4, P5 and P7 contingencies.
- The TTC between NYISO and adjacent areas including IESO, PJM and ISO-NE for emergency conditions in the summer/winter periods. The TTC is calculated based on NERC TPL-001-5 Category P1 and P2 contingencies.

System Operating Limit (SOL) Methodology

As identified in “FAC-011-4_Methodology for Establishing SOL for the Operations Horizon_20240401”, the NYSRC Reliability Rules provide the documented methodology for use in developing System Operating Limits (SOLs) within the NYISO Reliability Coordinator Area. NYSRC Reliability Rules require compliance with all North American Electric Reliability Corporation (NERC) Standards and Northeast Power Coordinating Council (NPCC) Standards and Criteria. NYSRC Rule C.1, Tables C-1 and C-2 address the contingencies to be evaluated and the performance requirements to be applied. Rule C.1 also incorporates by reference Attachment H, NYISO

Transmission Planning Guideline #3-1, “Guideline for Stability Analysis and Determination of Stability-Based Transfer Limits” of the NYISO Transmission Expansion and Interconnection Manual.

STUDY PARTICIPANTS

First Name	Last Name	Company Name	First Name	Last Name	Company
Hao	Fu	PSEG Long Island*	Raj	Dontireddy	NYISO
John	Koziatek	PSEG Long Island*	Declan	Cahill	NYISO
Daniel	Head	ConEd	Sid	Nashurdeen	NYISO
Mohammed	Rahman	ConEd	Francisco	Sandoval	NYISO
Brent	Blanchard	NYPA	Elvin	D’Souza	IESO
Frank	Grimaldi	NYPA	Sasa	Mizdrak	IESO
Jeffery	Maher	National Grid	Mark	Dettrey	PJM
Phil	Nichols	National Grid	Akash	Patel	PJM
Sarah	Ambrose	O&R	Mark	Dettrey	PJM
Kevin	Mei	O&R	Gabriel	Dion Marcotte	HQ
Tom	Brown	O&R	Jonathan	Landry-Leclerc	HQ
Caroline	Decker	Central Hudson	Alex	Parsell	ISO-NE
Ruby	Chan	Central Hudson	Joseph	Koltz	ISO-NE
Robert	Gollogly	RG&E			
Robert	Houston	RG&E			
Jin	Hao	NYSEG			
Brian	Gordon	NYSEG			
John	McDonald	NextEra Energy			
Jeffrey	Mullen	NextEra Energy			
Jason	Kampschaefer	LS Power			
Matthew	Senus	LS Power			
Phil	Tatro	Transco			
Jim	McCloskey	Transco			

*Agent for LIPA

SYSTEM REPRESENTATION AND BASE STUDY ASSUMPTIONS

System Representation

The representation was developed from the NYISO Data Bank and assumes the forecast winter coincident peak load of 24,200 MW. The other NPCC Balancing Areas and adjacent Regional representations were obtained from the RFC-NPCC Winter 2025-2026 Reliability Assessment power flow base case and have been updated to reflect the Winter 2025-2026 capability period.

The base case model includes:

- The NYISO Transmission Operator area
- All Transmission Operator areas contiguous with NYISO
- All system elements modeled as in-service
- All generation represented
- Phase shifters in the regulating mode in accordance with the NYISO Available Transfer Capability Implementation Document (ATCID)
- The NYISO Load Forecast
- Transmission Facility additions and retirements
- Generation Facility additions and retirements
- Remedial Action Scheme (RAS) models where currently existing or projected for implementation within the studied time horizon
- Series compensation for each line at the expected operating level unless specified otherwise in the ATCID.
- Facility Ratings as provided by the Transmission Owner and Generator Owner

Generation Resource Changes

The status and dispatch level of generation represented in this analysis is a reasonable expectation based on the information available at the time of the study. Those modeling assumptions incorporate known unit outage status. The inter-Area schedules represented in the study base case are summarized in Appendix A. The following table shows generation deactivations and additions since the Winter 2024-25 capability period:

Deactivations	
Astoria GT 1	-16 MW
Glenwood GT	-16 MW
West Babylon 4	-52.4 MW
Shoreham 2	-18.6 MW
59 St GT	-17.1 MW
Madison Wind Power	-11.6 MW
Far Rockaway GT1	-60.5 MW
Far Rockaway GT2	-60.5 MW
Pinelawn Power 1	-82 MW
Total Retirements	-334.7 MW
Additions	
SunEast Scipio Solar	18 MW
Flat Hill Solar	20 MW
Grassy Knoll Solar	20 MW
Yellow Barn Solar	160 MW
Clear View Solar	20 MW
Transit Solar	20 MW
Riverhead Expansion (Calverton Solar)	36 MW
Total Additions	294 MW

Transmission Facilities Changes update list

Significant facility changes since the Winter 2024-25 capability period include:

- Dover PAR (Y17, T-398-A, T-398-B) 345 kV addition
- Smart Path Connect Project (Adirondack station, Austin Road station, Haverstock station) 345 kV upgrade and Willis Anex 230 kV addition
- Gowanus-Greenwood (42233) 138 kV PAR & feeder addition
- Goethals-Fox Hills (39291) 138 kV PAR & feeder addition
- Marcy STATCOM (CSC) returned in-service
- Edic (BK3) 345/115 kV transformer returned in-service
- Gowanus – Greenwood (42G24 & 42G51) 138 kV returned in-service
- Vernon 138 kV (38M06) modeled out-of-service
- Farragut 345/138 kV (BK2X) modeled out-of-service
- Farragut – Plymouth St 138 kV (32072) modeled out-of-service

The addition of the Smart Path Connect project impacts the Moses South interface definition. The project includes upgrades from the existing Adirondack 230 kV station to 345 kV, the addition of Austin Road 345 kV station, the addition of Haverstock 345 kV station and the addition of Willis Annex 230 kV station. The addition of the Dover 345 kV PAR impacts the NYISO-ISONNE interface definition. It intersects the pre-existing Cricket Valley – Long Mountain (398) 345 kV line and changes the definition to Dover – Long Mountain (398) 345 kV.

System Representation

The Siemens PTI PSS™E and PowerGEM's Transmission Adequacy and Reliability Assessment "TARA" software packages were used to calculate the thermal limits based on Normal and Emergency Transfer Criteria as defined in the NYSRC Reliability Rules. The thermal transfer limits presented have been determined for all transmission facilities scheduled in-service during the Winter 2025-2026 period.

The schedules used in the base case power flow for this analysis assumed a net flow of 0 MW from Public Service Electric & Gas (PSE&G) to Consolidated Edison via the PAR transformers controlling the Hudson – Farragut and Linden – Goethals interconnections, and 0 MW on the South Mahwah – Waldwick circuits from Consolidated Edison to PSE&G, controlled by the PARs at Waldwick. The Hopatcong – Ramapo (5018) 500 kV circuit is scheduled to 202 MW from PJM to New York. The four Ontario – Michigan PARs are modeled in-service and scheduled to a 0 MW transfer. These schedules are consistent with the scenarios developed in the RFC-NPCC Inter-Regional Reliability Assessment for Winter 2025-2026, and the MMWG Winter 2025-2026 power flow base cases. The Dysinger – East Stolle Rd. PAR is scheduled to 400 MW from Dysinger to East Stolle Rd. The series reactors on the Farragut – Gowanus (41 and 42) 345 kV cables, Packard – Sawyer (77 and 78) 230 kV feeders, as well as the E. 179th St. – Hell Gate (15055) 138 kV feeder are in-service in the base case. The series reactors on the Dunwoodie – Mott Haven (71 and 72) and the Sprain Brook – W. 49th St. (M51 and M52) 345 kV and Sprain Brook – East Garden City (Y49) 345 kV cable are by-passed. The series capacitors on the Marcy – Coopers Corners (UCC2-41) 345 kV, the Edic – Fraser (EF24-40) 345 kV, and the Fraser – Coopers Corners (33) 345 kV are by-passed in the base case. The series capacitors on the Knickerbocker – Pleasant Valley (Y57) 345 kV circuit are modeled in-service in the base case.

Smart Wire SmartValve, a modular static synchronous series compensator is installed at the Hurley 345 kV substation on the Leeds – Hurley (301) 345 kV line. This device injects voltage in quadrature with the line current to synthesize a capacitive or inductive reactance. The device is expected to be operated in capacitive reactance mode and will be changed as deemed necessary by the NYISO.

The NYISO Niagara generation was modeled using a 50-50 split on the 230 kV and 115 kV generators. The total output for the Niagara facility was modeled at 2,100 MW. The Ontario Beck generation was modeled at an output of 1,300 MW.

DISCUSSION

Resource Assessment

Load and Capacity Assessment

The forecast peak demand for the Winter 2025-2026 capability period is 24,200 MW¹. This forecast is approximately 400 MW (1.68%) higher than the forecast of 23,800 MW for the Winter 2024-25 capability period, and 1,538 MW (5.98%) lower than the all-time New York Control Area (NYCA) seasonal peak of 25,738 MW, which occurred on January 7, 2014.

The Installed Capacity (ICAP) requirement for the Winter capability period is 39,148MW based on the NYSRC 24.4% Installed Reserve Margin (IRM) requirement for the 2025 Capability Year. NYCA generation capacity for Winter 2025-2026 is 40,080MW, and net external capacity purchases of 1,203 MW have been secured for the Winter period. The combined capacity resources represent a 70.5% margin above the forecast peak demand of 24,200 MW. These values were taken from the 2025 Load & Capacity Data report produced by the NYISO and updated with known changes at the time of this writing.

The Winter assumed unavailable capacity is 6,109 MW, and includes forced outages and de-ratings based on historical performance of all generation in the NYCA. For Winter 2024-25, the equivalent forced outage rate assumed was 3.21%.

Cross-State Interfaces

Transfer Limit Analysis

This report summarizes the results of thermal transfer limit analyses performed on power system representation modeling the forecast peak load conditions for Winter 2025-2026. Normal and emergency thermal limits were calculated according to Normal and Emergency Transfer Criteria definitions in the NYSRC Reliability Rules. For this assessment period the most severe single generation contingency is Nine Mile Point 2 at 1,310 MW. Facility ratings applied in the analysis were from the online MW ratings in the EMS, and are detailed in Appendix D.

Figure 1 presents a comparison of the Winter 2025-2026 thermal transfer limits to Winter 2024-25 thermal transfer limits. Changes in these limits from previous years are due to changes in

¹ Forecast Coincident Peak Demand (50th percentile baseline forecast)

the base case load flow generation and load patterns that result in different pre-contingency line loadings, changes in limiting contingencies, changes in circuit ratings, or line status. Appendix H presents a summary comparison of Cross-State thermal transfer limits between Winter 2025-2026 and 2024-2025, with limiting element/contingency descriptions. Significant differences in these thermal transfer limits are discussed below.




Figure 1 – Cross-State Thermal Transfer Limits

Dysinger East interface thermal transfer limit decreased by 50 MW mainly due to redistribution of flows from change in load pattern in West and Genessee areas.

West Central Reverse interface thermal transfer limit increased by 175 MW mainly due to a rating increase on the Clay – Pannell (1) 345 kV and Clay – Pannell (2) 345 kV lines.

Total East interface thermal transfer limit increased by 500 MW mainly due to the modeling of Knickerbocker series compensation in-service.

Central East interface thermal transfer limit increased by 125 MW mainly due to the modeling of Knickerbocker series compensation in-service.

Sprain Brook Dunwoodie S. interface thermal transfer limit increased by 50 MW mainly due to the change modeling Y49 Series Reactor as by-passed.

Moses South interface thermal transfer limit increased by 475 MW mainly due to the modeling of the Smart Path Connect project as in-service.

West Woodbourne Transformer

The Total-East interface may be limited at significantly lower transfer levels for certain contingencies that result in overloading of the West Woodbourne 115/69 kV transformer. Should the West Woodbourne tie be the limiting facility, it may be removed from service to allow higher Total-East transfers. Over-current relays are installed at West Woodbourne and Honk Falls to protect for contingency overloads.

ConEd – LIPA Transfer Analysis

Normal transfer capabilities were determined using the base case generation dispatch and PAR settings as described in Appendix B. Emergency limits are dispatch dependent, and can vary based on generation and load patterns in the LIPA system.

For emergency transfer capability analysis, the PARs controlling the LIPA import were adjusted to allow for maximum transfer capability into LIPA:

<u>ConEd – LIPA PAR Settings</u>		
	Normal	Emergency
Jamaica – Lake Success 138 kV	-200 MW	81 MW
Jamaica – Valley Stream 138 kV	-100 MW	227 MW
Sprain Brook – E. Garden City 345 kV	693 MW	693 MW
<u>ISO-NE – LIPA PAR Settings</u>		
Norwalk Harbor – Northport 138 kV	100 MW	286 MW

The PAR schedules referenced above and the ConEd - LIPA transfer assessment assume the following loss factors and oil circulation modes in determination of the facility ratings for the 345 kV cables:

- Y49 has a 70% loss factor in slow oil circulation mode.
- Y50 has a 70% loss factor in rapid circulation mode.

Emergency Transfer via the 138 kV PAR-controlled Jamaica ties between Con Edison and LIPA

Con Edison and LIPA have determined possible emergency transfer levels via the Jamaica - Valley Stream (901) 138 kV and Jamaica - Lake Success (903) 138 kV PAR-controlled ties that could be used to transfer emergency power between the two entities during peak conditions. The emergency transfer levels were calculated in both directions, for system peak load conditions with all transmission lines in-service and all generation available at full capacity.

ConEd to LIPA emergency assistance

Based on load flow analysis performed by Con Edison, Con Edison anticipates being able to supply a total flow up to 308 MW of emergency transfer from Con Edison to Long Island, if requested, via the ties for the coming Winter season.

LIPA to ConEd emergency assistance

LIPA anticipates being able to supply a total flow up to 497 MW of emergency transfer from Long Island to Con Edison, if requested, via the ties under ideal conditions (i.e. all lines and generation in-service, imports via Neptune, Norwalk Harbor to Northport Cable - NNC and Cross Sound Cable - CSC).

Transfer Limits for Outage Conditions

Transfer limits for scheduled outage conditions are determined by the NYISO Scheduling and Market Operations groups. The NYISO Real-Time Dispatch system monitors the EHV transmission continuously to maintain the secure operation of the interconnected EHV system.

Transient Stability and Voltage transfer Limits

The interface transfer limits shown in “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section are the results of a thermal transfer limit analysis only. Transient stability and voltage interface transfer limits for all lines in-service and line outage conditions are summarized and available through the NYISO website located under “Interface Limits & Op Studies” at the following link: <https://www.nyiso.com/reports-information>

Thermal Transfer Capabilities with Adjacent Balancing Areas




Figure 2 - Inter-Area Thermal Transfer Capabilities²

Thermal transfer limits between New York and adjacent Balancing Areas also are determined in this analysis. These transfer limits supplement, but do not change, existing internal operating limits. There may be facilities internal to each system that may reduce the transfer limits between Balancing Areas. Reductions due to these situations are considered to be the responsibility of the

² TE-NY transfer capabilities shown in Figure 2 are not thermal transfer limits; for more information see page 18

respective reliability authority. Some of these potential limitations are indicated in the summary tables by “Reliability Coordinating Facility” limits, which supplement the “Direct Tie” limits between the Balancing Areas. Transfer conditions within and between neighboring Balancing Areas can have a significant effect on inter- and intra-Area transfer limits. Coordination between Balancing Areas is necessary to provide optimal transfer while maintaining the reliability and security of the interconnected systems.

New York – New England Analysis

New England Transmission/Capacity Additions

Transmission

For the Winter 2025-2026 (October through May) study period, there are no major transmission projects coming into service that will significantly impact the New York – New England transmission capability.

Capacity

In the New England Control Area, for the Winter 2025-2026 study period, three major generation projects are expected to become commercial. This includes Vineyard Wind (800 MW Offshore Wind), Cross Town (175 MW Battery Energy Storage), and Medway Grid (250 MW Battery Energy Storage).

Approximately 9.1 MW of Solar Photovoltaic, 800 MW of Offshore Wind, and 467 MW of Battery Energy Storage Systems are anticipated to become commercial during this period.

There are no planned retirements anticipated during this period.

Thermal Transfer Limit Analysis

The transfer limits between the NYISO and ISO New England for normal and emergency transfer criteria are summarized in Tables 2.a and 2.b.

Cross-Sound Cable

The Cross-Sound Cable (CSC) is an HVDC merchant transmission facility connecting the New Haven Harbor 345 kV (United Illuminating, ISO-NE) station and Shoreham 138 kV (LIPA, NYISO) station. It has a design capacity of 330 MW. This facility is not metered as part of the NYISO – ISO-NE interface, and HVDC transfers are independent of transfers between the NYISO and ISO-NE.

Smithfield – Salisbury 69 kV

CHG&E and Eversource will normally operate the Smithfield - Salisbury 69 kV (FV/690) line closed. The maximum allowable flow on this line is 31 MVA based on limitations in the Eversource 69 kV system. When the ISO-NE to NYISO transfer is greater than approximately 400 MW, the line will be opened due to post contingency limits within the Eversource system. The FV/690 line has directional over-current protection

that will trip the FV/690 line in the event of an overload when the flow is into ISO-NE. No protection exists to trip the FV/690 line in the event of an overload when the flow is into NYISO.

Northport – Norwalk Harbor Cable Flow

Flow on the NNC Norwalk Harbor to Northport facility is controlled by PAR transformer at Northport. As system conditions vary, the scheduled flow on the NNC may be used to optimize transfer capability between the Balancing Areas. The thermal transfer limits are presented in Table 2 for different PAR schedule assumptions on the Northport – Norwalk Harbor interconnection.

Whitehall – Blissville 115 kV

The PAR transformer on the K7 line at the VELCO Blissville substation will control pre-contingency flow between the respective stations. For the analyses, the pre-contingency schedule is 25 MW from Blissville (ISO-NE) to Whitehall (NYISO). The scheduled flow may be adjusted to protect the National Grid local 115 kV transmission south of Whitehall for 345 kV contingency events in southern Vermont pursuant to joint operating procedure developed by VELCO, National Grid, ISO-NE and NYISO.

Plattsburgh – Sand Bar 115 kV (i.e. PV20)

The PAR transformer on the PV20 line at the VELCO Sand Bar substation was modeled holding a pre-contingency flow of approximately 100 MW on the PV20 tie. This modeling assumption was premised upon common operating understandings between ISO-NE and the NYISO given local operating practice on the Moses – Willis – Plattsburgh 230 kV transmission corridor. ISO-NE’s analysis examined and considered New England system limitations given this modeling assumption and did not examine generation dispatch or system performance on the New York side of the PV20 tie.

New York - PJM Analysis

Thermal Transfer Limit Analysis

The transfer limits for the NYISO – PJM and PJM – NYISO interfaces are summarized in Tables 3a and 3b respectively of the “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section of this report. The Marion-Farragut 345 kV B and C cables are expected to remain open and the Waldwick E, F, O and Goethals A paths are expected to deliver a percentage of the scheduled interchange as referenced in the NYISO-PJM JOA. The Hopatcong – Ramapo 500 kV (5018) circuit is scheduled in accordance with the “TCC Market PJM -NYISO Interconnection Scheduling Protocol”, February 28th, 2020.

Opening of PJM - New York 115 kV Ties as Required

The normal criteria thermal transfer limits presented in “SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS” section were determined for an all lines in-service condition. The 115

kV interconnections between First Energy East and New York (Warren – Falconer, North Waverly – East Sayre, and Laurel Lake – Westover) may be opened in accordance with NYISO and PJM Operating Procedures provided that this action does not cause unacceptable impact on local reliability in either system. Over-current protection is installed on the Warren - Falconer and the North Waverly – East Sayre 115 kV circuits; either of these circuits would trip by relay action for an actual overload condition. This North Waverly-East Sayre scheme is expected to be designated as a RAS in the future and hence the line could be expected to be operated as in-service more often. There is no overload protection on the Laurel Lake - Westover circuit, but it may be opened by operator action if there is an actual or post-contingency overload condition. However, opening the Laurel Lake – Westover tie could potentially cause local thermal and pre- and post-contingency voltage violations for the 34.5 kV distribution system within First Energy East transmission zone. Sensitivity analysis performed indicated that the thermal and voltage conditions were exacerbated for conditions that modeled high simultaneous interface flows from NY to PJM and NY to Ontario.

DC Ties

Neptune DC tie is expected to be available. Hudson Transmission Project (HTP) DC tie is expected to be available.

Variable Frequency Transformer (VFT) Tie

The Variable Frequency Transformer Tie is a transmission facility connecting the Linden 230 kV (PSEG, PJM) to Linden 345 kV (ConEd, NYISO). For the Winter 2025-2026, Linden VFT will have 330 MW non-firm withdrawal right and 300 MW firm injection rights into PJM market.

Ontario – New York Analysis

Thermal Transfer Limit Analysis

The thermal transfer limits between the NYISO and Ontario’s Independent Electricity System Operator (IESO) Balancing Areas for normal and emergency transfer criteria are presented in tables 4 and 5. The NYISO Niagara generation was modeled at an output of 2,100 MW.

The Ontario – New York ties at St. Lawrence, L33P and L34P PARs were controlling to 0 MW in all four scenarios. The interconnection flow limit across these ties is 300 MW, as presented in Table B3 “Interconnection Flow Limits” from the document “Reliability Outlook Tables” available at:

https://www.ieso.ca/-/media/Files/IESO/Document-Library/planning-forecasts/reliability-outlook/ReliabilityOutlookTables_2024Jun.xlsx

Transient Stability Limitations

Transient stability limits for the NYISO - IESO interconnection are reported in "NYPP-OH TRANSIENT STABILITY TESTING REPORT on DIRECT TIE TRANSFER CAPABILITY - OCTOBER 1993" available at:

https://www.nyiso.com/documents/20142/3694079/NYPP-OH_1993-2.pdf/2e21484a-22cf-739a-7a10-69dfd69f5d58

Ontario - Michigan PARs

All of the PARs on the four transmission lines interconnecting Ontario and Michigan are in-service and regulating. For this study, the PARs were scheduled to regulate at 0 MW.

Impact of the Queenston Flow West (QFW) Interface on the New York to Ontario Transfer Limit

The QFW interface is defined as the sum of the power flows through the 230 kV circuits out of Beck. QFW is the algebraic sum of the following:

- Total generation in the Niagara zone of Ontario including the units at the Beck #1, #2 & Pump Generating Stations, Thorold CGS and Decew Falls GS
- The total load in the Niagara zone
- The import from New York through the Niagara Interties.

For a given QFW limit, the import capability from New York depends on the generation dispatch and the load in the Niagara zone. The Ontario Niagara generation is set to 1,300 MW. The import capability from New York can be increased by decreasing generation in the Ontario Niagara zone contingent on water and tourism regulations, and increasing demand in the Ontario Niagara zone, or both.

TransÉnergie–New York Interface

Thermal transfer limits between TransÉnergie (Hydro-Quebec) and New York are not analyzed as part of this study. Respecting the NYSRC and NYISO operating reserve requirements, the maximum allowable delivery into the NYCA from TransÉnergie on the Chateauguay – Massena (MSC-7040) 765 kV tie is 1310 MW. However in real-time the total flow is limited to 1800 MW; the additional flow is a “wheel-through” transaction to another Balancing Authority Area. Maximum delivery from NYCA to Quebec on the 7040 line is 1000 MW.

The Dennison Scheduled Line represents a 115 kV dual-circuit transmission line that interconnects the New York Control Area to the Hydro-Quebec Control Area at the Dennison Substation, near Massena, NY. The Dennison Line has a nominal north to south capacity of 279 MW in winter, into New York, and a nominal south to north capacity of 200 MW into Quebec. The south to north capacity will be limited to 100 MW into Quebec until such time as the HQ-Cedars Export Study report is approved by the Operating Committee and conditions outline in the report are satisfied.

SUMMARY OF RESULTS – THERMAL TRANSFER LIMIT ANALYSIS

Table 1 – NYISO CROSS STATE INTERFACE THERMAL TRANSFER LIMITS

- Table 1.a
 - Dysinger East
 - West Central Reverse
 - UPNY – SENY
 - UPNY – ConEd
 - Sprain Brook – Dunwoodie So.
 - ConEd – LIPA Transfer Capability
- Table 1.b – MSC-7040 Flow Sensitivity
 - Central East
 - Total East
 - Moses South

Table 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS

- Northport-Norwalk Flow Sensitivity
- Cricket Valley Energy Center I/S and O/S

Table 2.b – ISO-NE to NYISO INTERFACE THERMAL TRANSFER LIMITS

- Northport-Norwalk Flow Sensitivity
- Cricket Valley Energy Center I/S and O/S

Table 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS

- 3-115 kV Ties I/S and O/S
- Hudson – Farragut (B3402) 345 kV and Marion – Farragut (C3403) 345 kV lines and associated PARs I/S and O/S

Table 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS

- 3-115 kV Ties I/S and O/S
- Hudson – Farragut (B3402) 345 kV and Marion – Farragut (C3403) 345 kV lines and associated PARs I/S and O/S

Table 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS

Table 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS

TABLE 1.a – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2025-26

ALL LINES IN-SERVICE

	Dysinger East	West Central Reverse	UPNY - ConEd	UPNY - SENY	Sprain Brook Dunwoodie - So.	ConEd - LIPA
NORMAL	2050 MW (1)	2025 MW (3)	7275 MW (5)	4725 MW (5)	4025 MW (7)	1025 MW (9)
EMERGENCY	2125 MW (2)	2750 MW (4)	8800 MW (6)	6250 MW (6)	4175 MW (8)	1425 MW (10)

	LIMITING ELEMENT	RATING		LIMITING CONTINGENCY	
(1)	Niagara – Dysinger (ND1) 345 kV	@LTE ₃	1745 MW	L/O	Niagara – Dysinger (ND2) 345 kV
(2)	Niagara – Dysinger (ND1) 345 kV	@STE	1793 MW	L/O	Niagara – Dysinger (ND2) 345 kV
(3)	Clay – Pannell (1) 345 kV	@LTE	1410 MW	L/O	Clay – Pannell (2) 345 kV Clay – Edic (2-15) 345 kV
(4)	Clay – Pannell (2) 345 kV	@STE	1792 MW	L/O	Pannell – Clay (1) 345 kV
(5)	Lovett – Buchanan (Y88) 345 kV	@LTE	2015 MW	L/O	Buchanan – Ramapo (Y94) 345 kV
(6)	Coopers Corner –Middletown Tap (CCRT34) 345 kV	@STE	1792 MW	L/O	Dolson Ave – Rock Tavern (DART44) 345 kV
(7)	Dunwoodie – Mott Haven (71) 345 kV	@MTE ₁	1083 MW	L/O	Dunwoodie – Mott Haven (72) 345 kV
(8)	Dunwoodie – Mott Haven (71) 345 kV	@NORM	741 MW		Pre-Contingency Loading
(9)	Dunwoodie – Shore Rd. (Y50) 345 kV	@LTE	977 MW ₂	L/O	Sprainbrook – East Garden City (Y49) 345kV Sprainbrook – Academy (M29) 345 kV
(10)	Newbridge – Locust Grove (558) 138 kV	@NORM	354 MW		Pre-Contingency Loading

Note

- 1: The rating used for cable circuits during SCUC reliability analysis is the average of the LTE and STE rating (MTE Rating).
- 2: LIPA rating for Y50 circuit is based on 70 % loss factor and rapid oil circulation.
- 3: The Dysinger – E. Stolle PAR controller schedule has direct impact on the Dysinger East limit.

TABLE 1.b – NYISO CROSS-STATE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2025-26
ALL LINES IN-SERVICE

	7040 FLOW HQ->NY 600 MW	7040 FLOW 0 MW	7040 FLOW NY->HQ 600 MW
<i>Central East</i>			
NORMAL	4325 MW (1)	4325 MW (1)	4325 MW (1)
EMERGENCY	5525 MW (2)	5475 MW (2)	5375 MW (2)
<i>Total East</i>			
NORMAL	5850 MW (3)	5825 MW (3)	5800 MW (3)
EMERGENCY	6225 MW (4)	6200 MW (4)	6175 MW (4)
<i>Moses South</i>			
NORMAL	1925 MW (5)	1925 MW (5)	1750 MW (5)
EMERGENCY	3150 MW (6)	2900 MW (7)	2800 MW (8)

ID	LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1)	New Scotland – Princetown (55) 345 kV	@LTE 1781 MW	L/O Princetown – New Scotland (361) 345 kV Princetown – New Scotland (362) 345 kV
(2)	Fraser – Cooper’s Corner (33) 345 kV	@STE 1793 MW	L/O Marcy – Cooper’s Corner (UCC2-41) 345 kV
(3)	Roseton – East Fishkill (RFK305)	@LTE 2772 MW	L/O Lovett – Buchanan (Y88) 345 kV Ramapo – Buchanan (Y94) 345 kV
(4)	Coopers Corners – Middletown TAP (CCRT34) 345 kV	@STE 1792 MW	L/O Dolson Ave – Rock Tavern (DART44) 345 kV
(5)	Moses – Haverstock (MH3) 230 kV	@LTE 500 MW	L/O Moses – Haverstock (MH1) 230 kV Moses – Haverstock (MH2) 230 kV
(6)	Moses – Haverstock (MH1) 230 kV	@NORM 434 MW	Pre-Contingency Loading
(7)	Browns Falls – Taylorville (1) 115 kV	@STE 159 MW	L/O Browns Falls – Taylorville (2) 115 kV
(8)	Moses – Massena (MMS1) 230 kV	@NORM 936 MW	Pre-Contingency Loading

Note

- 1: Moses South limit used the NYSRC Rules Exception No. 10 – Post Contingency Flows on Marcy AT1 Transformer
- 2: Moses South limit used the NYSRC Rules Exception No. 12 – Post Contingency Flows on Marcy AT2 Transformer

TABLE 2.a – NYISO to ISO-NE INTERFACE THERMAL TRANSFER LIMITS - WINTER 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY	DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY
Cricket Valley Energy Center Out of Service			Cricket Valley Energy Center in Service (1105 MW)			

Northport – Norwalk 0MW

NORMAL	2400 MW (1)	3350 MW (3)	1825 MW (5)	2375 MW (1)	3400 MW (3)	1800 MW (5)
EMERGENCY	2450 MW (2)	3425 MW (4)	2375 MW (6)	2400 MW (2)	3450 MW (4)	2375 MW (6)

Northport – Norwalk 100MW

NORMAL	2400 MW (1)	3350 MW (3)	1825 MW (5)	2375 MW (1)	3400 MW (3)	1800 MW (5)
EMERGENCY	2450 MW (2)	3425 MW (4)	2375 MW (6)	2400 MW (2)	3450 MW (4)	2375 MW (6)

Northport – Norwalk 200 MW

NORMAL	2400 MW (1)	3350 MW (3)	1825 MW (5)	2375 MW (1)	3400 MW (3)	1800 MW (5)
EMERGENCY	2450 MW (2)	3425 MW (4)	2375 MW (6)	2400 MW (2)	3450 MW (4)	2375 MW (6)

	LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1)	Alps – Berkshire (393) 345 kV	@LTE 1883 MW	L/O Seabrook (G1) 25 kV (1309 MW)
(2)	Alps – Berkshire (393) 345 kV	@STE 1912 MW	L/O Seabrook (G1) 25 kV (1309 MW)
(3)	Reynolds Road 115/345 kV Transformer	@STE 699 MW	L/O Pleasant Valley – Knickerbocker (Y57) 345 kV Alps – Knickerbocker (6) 345 kV
(4)	North Troy – Hoosick (5) 115 kV	@STE 317 MW	L/O Alps – Berkshire (393) 345 kV
(5)	Berkshire – Northfield Mtn. (312) 345 kV	@LTE 1345 MW	L/O Seabrook (G1) 25 kV (1309 MW)
(6)	Berkshire – Northfield Mtn. (312) 345 kV	@NORM 1345 MW	Pre-Contingency Loading

NOTE

- 1: The Northport – Norwalk Harbor (NNC) flow is positive in the direction of transfer
- 2: The Northport – Norwalk Harbor (NNC) line is no longer part of the New York – New England Interface Definition

TABLE 2.b – ISO-NE to NYISO INTERFACE THERMAL LIMITS - WINTER 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY	DIRECT TIE	NYISO FACILITY	ISO-NE FACILITY
Cricket Valley Energy Center Out of Service				Cricket Valley Energy Center in Service (1105 MW)		

Norwalk –Northport @ 0 MW

NORMAL	2075 MW (1)	1425 MW (3)	2375 MW (6)	1750 MW (1)	1525 MW (3)	2425 MW (8)
EMERGENCY	2225 MW (2)	1425 MW (3)	2475 MW (7)	1900 MW (2)	1525 MW (3)	2425 MW (8)

Norwalk –Northport @ 100 MW

NORMAL	2075 MW (1)	1425 MW (3)	2375 MW (6)	1750 MW (1)	1525 MW (3)	2425 MW (8)
EMERGENCY	2225 MW (2)	1425 MW (3)	2475 MW (7)	1900 MW (2)	1525 MW (3)	2425 MW (8)

Norwalk–Northport @ 200 MW

NORMAL	2075 MW (1)	1425 MW (3)	2375 MW (6)	1750 MW (1)	1525 MW (3)	2425 MW (8)
EMERGENCY	2225 MW (2)	1425 MW (3)	2475 MW (7)	1900 MW (2)	1525 MW (3)	2425 MW (8)

	LIMITING ELEMENT	RATING	LIMITING CONTINGENCY
(1)	Eastover – Bear Swamp (E205W) 230 kV	@LTE 586 MW	L/O Alps – Berkshire (393) 345 kV
(2)	Eastover – Bear Swamp (E205W) 230 kV	@STE 634 MW	L/O Alps – Berkshire (393) 345 kV
(3)	Reynolds Road 345/115 kV Transformer	@STE 699 MW	L/O Knickerbocker – Alps (6) 345 kV
(4)	Cricket Valley – Long Mountain (398) 345 kV	@NORM 1533 MW	Pre-Contingency Loading
(5)	Northport – Norwalk Harbor (NNC) 138 kV	@STE 569 MW	L/O Long Mountain – Cricket Valley (398) 345 kV Cricket Valley GT3&ST3
(6)	Northfield – Berkshire (312) 345 kV	@LTE 1345 MW	L/O Dover – Long Mountain (398) 345 kV
(7)	Berkshire 345/115 kV Transformer	@NORM 598 MW	L/O Northfield – Berkshire (312) 345 kV
(8)	Bear Swamp – Adams (E131) 115 KV	@NORM 529 MW	L/O Bear Swamp – Eastover Road (E205W) 230 kV

NOTE

- 1: The Northport – Norwalk Harbor (NNC) flow is positive in the direction of transfer
- 2: The Northport – Norwalk Harbor (NNC) line is no longer part of the New England – New York Interface Definition

TABLE 3.a – NYISO to PJM INTERFACE THERMAL TRANSFER LIMITS - WINTER 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY	PJM FACILITY	DIRECT TIE	NYISO FACILITY	PJM FACILITY
B&C PARs In-Service			B&C PARs Out-Of-Service			
NORMAL	2100 MW (1)	2500 MW (3)	3125 MW (4)	1875 MW (1)	2250 MW (3)	2900 MW (4)
EMERGENCY	2125 MW (2)	2500 MW (3)	3125 MW (4)	1900 MW (2)	2250 MW (3)	2900 MW (4)
3 x 115 kV Lines Out-of-Service						
NORMAL	2675 MW (5)	2650 MW (7)	3350 MW (9)	2450 MW (5)	2425 MW (7)	2775 MW (9)
EMERGENCY	2875 MW (6)	3475 MW (8)	3675 MW (11)	2650 MW (6)	2825 MW (8)	3425 MW (11)

	LIMITING ELEMENT	RATING		LIMITING CONTINGENCY
(1)	East Sayre – North Waverly (956) 115 kV	@STE 127 MW	L/O	East Towanda – Hillside (70) 230 kV Hillside 230/69 kV Transformer
(2)	East Sayre – North Waverly (956) 115 kV	@STE 127 MW	L/O	East Towanda – Hillside (70) 230 kV
(3)	Oakdale – Westover (939) 115 kV	@STE 352 MW	L/O	Watercure – Oakdale (31) 345 kV
(4)	Tiffany – Laurel Lake 115 kV	@NORM 151 MW		Pre-Contingency Loading
(5)	East Towanda – Hillside (70) 230 kV	@LTE 594 MW	L/O	Mainesburg – Watercure (30) 345 kV
(6)	East Towanda – Hillside (70) 230 kV	@STE 670 MW	L/O	Mainesburg – Watercure (30) 345 kV
(7)	Oakdale Transformer (BK2) 345kV/115kV	@LTE 557 MW	L/O	Oakdale – Watercure (31) 345kV Oakdale 3-Winding (BK3) 345/115/34.5kV
(8)	Oakdale – Watercure (31) 345 kV	@NORM 717 MW		Pre-Contingency Loading
(9)	Ridgeway – Farmer Valley 115 kV	@STE 160 MW	L/O	Glade – Warren (2088) 230 kV Warren 230/115 kV Transformer Glade – Forest (FOR-GLA1) 230 kV Glade – Lewis (GLA-LEW1) 230 kV Glade – Seneca (2017) 230 kV
(11)	S. Troy – Evert Drive 115 kV	@STE 310 MW	L/O	Hillside – East Towanda (70) 230 kV

NOTE

- 1: Emergency Transfer Capability Limits may have required line outages as described in the New York - PJM Analysis section.
- 2: PAR schedules have been adjusted in the direction of transfer.
- 3: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets (typically 115 kV)

TABLE 3.b – PJM to NYISO INTERFACE THERMAL TRANSFER LIMITS – Winter 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY	PJM FACILITY	DIRECT TIE	NYISO FACILITY	PJM FACILITY
B&C PARs In-Service			B&C PARs Out-Of-Service			
NORMAL	1850 MW (1)	2600 MW (2)	2800 MW (3)	1775 MW (1)	2500 MW (2)	2700 MW (3)
EMERGENCY	2800 MW (4)	2900 MW (6)	3075 MW (7)	2725 MW (4)	2950 MW (6)	2975 MW (7)
3 x 115 kV Lines Out-of-Service						
NORMAL	2525 MW (5)	2725 MW (8)	3600 MW (11)	2400 MW (5)	2600 MW (8)	3475 MW (11)
EMERGENCY	2725 MW (10)	2975 MW (9)	3600 MW (11)	2600 MW (10)	2850 MW (9)	3475 MW (11)

	LIMITING ELEMENT	RATING		LIMITING CONTINGENCY
(1)	North Waverly – East Sayre (956) 115 kV	@STE 127 MW	L/O	Hillside – East Towanda (70) 230 kV Hillside – Watercure (69) 230 kV Hillside 230/115 kV Transformer
(2)	North Waverly – Lounsberry (962) 115 kV	@STE 167 MW	L/O	Watercure – Oakdale (31) 345 kV Clarks Corners – Oakdale (36) 345kV
(3)	Towanda – East Sayre 115 kV	@STE 291 MW	L/O	Hillside – East Towanda (70) 230 kV Hillside – Watercure (69) 230 kV Hillside 230/115 kV Transformer
(4)	East Sayre – North Waverly 115 kV	@NORM 127 MW		Pre-Contingency Loading
(5)	Hillside – East Towanda (70) 230 kV	@LTE 594 MW	L/O	Watercure – Mainseburg (30) 345 kV
(6)	North Waverly – Lounsberry (962) 115 kV	@STE 167 MW	L/O	Watercure – Oakdale (31) 345 kV
(7)	Lenox – North Meshoppen 115 kV	@STE 205 MW	L/O	Hillside – East Towanda (70) 230 kV
(8)	Hillside – North Waverly (962) 115 kV	@STE 155 MW	L/O	Oakdale – Clarks Corners (36) 345 kV Watercure – Oakdale (31) 345 kV
(9)	Gridle Rd. – Stolle Rd. (706) 115 kV	@STE 239 MW	L/O	Five Mile (BK1) 345/115kV Transformer
(10)	Hillside – East Towanda (70) 230 kV	@STE 670 MW	L/O	Watercure – Mainseburg (30) 115kV
(11)	Everett Drive – Mainseburg 115 kV	@STE 307 MW	L/O	Hillside – East Towanda (70) 230 kV

NOTE

- 1: Emergency Transfer Capability Limits may have required line outages as described in New York – PJM Analysis Section.
- 2: PAR schedules have been adjusted in the direction of transfer.
- 3: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets.

TABLE 4 – IESO to NYISO INTERFACE THERMAL TRANSFER LIMITS - WINTER 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY_{1,2}	IESO FACILITY
NORMAL	2500 MW (1)	3375 MW (3)	4900 MW (4)
EMERGENCY	3100 MW (2)	3375 MW (3)	4900 MW (4)

	LIMITING ELEMENT	RATING			LIMITING CONTINGENCY
(1)	Beck - Niagara (PA27) 230 kV	@LTE	540 MW	L/O	Beck - Niagara (PA301) 345 kV
(2)	Beck - Niagara (PA27) 230 kV	@STE	685 MW	L/O	Beck - Niagara (PA301) 345 kV
(3)	Lockport – Hinman (100) 115 kV	@STE	317 MW	L/O	Robinson – Stolle Road (65) 230 kV
(4)	Middleport 220/500 kV Transformer	@NORM	823 MW		Pre-Contingency Loading

Note

- 1: Ontario - NYISO limit used the NYSRC Rules Exception No. 13 – Post Contingency Flows on Niagara Project Facilities
- 2: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets

TABLE 5 – NYISO to IESO INTERFACE THERMAL TRANSFER LIMITS – WINTER 2025-26
ALL LINES IN-SERVICE

	DIRECT TIE	NYISO FACILITY^{2,3}	IESO FACILITY
NORMAL	1875 MW (1)	4775 MW (3)	1825 MW (4)
EMERGENCY	2250 MW (2)	4775 MW (3)	1825 MW (4)

	LIMITING ELEMENT	RATING		LIMITING CONTINGENCY
(1)	Beck – Niagara (PA27) 230 kV	@LTE 540 MW	L/O	Beck - Niagara (PA301) 345 kV
(2)	Beck – Niagara (PA27) 230 kV	@NORM 480 MW		Pre-Contingency Loading
(3)	Stolle Road – Girdle Road (927) 115 kV	@STE 239 MW	L/O	Stolle Road – Sheldon (67) 230 kV
(4)	Beck – Hannon (Q24) 220 kV	@NORM 501 MW		Pre-Contingency Loading

Note

- 1: This limit can be increased by reducing generation or increasing demand in the Niagara zone of Ontario contingent on water and tourism regulations. See Ontario – New York Analysis for discussion.
- 2: Internal Non-Secured Limit: Limit to secure internal transmission elements that are not secured with pricing in the NYISO markets.
- 3: This limit can be increased by adjusting the PAR schedule on the Dysinger – East Stolle Rd (DES-1) 345 kV line, reducing the flows into East Stolle Rd. 345 kV substation.