



# **UPNY-ConEd Voltage Collapse Transfer Limits**

A Report by the Operations Engineering Staff  
New York Independent System Operator

**October 2024**

## Executive Summary

In light of the new Lovett 345 kV station, the NYISO deemed it appropriate to conduct a study of area voltage performance, including the investigation of voltage collapse transfer limits, for the UPNY-ConEd operating interface. This report presents the methodology, analysis and results of this study.

The voltage collapse limits currently in use for the UPNY-ConEd interface were developed and approved in 2023. This study re-evaluates these limits to maintain reliable operation of the bulk power system. New derates were developed to account for new transmission related to Lovett 345 kV station.

This study shows no change in voltage collapse limits except for a slight decrease in the Y88 limits as a result of the new station bisecting the line. Analysis also shows that no adjustments to pre-contingency low voltage limits are necessary.

## Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>2</b>
<b>TABLE OF CONTENTS .....</b>	<b>3</b>
<b>LIST OF FIGURES .....</b>	<b>4</b>
<b>INTRODUCTION .....</b>	<b>5</b>
<b>RECOMMENDATIONS.....</b>	<b>5</b>
<b>DISCUSSION .....</b>	<b>9</b>
System Representation and Base Study Assumptions.....	9
Study Criteria .....	10
Study Methodology.....	11
UPNY-ConEd Interface Definition .....	12
Transfer Case Development.....	13
Voltage Contingency Evaluation .....	14
Configuration Modeling.....	15
Monitored Buses .....	16
Results .....	17

# List of Figures

Figure 1: UPNY-ConEd Voltage Collapse Limits for 2024.....	6
Figure 2: Comparison of 2023 and 2024 Limits (SB/Dun SR Bypassed and SB-EGC/Gow SR I/S).....	7
Figure 3: Comparison of 2023 and 2024 Limits (SB-EGC/Gow SR Bypassed and SB/Dun SR I/S).....	8
Figure 4: Status of ConEd Series Reactors .....	9
Figure 5: UPNY-ConEd Interface Definition .....	12
Figure 6: NYISO Transmission System.....	12
Figure 7: Contingencies Studied .....	14
Figure 8: Configuration Modeling .....	15
Figure 9: Sample Post-Contingency Flows Chart .....	17
Figure 10: Sample Pre-Contingency Flows by Post Contingency Voltages .....	18
Figure 11: Sample Tabular Voltage Collapse Limits .....	18

## Introduction

The purpose of this study is to evaluate the UPNY-ConEd Voltage Collapse Transfer Limits for all-lines-in-service and significant equipment outage conditions expected for the system configuration for the Winter 2024 season and beyond. This analysis was conducted using the NYISO Summer 2024 Operating Study base case. Details of base case development are included in this report.

This report documents the results of the analysis and provides recommendations based on the simulation results for operating criteria contingencies. Tables of the recommended derates, the contingencies evaluated, examples of power-voltage (PV) plots and summaries of the transfer base case conditions are included.

“FAC-011-4\_Methodology for Establishing SOL for the Operations Horizon\_20240401”, documented the methodology employed to develop System Operating Limits (SOLs) within the NYISO Reliability Coordinator Area. NYSRC Reliability Rules require compliance with all North American Electric Reliability Corporation (NERC) Standards and Northeast Power Coordinating Council (NPCC) Standards and Criteria. NYSRC Rule C.1, Establishing Operating Transfer Capabilities, addresses the contingencies to be evaluated and the performance requirements to be applied. Rule C.1 also references NYISO Bus Voltage Limits as found in Tables A.2 and A.3 of the NYISO Emergency Operations Manual. The applicable process for establishing voltage collapse limits is established by the “Guideline for Voltage Analysis and Determination of Voltage-Based Transfer Limits” found in the NYISO “Transmission Expansion and Interconnection Manual” Attachment G.

## Recommendations

It is recommended that the limits presented in Figure 1 below be employed to secure the bulk power system for the applicable system conditions identified in this study. Figure 1 shows the breakdown of the UPNY-ConEd Voltage Collapse Transfer Limit components. Tables showing the changes in limits can be found in the Discussion section. Figures 2 and 3 below show the changes between the new proposed limits and those approved in 2023.

The results of the study also showed that no changes are needed for pre-contingency low voltage limits, given the recommended establishment of the UPNY-ConEd interface voltage collapse limits.

Figure 1: UPNY-ConEd Voltage Collapse Limits for 2024

UPNY-ConEd Voltage Collapse Transfer Limits*			
Equipment Status		Voltage (kV)	Limit (MW)
		w/ SB/Dun SR Bypassed and SB-EGC/Gow SR I/S	w/ SB/Dun SR I/S and SB-EGC/Gow SR Bypassed
All Equipment I/S		8050	7700
1 Bowline I/S		-	7715
0 Bowline I/S		-	7355
1 Roseton I/S		-	7830
0 Roseton I/S		-	7460
0 Danskammer I/S		-	7820
2 Cricket Valley I/S		-	7860
1 Cricket Valley I/S		-	7795
0 Cricket Valley I/S		-	7630
Millwood Caps (2 O/S)		345	7960
E. Fishkill Caps (2 O/S)		345	8050
Van Wagner Caps (2 O/S)		345	8050
Hopatcong-Ramapo 5018 O/S		500	7795
Knickerbocker-Pleasant Valley Y57 O/S		345	7885
Knickerbocker Series Compensation @ 0%, 17%, 33%		345	8050
Leeds-Hurley 301 O/S		345	8050
Leeds-Hurley Smart Wire Bypassed		345	8050
Ladentown-Lovett Y66 O/S		345	7665*
Lovett-Buchanan S. Y88 O/S		345	<b>7575*</b>
Lovett 345/138 XFRM O/S		345/138	8050*
Y66 & Y88 O/S		345	7525*
Ramapo-Buchanan N. Y94 O/S		345	7755
Roseton-E.Fishkill RFK-305 O/S		345	7215
Millwood W.-Eastview W99 (or W85 or W82) O/S		345	7810
Buchanan S.-Millwood W. W97 (or W98) O/S		345	8015
Wood St.-Pleasantville Y86 O/S		345	7475
Wood St.-Pleasantville Y87 O/S		345	7470

\*Some Limits were additionally reduced to accommodate implementation in the NYISO Energy

Management System.

**Figure 2: Comparison of 2023 and 2024 Limits (SB/Dun SR Bypassed and SB-EGC/Gow SR I/S)**

<b>Comparison of 2023 and 2024 UPNY-ConEd Voltage Collapse Limits (SB/Dun SR Bypassed and SB-EGC/Gow SR In-Service)</b>			
<b>Equipment Status</b>	<b>2023 Limit (MW)</b>	<b>2024 Limit (MW)</b>	<b>Difference (MW)</b>
All Equipment I/S	8050	8050	0
1 Bowline I/S	7715	7715	0
0 Bowline I/S	7355	7355	0
1 Roseton I/S	7830	7830	0
0 Roseton I/S	7460	7460	0
0 Danskammer I/S	7820	7820	0
2 Cricket Valley I/S	7860	7860	0
1 Cricket Valley I/S	7795	7795	0
0 Cricket Valley I/S	7630	7630	0
Millwood Caps (2 O/S)	7960	7960	0
E. Fishkill Caps (2 O/S)	8050	8050	0
Van Wagner Caps (2 O/S)	8050	8050	0
Hopatcong-Ramapo 5018 O/S	7795	7795	0
Knickerbocker-Pleasant Valley Y57 O/S	7885	7885	0
Knickerbocker Series Compensation @ 0%, 17%, 33%	8050	8050	0
Leeds-Hurley 301 O/S	8050	8050	0
Leeds-Hurley Smart Wire Bypassed	8050	8050	0
Ladentown-Lovett Y66 O/S	-	7665	New Limit
Lovett-Buchanan S. Y88 O/S	7695	7575	-120
Lovett 345/138 XFRM O/S	-	8050	New Limit
Y66 & Y88 O/S	-	7525	New Limit
Ramapo-Buchanan N. Y94 O/S	7755	7755	0
Roseton-E.Fishkill RFK-305 O/S	7215	7215	0
Millwood W.-Eastview W99 (or W85 or W82) O/S	7810	7810	0
Buchanan S.-Millwood W. W97 (or W98) O/S	8015	8015	0
Wood St.-Pleasantville Y86 O/S	7475	7475	0
Wood St.-Pleasantville Y87 O/S	7470	7470	0

Figure 3: Comparison of 2023 and 2024 Limits (SB/Dun SR I/S and SB-EGC/Gow SR Bypassed)

Comparison of 2023 and 2024 UPNY-ConEd Voltage Collapse Limits (SB/Dun SR I/S and SB-EGC/Gow SR Bypassed)			
Equipment Status	2023 Limit (MW)	2024 Limit (MW)	Difference (MW)
All Equipment I/S	7700	7700	0
1 Bowline I/S	7365	7365	0
0 Bowline I/S	7005	7005	0
1 Roseton I/S	7480	7480	0
0 Roseton I/S	7110	7110	0
0 Danskammer I/S	7470	7470	0
2 Cricket Valley I/S	7510	7510	0
1 Cricket Valley I/S	7445	7445	0
0 Cricket Valley I/S	7280	7280	0
Millwood Caps (2 O/S)	7610	7610	0
E. Fishkill Caps (2 O/S)	7700	7700	0
Van Wagner Caps (2 O/S)	7700	7700	0
Hopatcong-Ramapo 5018 O/S	7445	7445	0
Knickerbocker-Pleasant Valley Y57 O/S	7535	7535	0
Knickerbocker Series Compensation @ 0%, 17%, 33%	7700	7700	0
Leeds-Hurley 301 O/S	7700	7700	0
Leeds-Hurley Smart Wire Bypassed	7700	7700	0
Ladentown-Lovett Y66 O/S	-	7320	New Limit
Lovett-Buchanan S. Y88 O/S	7250	7200	-50
Lovett 345/138 XFRM O/S	-	7695	New Limit
Y66 & Y88 O/S	-	7175	New Limit
Ramapo-Buchanan N. Y94 O/S	7195	7195	0
Roseton-E.Fishkill RFK-305 O/S	6865	6865	0
Millwood W.-Eastview W99 (or W85 or W82) O/S	7460	7460	0
Buchanan S.-Millwood W. W97 (or W98) O/S	7665	7665	0
Wood St.-Pleasantville Y86 O/S	7125	7125	0
Wood St.-Pleasantville Y87 O/S	7120	7120	0



## Discussion

### System Representation and Base Study Assumptions

The study was conducted using the 2024 NYISO Summer Peak Operating Study Base Case with a NYISO forecasted summer coincident peak load of 31,541 MW, and a GHIJ load of 15,008 MW. This base case was selected as the most recently reviewed case available.

The initial base case is modeled as an all-lines-in-service representation with all generation in-service, with both the new Knickerbocker Series Compensation at full 50% compensation, and the new Leeds-Hurley Smart Wire Smart Valve at full 100% series compensation mode.

To create transfers to stress the UPNY-ConEd interface, significant generation in the NYC zone needed to be shut off. As is typical dispatch, oil fueled units were shutoff before gas fueled units. The Ravenswood 3 generating station was modeled in-service as this is tested as the largest single source generating contingency.

Two versions of the base case were created, representing the Sprain Brook/Dunwoodie Series Reactors in- and out-of- service. The Sprain Brook/Dunwoodie Series Reactors refer to the M51 and M52 series reactors at Sprain Brook and the 71 and 72 series reactors at Dunwoodie. When these series reactors are bypassed, the Y49 series reactor at Sprain Brook and the 41 and 42 series reactors at Gowanus must be in-service. Conversely, the Y49, 41 and 42 reactors must be bypassed when the M51/M52/71/72 reactors are in-service. Figure 4 below shows the status of the series reactors in each scenario.

**Figure 4: Status of ConEd Series Reactors**

Equipment Name	Sprain Brook / Dunwoodie Base Case	
	Series Reactors Bypassed	Series Reactors In-Service
Sprain Brook M51 & M52	Bypassed	In-Service
Dunwoodie 71 & 72	Bypassed	In-Service
Sprain Brook Y49	In-Service	Bypassed
Gowanus 41 & 42	In-Service	Bypassed

- The initial base case dispatch real power transfers were adjusted to stress conditions through: Ontario generation set to attain an import of ~1530 MW
- 7040 flow set to 1,300 MW import from Hydro-Québec

- 0 MW import on Cedars-Dennison
- Sandbar PAR set to achieve 100 MW flow on PV20
- Ontario-Michigan PARS set to maintain Lake Erie circulation near zero
- Flows across Dysinger-East, Moses-South, and Central East interfaces stressed to 930, 1,790, and 2860 MW respectively.

To ensure utilization of available reactive resources, the following actions were taken:

- All capacitors in-service were switched in.
- All generator terminal voltages were set to local control, between .95 and 1.05.
- Assorted Generator and LTC control parameters were adjusted to maintain all bulk power buses within historic operating voltage ranges.
- Oswego area 345 kV stations (Fitzpatrick, Scriba, Oswego 5 and 6) modeled to typical voltages which can exceed 1.06 p.u.
- Marcy-South Series Capacitors were modeled in-service

Updates to the base case included the new Lovett 345 kV station, and the new connected lines:

- Lovett 345 kV station bisects the existing Ladentown – Buchanan South (Y88) 345 kV line
- Lovett 345/138 kV transformer
- Ladentown – Lovett (Y66) 345 kV line
- Lovett – Buchanan S. (Y88) 345 kV line

### **Study Criteria**

This analysis was conducted in accordance with the “FAC-011-4\_Methodology for Establishing SOL for the Operations Horizon\_20240401” which encompasses the “NYSRC Reliability Rules, Standards for Planning and Operation the New York ISO Bulk Power System” and “NPCC Regional Reliability Reference Directory # 1 Design and Operation of the Bulk Power System”.

The NYISO Transmission Expansion and Interconnection Manual, Attachment G: NYISO Transmission Planning Guideline #2-1 "Guideline for Voltage Analysis and Determination of Voltage-Based Transfer Limits" describes the methodology employed to determine voltage transfer limits.

A pre-contingency kV limit is determined when the post-contingency voltages falls below the post-

contingency low voltage limit. In this analysis the pre-contingency low voltages were recorded at the highest transfer at which the post-contingency low solved voltage reached the defined post-contingency low limit. The NYISO post-contingency low voltages employed in the analysis are found in the NYISO Emergency Operations Manual, Attachment A, Table A-2 "NYISO Voltage Limits".

### **Study Methodology**

The Voltage Contingency Analysis Procedure (VCAP) is used to evaluate the steady state voltage performance of the power system for a series of power flow transfer conditions. A transmission interface in the vicinity of the area of the system to be studied is tested by preparing a series of power flow base cases with increasing MW transfer levels across that interface. The pre-contingency cases are then subjected to the most severe voltage contingencies for the area involved. The post-contingency cases are then reviewed for voltage performance at each of the monitored buses to best determine reactive conditions and develop guidelines for the operation of the system.

The basic principle employed is to develop a set of power transfer vs. voltage (PV) curves through the VCAP application. These PV curves are developed by progressively increasing transfers across UPNY-ConEd interface and recording the post contingency voltage for severe contingencies. Two potential limits are obtained through examination of the PV curves. A post-contingency voltage transfer limit is defined when the post contingency voltage crosses the predefined post contingency low voltage limit. A voltage collapse transfer limit is defined by identifying the highest transfer where post contingency power flow stopped increasing, also called the "knee" of the post contingent flow curve, and then applying a 5% margin. The voltage collapse transfer limit is then compared to that transfer level obtained by applying the applicable post-contingency low voltage limit. To ensure that a voltage-based transfer limit is determined with a safe margin, the lower of the two power transfer levels from the foregoing comparison is to be selected as the interface transfer limit.

A key level of conservatism in the development of voltage transfer limits developed for operations is all analysis is conducted under peak load conditions. This is conservative for two reasons. First, it is the highest end user reactive load condition, and thereby consumes the greatest amount of innate and controllable reactive resources at the point of delivery to the end user. Secondly, the delivery of power to the end user under peak load results in the highest-level reactive transmission losses across the system. Under anything less than peak load conditions, additional reactive resources are available to the system.


## UPNY-ConEd Interface Definition

The UPNY-ConEd interface definition is given below in Figure 5 and illustrated in Figure 6.

**Figure 5: UPNY-ConEd Interface Definition**

UPNY-ConEd			
Hudson Valley (Zone G) - Millwood (Zone H)			
Name	Line ID	Voltage (kV)	
*Lovett-Buchanan South	Y88	345	
*Pleasant Valley-Wood S	F30	345	
*Pleasant Valley-Wood St	F31	345	
*Pleasant Valley-East Fishkill	F36	345	
*Pleasant Valley-East Fishkill	F37	345	
*Ramapo-Buchanan North	Y94	345	
Roseton-East Fishkill*	RFK305	345	
*Fishkill Plains-Sylvan Lake	FP/990	115	
East Fishkill 115/345*	BK1	115/345	
East Fishkill 115/345*	BK2	115/345	

**Figure 6: NYISO Transmission System**



## Transfer Case Development

Transfer cases were developed by sourcing major generation on the 345 kV backbone in Western, Central, Capital and Hudson Valley zones of New York. Power was sunk to major generation on the 345 kV network in the NYC zone. This was sourced by scaling New England generation as a whole. Central East Voltage Collapse limits were respected to avoid influencing results on UPNY-ConEd. For base transfer conditions the bulk power system voltages were maintained in the .95-1.05 p.u. range. To ensure full utilization of available reactive resources, the following actions were taken:

- All switched shunt capacitors were switched in so long as it did not cause excessively high voltage
- All ConEd category 1 switched shunt reactors were kept in-service.
- ConEd category 2 switched shunt reactors were utilized as necessary to keep voltages within operating limits.
- Generator and LTC voltage control parameters were adjusted to maintain adequate voltages. In some cases, where generator step up transformer ratios warranted, plant voltage settings were set higher than 1.05 p.u.
- 0 MW flow on the A2253 PAR
- The B3402 & C3403 Lines are assumed out-of-service

## Voltage Contingency Evaluation

Figure 7 below lists the contingencies that were evaluated for each configuration studied.

**Figure 7: Contingencies Studied**

ID	Description
log09	LOG09 L/O RAVENSWOOD 3
uc02	UC02 TWR Y86/Y87
uc04a	UC04a SBK BUCHANAN 345
uc18a	UC18a TWR Y66/Y94
uc18b	UC18b TWR Y88/Y94
uc20	UC20 TWR W89/W90
uc21	UC21 TWR 30/31
uc25	UC27 SBK ROCK TAV 345 (44 & 76)
uc27a	UC27a SBK ROCK TAV 345 (77 & CCRT-42)
uc28	UC28 TWR 76/77 new
uc31	UC31 TWR 34/42
uc32	UC32 TWR 34/44
uc33	UC33 TWR W97/W98

## Configuration Modeling

Figure 8 below lists the equipment outages that were modeled and studied. For all configurations the Sprain Brook-Dunwoodie Series Reactors were modeled in-service and bypassed.

**Figure 8: Configuration Modeling**

Equipment Status	ID	Voltage
1 Bowline I/S	-	-
0 Bowline I/S	-	-
1 Roseton I/S	-	-
0 Roseton I/S	-	-
0 Danskammer I/S	-	-
2 Cricket Valley I/S	-	-
1 Cricket Valley I/S	-	-
0 Cricket Valley I/S	-	-
Millwood Caps (2 O/S)	-	345
E. Fishkill Caps (2 O/S)	-	345
Van Wagner Caps (2 O/S)	-	345
Hopatcong-Ramapo O/S	5018	500
Knickerbocker-Pleasant Valley O/S	Y57	345
Knickerbocker Series Compensation @ 0% (both SC bypassed)	RY5714 & RY5715	345
Knickerbocker Series Compensation @ 17% (single SC bypassed)	RY5714	345
Knickerbocker Series Compensation @ 33% (single SC bypassed)	RY5715	345
Leeds-Hurley O/S	301	345
Leeds-Hurley Smart Wire @ 0%	301501 & 301505	345
Ladentown-Lovett O/S	Y66	345
Lovett-Buchanan S. O/S	Y88	345
Lovett 345/138 kV transformer	-	345/138
Ramapo-Buchanan N. O/S	Y94	345
Roseton-E.Fishkill O/S	RFK-305	345
Millwood W.-Eastview O/S	W99/W85/W82	345
Buchanan S.-Millwood W. O/S	W97/W98	345
Wood St.-Pleasantville O/S	Y86	345
Wood St.-Pleasantville O/S	Y87	345

### **Monitored Buses**

All buses in the Emergency Operations Manual A2 Bus List were monitored for pre-contingency and post-contingency low voltage limits.



## Results

The Appendices contain all the tabular results from the 2023 study and 2024 review. Due to the volume of material, the Appendices are a separate document. As an example, the results of the new Lovett-Buchanan S. Y88 O/S with Con Ed Series Reactors bypassed base case analysis are presented here.

Figure 9 below shows the post-contingency flows for the most limiting contingencies for the Lovett-Buchanan S. Y88 O/S with Con Ed Series Reactors bypassed. From this graph the knees of the curves are identified. In this case the most limiting contingency is the loss of Tower W89/W90 (uc20), identified with a black arrow.

**Figure 9: Sample Post-Contingency Flows Chart**

1: S24 UCVC SBDW\_SR\_BYP\_ALI\_Y88\_OS UC7450 Figure 1




Figure 10 below shows the pre-contingency base flow with respect to the post contingency voltage for each of the most limiting contingencies. The graph is marked with at the MW level corresponding to the knee of the curve from the previous post-contingency plot. It is also marked at the MW level of the 5%

margin of this knee. From the graph it is clear that the 5% margin on the knee of the most limiting contingency is more limiting than the post-contingency low voltage limit at Millwood 345kV station.

**Figure 10: Sample Pre-Contingency Flows by Post Contingency Voltages**

1: S24 UCVC SBDW\_SR\_BYP\_ALI\_Y88\_OS UC7450 Figure 1




Figure 11 below shows the limits in tabular form, listing limiting elements in order of increasing pre-contingency UPNY-ConEd flow. The result of every single scenario shows that flows may be limited in real-time operations by pre-contingency low voltage limits.

**Figure 11: Sample Tabular Voltage Collapse Limits**

Limit	<-----FACILITY----->	<---CONTINGENCY--->
7578	limit with 5% margin	TWR W89/W90
7726	limit with 5% margin	TWR Y86/Y87
7859	Millwood 345kV Voltage	TWR W89/W90
7861	Buchanan South 345kV Voltage	TWR W89/W90
7929	limit with 5% margin	Ravenswood 3