

Summary of Modification Requests Deemed Non-Material

Q#746 North Street Energy Storage

Change proposed Commercial Operation Date from March 31, 2024 to February 7, 2025.

Q#959 El Oceanside 2

Change wind turbines from GE turbines to Vesta turbines, including the Developer Attachment Facilities.

Q#1016 El Steinway 1

Move the Point of Interconnection of the project from Astoria West 138kV substation to a new 345kV substation that is interconnected via a loop-in/loop-out of the two existing Mott Haven-Rainey 345kV circuits.

Q#1017 El Steinway 2

Move the Point of Interconnection of the project from Astoria East 138kV substation to a new 345kV substation that is interconnected via a loop-in/loop-out of the two existing Mott Haven-Rainey 345kV circuits.

Q#1180 Union Energy Center

Reduce the project size from 150 MW to 116 MW.

Q#1197 Cold Creek Solar

Move the Point of Interconnection of the project to a different point along the same transmission line, Station 162-Station 180 115kV line (Line#907).

Q#1199 El Steinway 1.1

Reduce the project size from 300 MW to 200 MW and move the Point of Interconnection of the project from Astoria West 138kV substation to a new 345kV substation that is interconnected via a loop-in/loop-out of the two existing Mott Haven-Rainey 345kV circuits.