

**Summary of Modification Requests Deemed Non-Material and No System Impact Study Required  
for a Transmission Project under OATT Section 3.7**

**ConEd Brooklyn Clean Energy Hub**

Build a new 345kV substation between Rainey-Farragut transmission circuits.

**Q#631 NS Power Express and Q#887 CH Uprate**

Reconfigure the Astoria 345kV ring bus from an 8-breaker ring bus to a 6-breaker ring bus.

**Q#1041 Silverline Energy Center**

Reduce the project size from 200 MW to 150 MW and modify the project to a Co-located Storage Resource project consisting of 150 MW solar Generator and 20 MW energy storage Generator.