



# **Short-Term Assessment of Reliability: 2025 Quarter 1**

A Report by the  
New York Independent System Operator

**April 14, 2025**

## Table of Contents

<b>EXECUTIVE SUMMARY .....</b>	<b>4</b>
New York City Reliability Need.....	4
Reliability Assessment .....	6
<b>PURPOSE.....</b>	<b>7</b>
<b>ASSUMPTIONS.....</b>	<b>7</b>
Generation Assumptions .....	8
Generator Deactivation Notices.....	8
Peaker Rule: Ozone Season Oxides of Nitrogen (NOx) Emission Limits for Simple Cycle and Regenerative Combustion Turbines.....	10
Generator Return-to-Service .....	13
Generator Additions.....	13
Demand Assumptions.....	13
Transmission Assumptions.....	18
Existing Transmission.....	18
Proposed Transmission .....	18
<b>FINDINGS.....</b>	<b>19</b>
Resource Adequacy Assessments .....	19
Transmission Security Assessments.....	20
Steady State Assessment.....	22
Dynamics Assessment.....	23
Short Circuit Assessment .....	24
Statewide System Margins .....	24
Transmission Security Margin Assessment.....	26
New York City Transmission Security Margin Baseline .....	27
New York City Transmission Security Margin Sensitivities.....	29
<b>SOLUTIONS TO PREVIOUSLY IDENTIFIED SHORT TERM RELIABILITY NEEDS .....</b>	<b>35</b>
<b>LOCAL NON-BPTF RELIABILITY ASSESSMENT .....</b>	<b>37</b>
<b>CONCLUSIONS AND DETERMINATION .....</b>	<b>39</b>
<b>APPENDIX A: LIST OF SHORT-TERM RELIABILITY NEEDS.....</b>	<b>41</b>
<b>APPENDIX B: SHORT-TERM RELIABILITY PROCESS SOLUTION LIST .....</b>	<b>41</b>
<b>APPENDIX C: SUMMARY OF STUDY ASSUMPTIONS.....</b>	<b>42</b>
Generation Assumptions .....	42

Demand Assumptions.....	45
Transmission Assumptions.....	45
<b>APPENDIX D: RESOURCE ADEQUACY ASSUMPTIONS.....</b>	<b>47</b>
2025 Q1 STAR MARS Assumptions Matrix.....	47
2024 RNA MARS Topology .....	53
<b>APPENDIX E: TRANSMISSION SECURITY MARGIN ASSESSMENT .....</b>	<b>54</b>
Introduction .....	54
Statewide System Margin .....	55
Lower Hudson Valley (Zones G-J) .....	68
New York City (Zone J).....	72
Long Island (Zone K).....	88
<b>APPENDIX F – ADDITIONAL OUTAGE IMPACTS TO MARGINS.....</b>	<b>92</b>

## Executive Summary

This report sets forth the 2025 Quarter 1 Short-Term Assessment of Reliability (“STAR”) findings for the five-year study period of January 15, 2025, through January 15, 2030, considering forecasts of peak power demand, planned upgrades to the transmission system, and changes to the generation mix over the next five years. Included in this STAR is the retirement of Shoreham 2 IC and Madison Windpower. This assessment does not identify any Generator Deactivation Reliability Need following the retirement of these units. No new reliability needs are identified in this STAR.

### New York City Reliability Need

In the 2023 Quarter 2 STAR, the NYISO identified a short-term reliability need beginning in summer 2025 within New York City primarily driven by a combination of forecasted increases in peak demand and the assumed unavailability of certain generation in New York City affected by the “Peaker Rule.”<sup>1</sup> Specifically, the 2023 Quarter 2 STAR identified that the New York City zone is deficient by as much as 446 MW for a duration of nine hours on the peak day during expected weather conditions when accounting for forecasted economic growth and policy-driven increases in demand. After accounting for the updated assumptions in this 2025 Quarter 1 STAR, the New York City zone is deficient by 281 MW for a duration of five hours to as much as 461 MW for a duration of seven hours with high demand. The deficiency may be greater depending on system performance as highlighted by the sensitivities evaluated for this STAR.


On November 20, 2023, following a solicitation for solutions, the NYISO issued a Short-Term Reliability Process Report<sup>2</sup> identifying the temporary and permanent solutions to the identified 2025 New York City need. The NYISO determined that temporarily retaining the peaker generators on the Gowanus 2 & 3 and Narrows 1 & 2 barges is necessary to address the need, and that the permanent solution is the Champlain Hudson Power Express (“CHPE”) connection from Quebec, Canada to New York City, currently scheduled to enter service in spring 2026. With the continued operation of these peakers until the earlier of the date a permanent solution (*i.e.*, CHPE) is in place and demonstrates dependable capacity supply during summer peak conditions or May 2027, the Need for the currently forecasted demand is addressed if CHPE is not delayed beyond 2026, as shown in the following chart. Without the retention of these generators, the New York City area would not meet the mandatory reliability criteria during expected summer weather peak demand periods.

---

<sup>1</sup> In 2019, the New York State Department of Environmental Conservation adopted a regulation to limit nitrogen oxides (NOx) emissions from simple-cycle combustion turbines, referred to as the “Peaker Rule” ([here](#))

<sup>2</sup> <https://www.nyiso.com/documents/20142/39103148/2023-Q2-Short-Term-Reliability-Process-Report.pdf>





The NYISO’s designation of the Gowanus 2 & 3 and Narrows 1 & 2 generators will allow their continued operation beyond May 2025 until permanent solutions are in place, for an initial period of up to two years (May 1, 2027). There is a potential for an additional two-year extension (to May 1, 2029) if reliability needs still exist, as provided by the DEC Peaker Rule. Through the quarterly STAR studies, the NYISO will continuously evaluate the reliability of the system as changes occur and will carefully monitor the progress of the Champlain Hudson Power Express project toward completion.

For this STAR, the NYISO performed sensitivity analyses for the New York City (Zone J) transmission security margin to evaluate the impact of updated forecasts and uncertainties in potential system changes or study assumptions. The following factors were evaluated in the sensitivity analyses: updated Zone J demand forecast, CHPE unavailability, heatwave conditions, accelerated deactivations of the NYPA small plants, unplanned failures or outages of aging fossil fuel generators, and different methods for determining the thermal unit derate factor. Some of the sensitivities show improved reliability margins and some show even further risks. For example, the reduced 2025 summer peak forecast increases the reliability margin by 200 MW, but this increase would be more than offset by uncertainties in the demand forecast or resource availability.

Considering the baseline results in this STAR and the heightened uncertainty of planned system conditions, the NYISO’s designation of the Gowanus 2 & 3 and Narrows 1 & 2 generators to allow their continued operation beyond May 2025 continues to be necessary to address the reliability need identified in the 2023 Quarter 2 STAR. Additionally, Con Edison’s local analysis identifies that until the fourth

Gowanus – Greenwood 345/138 kV PAR controlled feeder is placed into service, scheduled for May 2026, the Narrows and Gowanus generators would be required to remain in service.

### **Reliability Assessment**

In addition to New York City, this assessment also evaluated the transmission security margins for the Lower Hudson Valley and Long Island localities. For these localities, the planned Bulk Power Transmission Facilities (“BPTF”) through the study period are within applicable reliability criteria based on the baseline summer and winter coincident peak demand forecasts with expected weather and with the planned projects meeting their proposed in-service dates. The NYISO assessed the resource adequacy of the overall system and found no resource adequacy reliability needs.

Included in this STAR are the generator deactivation assessments for the retirement of Shoreham 2 IC and Madison Windpower. The NYISO performed a transmission security assessment of the BPTF and identified no new reliability needs during the STAR study period. LIPA performed a deactivation assessment to evaluate the reliability of the local non-BPTF system for the removal of Shoreham 2 IC. Avangrid performed a deactivation assessment to evaluate the reliability of the local non-BPTF system for the removal of Madison Windpower. No generator deactivation needs were identified for the retirement of these units.

The wholesale electricity markets administered by the NYISO are an important tool to help mitigate reliability risks. The markets are designed, and continue to evolve and adapt, to send appropriate price signals for new market entry and the retention of resources that assist in maintaining reliability. The potential risks and resource needs identified in the NYISO’s analyses may be resolved by new capacity resources coming into service, construction of additional transmission facilities, and/or increased energy efficiency and integration of demand-side resources. The NYISO is tracking the progression of many projects that may contribute to grid reliability that have not yet met the inclusion rules for reliability assessments. The NYISO will continue to monitor these resources and other developments to determine whether changing system resources and conditions could impact the reliability of the New York bulk electric grid.

As generators that are subject to the DEC’s Peaker Rule submit their Generator Deactivation Notices, the NYISO and the responsible Transmission Owners will continue to evaluate in future STARS whether Generator Deactivation Reliability Needs arise from the deactivation of Initiating Generators.<sup>3</sup>

---

<sup>3</sup> Per OATT 38.1, an “Initiating Generator” is “a Generator with a nameplate rating that exceeds 1 MW that submits a Generator Deactivation Notice for purposes of becoming Retired or entering into a Mothball Outage or that has entered into an ICAP Ineligible Forced Outage pursuant to Section

## Purpose

The NYISO's Short-Term Reliability Process ("STRP") with its requirements prescribed in Attachments Y and FF of the NYISO's Open Access Transmission Tariff ("OATT") evaluates the first five years of the planning horizon, with a focus on needs arising in the first three years of the study period. With this process in place, the biennial Reliability Planning Process focuses on identifying and resolving longer-term needs through the Reliability Needs Assessment ("RNA") and the Comprehensive Reliability Plan ("CRP").

The first step in the STRP is the Short-Term Assessment of Reliability ("STAR"). STARs are performed quarterly to proactively address reliability needs that may arise within five years ("Short-Term Reliability Needs")<sup>4</sup> due to various changes to the grid such as generator deactivations, revised transmission plans, and updated demand forecasts. Transmission Owners also assess the impact of generator deactivations on their local systems. A Short-Term Reliability Need that is observed within the first three years of the study period constitutes a "Near-Term Reliability Need."<sup>5</sup> Should a Near-Term Reliability Need be identified in a STAR, the NYISO solicits and selects the solution to address the need. If a need arises beyond the first three years of the study period, the NYISO may choose to address the need within the STRP or, if time permits, through the long-term Reliability Planning Process.

This STAR report sets forth the 2025 Quarter 1 findings for the study period from the STAR Start Date (January 15, 2025) through January 15, 2030. The NYISO assessed the potential reliability impacts to the Bulk Power Transmission Facilities ("BPTF") considering system changes, including the availability of resources and the status of transmission plans in accordance with the NYISO Reliability Planning Process Manual.<sup>6</sup>

## Assumptions

The NYISO evaluated the study period using the most recent Reliability Planning Process base case and data available as of January 14, 2025 (*i.e.*, the day before the January 15, 2025 Q1 STAR start date). In accordance with the base case inclusion rules,<sup>7</sup> generation and transmission projects are added to the base case if they have met significant milestones such that there is a reasonable expectation of timely completion of the project. A summary of key projects is provided in Appendix C. The NYISO is tracking the

---

5.18.2.1 of the ISO Services Tariff, which action is being evaluated by the ISO in accordance with its Short-Term Reliability Process requirements in this Section 38 of the ISO OATT."

<sup>4</sup> OATT Section 38.1 contains the tariff definition of a "Short-Term Reliability Process Need."

<sup>5</sup> OATT Section 38.1 contains the tariff definition of a "Near-Term Reliability Need." See also, OATT Section 38.3.6.

<sup>6</sup> NYISO Reliability Planning Process Manual, July 11, 2022. See: [https://www.nyiso.com/documents/20142/2924447/rpp\\_mnl.pdf](https://www.nyiso.com/documents/20142/2924447/rpp_mnl.pdf)

<sup>7</sup> See NYISO Reliability Planning Process Manual Section 3.

progress of many projects that may contribute to grid reliability, including numerous offshore wind and energy storage facilities that have not yet met the inclusion rules for reliability assessments. These additional tracked projects are listed in the *2024 Gold Book* and in Appendix D of the 2024 RNA.

This assessment used the major assumptions included in the 2024 RNA, along with several updates to key study assumptions which are provided below. Consistent with the obligations under its tariffs, the NYISO provided information to stakeholders on the modeling assumptions employed in this assessment. Details regarding the study assumptions were reviewed with stakeholders at the joint Electric System Planning Working Group (“ESPWG”)/Transmission Planning Advisory Subcommittee (“TPAS”) meeting on January 21, 2025. The meeting materials are posted on the NYISO’s website.<sup>8</sup>

## **Generation Assumptions**

### **Generator Deactivation Notices**

For this STAR, the deactivating generators included in this assessment are listed in Figure 1. A list of all generator deactivations, including those evaluated in prior STARs, is provided in Appendix C. Generator deactivation notices for retirement, mothball outage, or ICAP ineligible forced outage are available on the NYISO’s website under the Short-Term Reliability Process.<sup>9</sup>

---

<sup>8</sup> Short-Term Assessment of Reliability: 2025 Q1 Key Study Assumptions, ESPWG/TPAS, January 21, 2025 ([here](#))

<sup>9</sup> See <https://www.nyiso.com/short-term-reliability-process> then Generator Deactivation Notices/Planned Retirement Notices or Generator Deactivation Notices/IIFO Notifications

**Figure 1: 2025 Quarter 1 STAR Generator Deactivations**

Generating Unit	Submitting Entity	PTID	Responsible Transmission Owner	Zone	Nameplate MW	Unit Type	Date of Completed Deactivation Notice	Retire/Mothball Outage/ICAP Ineligible Forced Outage (IIFO)	Proposed Deactivation/IIFO Date
Shoreham 2 IC	National Grid Generation, LLC	23716	LIPA	K	18.6	JE	12/6/24	Retire	5/1/25
Madison Windpower	Madison Windpower, LLC	24146	Avangrid	E	11.6	WT	1/14/25	Retire	5/1/25

### **Peaker Rule: Ozone Season Oxides of Nitrogen (NOx) Emission Limits for Simple Cycle and Regenerative Combustion Turbines**

In 2019, the New York State Department of Environmental Conservation (“DEC”) adopted a regulation to limit nitrogen oxides (NOx) emissions from simple-cycle combustion turbines (referred to as the “Peaker Rule”).<sup>10</sup> Combustion turbines known as “peakers” typically operate to maintain bulk power system reliability during the most stressful operating conditions, such as periods of peak electricity demand. The Peaker Rule impacts turbines located mainly in the lower Hudson Valley, New York City and Long Island. Many of these units also maintain transmission security by supplying energy within certain areas of the grid referred to as “load pockets.” Load pockets represent transmission-constrained geographic areas where a portion of electrical demand can only be served by local generators due to transmission limitations that occur during certain operating conditions.

The Peaker Rule provides a phased reduction in emission limits, in 2023 and 2025, during the ozone season (May 1-September 30) and allows several options for achieving compliance with the new lower limits applicable during the ozone season. The rule required peaking unit owners to submit compliance plans to the DEC in March 2020. Compliance plans submitted to the DEC were provided to the NYISO for assessment and inclusion in the Reliability Planning Process base case. Considering all peaker unit compliance plans, approximately 1,600 MW of peaker generation capability would be unavailable during the summer by 2025 to comply with the emissions requirements. A subset of those generators became unavailable starting in 2023. As of May 1, 2023, 1,014 MW of affected peakers deactivated or limited their operations. The remaining peakers would become unavailable beginning May 1, 2025, except for those that have been designated as necessary to be temporarily retained for reliability until permanent, Climate Leadership and Community Protection Act<sup>11</sup> compliant, solutions are developed or completed. Remaining peaker units have stated either that they comply with the emission limits as currently operated, or proposed equipment upgrades to achieve the more stringent emissions limits.

A list of peaker generation removals is provided in Figure 2. Peaker generators that have already completed a Generator Deactivation Notice or entered an IIFO are indicated in the table. Additionally, the table notes the STAR study or other assessments where these generators have been evaluated once a generator completed its generator deactivation notice or entered into an IIFO.

The DEC regulations include a provision to allow an affected generator to continue to operate for up to two years, with a possible further two-year extension, after the compliance deadline if the generator is

---

<sup>10</sup> [DEC Peaker Rule](#)

<sup>11</sup> New York's Climate Leadership and Community Protection Act ("CLCPA"), Chapter 106 of the Laws of 2019. The CLCPA become effective on January 1, 2020.

designated by the NYISO or by the local transmission owner as needed to resolve a reliability need until a permanent solution is in place. Consistent with the DEC's regulations and detailed in the Short-Term Reliability Process report it issued on November 20, 2023, the NYISO has designated the Gowanus 2 & 3 and Narrows 1 & 2 generators (32 units total) to temporarily continue operation beyond May 2025 until permanent solutions are in place, for an initial period of up to two years (May 1, 2027).<sup>12</sup>

Study assumptions of generators for this STAR are derived from the 2024 RNA, except for the changes to generation assumptions specified below.

---

<sup>12</sup> Three of the 32 Gowanus and Narrows generators have recently experienced forced outages (Gowanus GT 3-6, Narrows GT 2-1, and Narrows GT 2-7). Gowanus GT 3-6 entered an ICAP Ineligible Forced Outage (IIFO) on April 1, 2025. The reliability impacts of its IIFO will be evaluated in the 2025 Q2 STAR. Narrows GTs 2-1 and 2-7 are expected to enter IIFO on May 1, 2025. When they enter IIFO the NYISO, in consultation with Con Edison, may decide to evaluate the reliability impacts of their outages in the 2025 Q2 STAR as well.

**Figure 2: Status Changes Due to DEC Peaker Rule**

Owner/Operator	Station	Zone	Nameplate (MW)	CRIS (MW) (1)		Capability (MW) (1)		Status Change Date (2)	STAR Evaluation or Other Assessment
				Summer	Winter	Summer	Winter		
National Grid	West Babylon 4 (6) (7)	K	52.4	49.0	64.0	41.2	63.4	12/12/2020 (R)	Other
National Grid	Glenwood GT 01 (4) (7)	K	16.0	14.6	19.1	13.0	15.3	2/28/2021 (R)	2020 Q3
Helix Ravenswood, LLC	Ravenswood 11 (12)	J	25.0	20.2	25.7	16.1	22.4	12/1/2021 (IIFO)	2022 Q1/2023 Q3
Helix Ravenswood, LLC	Ravenswood 01 (12)	J	18.6	8.8	11.5	7.7	11.1	1/1/2022 (IIFO)	2022 Q1/2023 Q3
Astoria Generating Company, L.P.	Gowanus 1-1 through 1-8	J	160.0	138.7	181.1	133.1	182.2	11/1/2022 (R)	2022 Q2
Astoria Generating Company, L.P.	Gowanus 4-1 through 4-8	J	160.0	140.1	182.9	138.8	183.4	11/1/2022 (R)	2022 Q2
Consolidated Edison Co. of NY, Inc.	Hudson Ave 3	J	16.3	16.0	20.9	12.3	15.6	11/1/2022 (R)	2022 Q2
Consolidated Edison Co. of NY, Inc.	Hudson Ave 5	J	16.3	15.1	19.7	15.3	18.6	11/1/2022 (R)	2022 Q2
Central Hudson Gas & Elec. Corp.	Coxsackie GT (8)	G	21.6	21.6	26.0	19.7	22.7	12/31/2025 (14)	2024 Q1
Central Hudson Gas & Elec. Corp.	South Cairo (8)	G	21.6	19.8	25.9	14.6	20.7	3/31/2024 (R)	2023 Q4
Consolidated Edison Co. of NY, Inc.	74 St. GT 1 & 2 (10)	J	37.0	39.1	49.2	37.8	43.6	5/1/2023	2022 Q2
NRG Power Marketing, LLC	Astoria GT 2-1, 2-2, 2-3, 2-4	J	186.0	165.8	204.1	138.0	184.2	5/1/2023 (R)	2022 Q2
NRG Power Marketing, LLC	Astoria GT 3-1, 3-2, 3-3, 3-4	J	186.0	170.7	210.0	139.1	180.4	5/1/2023 (R)	2022 Q2
NRG Power Marketing, LLC	Astoria GT 4-1, 4-2, 4-3, 4-4	J	186.0	167.9	206.7	138.5	178.6	5/1/2023 (R)	2022 Q2
Helix Ravenswood, LLC	Ravenswood 10	J	25.0	21.2	27.0	16.1	20.3	5/1/2023 (R)	2022 Q3
National Grid	Glenwood GT 03 (3) (4)	K	55.0	54.7	71.5	52.0	65.9	5/1/2023	
National Grid	Northport GT (9)	K	16.0	13.8	18.0	8.3	12.7	5/1/2023	
National Grid	Port Jefferson GT 01 (9)	K	16.0	14.1	18.4	13.0	15.3	5/1/2023	
National Grid	Shoreham 1 (3) (4)	K	52.9	48.9	63.9	42.0	63.0	5/1/2023	
National Grid	Shoreham 2 (3) (4)	K	18.6	18.5	23.5	17.4	21.5	5/1/2025	2025 Q1
Astoria Generating Company, L.P.	Astoria GT 01 (11)	J	16.0	15.7	20.5	13.8	17.6	5/1/2025 (11)	2024 Q3
Consolidated Edison Co. of NY, Inc.	59 St. GT 1	J	17.1	15.4	20.1	13.9	17.4	5/1/2025	
NRG Power Marketing, LLC	Arthur Kill GT 1	J	20.0	16.5	21.6	12.3	15.8	5/1/2025	
Astoria Generating Company, L.P.	Gowanus 2-1 through 2-8 (5) (13)	J	160.0	152.8	199.6	140.9	179.1	5/1/2025	
Astoria Generating Company, L.P.	Gowanus 3-1 through 3-8 (5) (13)	J	160.0	146.8	191.7	138.5	178.5	5/1/2025	
Astoria Generating Company, L.P.	Narrows 1-1 through 2-8 (5) (13)	J	352.0	309.1	403.6	284.3	365.7	5/1/2025	
			<b>Prior to Summer 2022</b>	112.0	92.6	120.3	78.0	112.2	
			<b>Prior to Summer 2023</b>	1,174.3	1,066.0	1,348.8	936.0	1,228.7	
			<b>Prior to Summer 2025</b>	725.1	656.3	857.1	603.7	774.1	
			<b>Total</b>	2,011.4	1,814.9	2,326.2	1,617.7	2,115.0	

**Notes**

- MW values are from the 2024 Load and Capacity Data Report except where the 2024 Load and Capacity Data Report lists 0 MW for CRIS and/or Capability. For those instances, previous Load and Capacity Data Report MW values are used.
- Dates identified by generators in their DEC Peaker Rule compliance plan submittals for transitioning the facility to Retired, Blackstart, or will be out-of-service in the summer ozone season or the date in which the generator entered (or proposed to enter) Retired (R) or Mothball Outage (MO) or the date on which the generator entered ICAP Ineligible Forced Outage (IIFO).
- Generator changed DEC peaker rule compliance plan as compared to the 2020 RNA and all STARs prior to 2021 Q3.
- Long Island Power Authority (LIPA) has submitted notifications to the DEC per part 227-3 of the peaker rule stating that these units are needed for reliability allowing these units to operate until at least May 1, 2025. Due to the future nature of these units being operated only as designated by the operator as an emergency operating procedure the NYISO will continue to plan for these units be unavailable starting May 2023.
- These units have indicated they will be out-of-service during the ozone season (May through September) in their compliance plans in response to the DEC peaker rule.
- This unit was evaluated in a stand-alone generator deactivation assessment prior to the creation of the Short-Term Reliability Process.
- Unit operating as a load modifier.
- Central Hudson submitted notification to the DEC per part 227-3 of the peaker rule stating these units are needed for reliability. The most recent LTP update from Central Hudson notes the planned retirement of South Cairo and Coxsackie generators in December 2024. <https://www.nyiso.com/documents/20142/26630522/Local-Transmission-Plan-2021.pdf/>
- On May 24, 2023 National Grid notified the New York State Public Service Commission that these units have been classified as black-start only units and are no longer subject to NYISO dispatch.
- Unit no longer subject to NYISO dispatch and is used for local reliability only.
- The initial proposed retirement was on or after May 1, 2023, and was studied in the 2022 Q4 STAR. However, the unit modified its Peaker Rule compliance plan to be available for operation through May 1, 2025. The unit has submitted a new generator deactivation notice with a new proposed retirement date by May 1, 2025.
- The retirement for this unit was evaluated in the 2023 Q3 STAR
- To address the Need identified in the 2023 Q2 STAR, the NYISO designated the generators on the Gowanus 2 & 3 and Narrows 1 & 2 barges to temporarily remain in operation after the DEC Peaker Rule compliance date (May 1, 2025) until permanent solutions to the Need are in place, for an initial period of up to two years (May 1, 2027).
- In March 2024, Central Hudson submitted an update to its DEC peaker compliance plan to extend the retirement date of Coxsackie GT until December 31, 2025 until a permanent Transmission and Distribution solution to local non-BPTF transmission security issues is completed.



### Generator Return-to-Service

There are no generators that have returned to service beyond those included in the 2024 RNA.

### Generator Additions

There are no generation additions beyond those included in the 2024 RNA. A list of generator additions, including updates to planned commercial operation dates as included in the 2024 RNA, is provided in Appendix C.

### Demand Assumptions

The NYISO used the demand forecasts for this assessment consistent with the 2024 Gold Book. This STAR includes the following load project, which was not included in the 2024 RNA:

- Q1213 — St Lawrence Data and Agricultural Center (Zone D)

Figure 3 shows the summer and winter coincident peak demand forecast and the annual energy forecast for the STAR study period.

**Figure 3: NYCA Demand Forecasts**


Baseline Summer Coincident Peak Demand Forecast (MW)												
Year	A	B	C	D	E	F	G	H	I	J	K	NYCA
2025	2,821	1,969	2,559	689	1,317	2,273	2,157	615	1,334	10,960	4,956	31,650
2026	2,853	2,000	2,598	946	1,276	2,229	2,167	620	1,341	10,990	4,955	31,975
2027	2,835	1,993	2,612	1,250	1,238	2,235	2,183	625	1,351	11,020	4,968	32,310
2028	2,799	1,968	2,639	1,251	1,222	2,225	2,209	632	1,363	11,040	4,982	32,330
2029	2,770	1,951	2,790	1,254	1,218	2,225	2,251	642	1,380	11,050	5,009	32,540
Baseline Winter Coincident Peak Demand Forecast (MW)												
Year	A	B	C	D	E	F	G	H	I	J	K	NYCA
2025-26	2,283	1,584	2,481	1,022	1,292	1,922	1,524	508	885	7,410	3,299	24,210
2026-27	2,348	1,626	2,587	1,304	1,289	1,931	1,548	512	896	7,490	3,334	24,865
2027-28	2,402	1,647	2,675	1,458	1,304	2,001	1,591	522	914	7,560	3,396	25,470
2028-29	2,444	1,670	2,797	1,459	1,323	2,037	1,640	532	933	7,660	3,465	25,960
2029-30	2,499	1,700	2,941	1,463	1,349	2,083	1,700	537	955	7,770	3,553	26,550
Baseline Annual Energy Forecast (GWh)												
Year	A	B	C	D	E	F	G	H	I	J	K	NYCA
2025	15,960	10,000	14,590	5,850	7,010	11,030	9,230	2,740	5,530	49,210	19,870	151,020
2026	16,100	10,330	14,810	7,380	6,740	10,780	9,280	2,740	5,560	49,290	19,980	152,990
2027	15,950	10,310	14,890	8,640	6,530	10,730	9,380	2,760	5,610	49,560	20,170	154,530
2028	15,750	10,100	15,260	8,650	6,390	10,770	9,510	2,780	5,670	49,830	20,390	155,100
2029	15,670	9,990	16,160	8,680	6,320	10,730	9,690	2,830	5,750	50,170	20,670	156,660

Due to economic development and in anticipation of electrification efforts over the next two decades, numerous new large loads are expected to interconnect to the New York system. These large loads are concentrated in upstate New York. Most of these new loads consist of manufacturing facilities and data centers, as well as hydrogen production operations (i.e., electrolysis).

While only a few large load projects have been connected to the New York system in the past

decade, the pace of new load interconnection requests<sup>13</sup> in New York has grown dramatically over the past several years. The NYISO currently has 19 projects requesting to interconnect for a combined total of over 3,000 MW of load.<sup>14</sup> It is projected that over the next decade numerous additional manufacturing and data centers will enter commercial operation and begin consuming relatively large amounts of electricity. The large load projects included in the forecasts vary by scenario, with the high demand forecast including more than the baseline forecast. Figure 4 highlights the majority of large loads with active requests in the NYISO Interconnection Queue (the figure does not include some of the more-recent load interconnection projects).

**Figure 4: Large Load Projects in the NYISO Interconnection Queue**




<sup>13</sup> Load interconnections that are subject to the NYISO's procedures include requests that are either (a) greater than 10 MW connecting a voltage level of 115 kV or above or (b) 80 MW or more connecting at a voltage level below 115 kV. Loads that do not meet one of the aforementioned criteria are handled through the Transmission Owner's processes.

<sup>14</sup> NYISO Interconnection Queue, accessed September 2024, Interconnection Queue Spreadsheet

The trend of rapid large load additions manifested over the past few years and is observed across the country, with regional variations in the speed and types of loads. While the RNA includes these large loads in the Base Case, there could be differences in the actual large loads that ultimately interconnect to the system.

The impact of large load assumptions on the forecast is significant. Figure 5 below shows the baseline forecast with and without large load growth. The timing and level of large load interconnections will have major impacts on future load growth and system risk.

**Figure 5: Large Load Impact on NYCA Baseline Load Forecast**



Generation capacity in New York is secured to ensure that demand can be met, including new large loads added to the system. Generation capacity above and beyond the maximum load is necessary to ensure reliability and resource availability. This means that new large load interconnections will increase the requirement for generation capacity to a value greater than the load itself. The new large loads will have a significant impact on the need for new generating capacity.


Some large load projects, however, do not always require the entire amount of the load to be served for all hours, or during peak system demand. The ability for large loads to be flexible in their usage is an extremely important consideration, particularly during times of peak system demand. Enabling load flexibility, or the ability to move load from times of greater system demand to times with lower demand or higher renewable energy production, can significantly reduce the generation capacity buildout required to serve new large loads.

One key assumption in this STAR is that cryptocurrency mining and hydrogen production large loads will be flexible during system peak demand conditions. This assumption, based on communications with load developers and recent operating experience, results in up to approximately 1,200 MW of large load reduction during the summer and winter peak periods by 2027.


The trend of large load development, and their operating characteristics, requires continuous monitoring as they come in service. The NYISO will continue to coordinate with load developers and TOs.

This assessment recognizes that there is uncertainty in the demand forecast driven by uncertainties in key assumptions, such as population and economic growth, energy efficiency, installation of behind-the-meter renewable energy resources, and electric vehicle adoption and charging patterns. These risks are considered in the transmission security margin calculations by incorporating the lower and higher bounds as a range of forecasted conditions during expected weather, which are specified in the Gold Book as the higher and lower demand forecasts. The lower and higher demand scenarios reflect achievement of policy targets through alternative pathways and assume the same weather factors as the baseline demand forecast. Figure 6 shows the range of baseline forecast along with the demand for heatwave and extreme heatwave conditions within the New York City locality. Figure 7 provides the same forecast information but for all of New York. The dominant policy driver in the early forecast years is energy efficiency, with significant state energy savings targets set through 2025 and 2030.

**Figure 6: New York City Demand Forecasts**



**Figure 7: NYCA Demand Forecasts**



## Transmission Assumptions

### Existing Transmission

The transmission assumptions utilized in this assessment are similar to those used for the 2024 RNA. Figure 8 lists the existing transmission outage assumptions.

A complete list of existing transmission facilities that are modeled as out-of-service for this assessment is also provided in Appendix C.

**Figure 8: Transmission Assumptions**

From	To	kV	ID	Out-of-Service Through	
				Prior STAR	Current STAR
Marion	Farragut	345	B3402	Long-Term	
Marion	Farragut	345	C3403	Long-Term	
Plattsburgh (1)	Plattsburgh	230/115	AT1	3/2025	
Stolle Rd	Stolle Rd	115	T11-52	12/2024	6/2025
E. 13th Street	E. 13th Street	345/69	BK17	12/2024	2/2025
Station 23	Station 42	115	920	-	12/2025

Notes

(1) A spare transformer is placed in-service during the outage

### Proposed Transmission

Compared to the 2024 RNA, there are no changes to assumed firm transmission facilities, as captured in Section 7 of the 2024 Gold Book. Details of the proposed transmission assumptions included in the 2024 RNA are provided in Appendix C.

## Findings

Grid reliability is determined by assessing transmission security and resource adequacy. Transmission security is the ability of the electric system to withstand disturbances such as electric short circuits or unanticipated loss of system elements without involuntarily disconnecting firm load. Resource adequacy is the ability of electric systems to supply the aggregate electrical demand and energy requirements of customers, accounting for scheduled and reasonably expected unscheduled outages of system elements.

Starting with the 2022 RNA and included in subsequent STARs (including this STAR), enhancements to the application of reliability rules were employed for both transmission security and resource adequacy:

- For transmission security, to represent that not all generation will be available at any given time, a derating factor is applied to thermal units. Additionally, intermittent, weather dependent generation is dispatched according to its expected availability coincident with the represented system condition. The enhancements also include the ability to identify BPTF reliability needs in instances where the transmission security margin for a constrained area of the system is less than zero MW.
- For resource adequacy, to ensure that some level of operating reserves is maintained, the emergency operating procedure (EOP) step will retain 400 MW of operating reserves at the time of a load shedding event.

As explained below, this assessment finds that reliability criteria would not be met for the BPTF throughout the five-year study period under the study assumptions and forecasted base case system conditions. However, the observed reliability violation in New York City is mitigated by the temporary and permanent solutions identified in the Short-Term Reliability Process Report issued November 20, 2023.

### Resource Adequacy Assessments

Resource adequacy is the ability of the electric system to supply the aggregate electrical demand and energy requirements of the firm load at all times, considering scheduled and reasonably expected unscheduled outages of system elements. The NYISO performs resource adequacy assessments on a probabilistic basis to capture the random nature of system element outages. If a system has sufficient transmission and generation, the probability of an unplanned disconnection of firm load is equal to or less than the system's standard, which is expressed as a loss of load expectation (LOLE). Consistent with the NPCC and NYSRC criterion, the New York State bulk power system is planned to meet an LOLE that, at any given point in time, is less than or equal



to an involuntary firm load disconnection that is not more frequent than once in every 10 years, or 0.1 event days per year.

This assessment finds that the planned system through the study period meets the resource adequacy criterion. Details about the resource adequacy study assumptions are provided in Appendix D.

### **Transmission Security Assessments**

Transmission security is the ability of the power system to withstand disturbances, such as electric short circuits or unanticipated loss of system elements, and continue to supply and deliver electricity. The analysis for the transmission security assessment is conducted in accordance with NERC Reliability Standards, NPCC Transmission Design Criteria, and the NYSRC Reliability Rules. Transmission security is assessed deterministically with potential disturbances being applied without concern for the likelihood of the disturbance in the assessment. These disturbances (single-element and multiple-element contingencies) are categorized as the design criteria contingencies, which are explicitly defined in the reliability criteria. The impacts resulting from applying these design criteria contingencies are assessed to determine whether thermal loading, voltage or stability violations will occur. In addition, the NYISO performs a short circuit analysis to determine if the system can clear faulted facilities reliably under short circuit conditions. The NYISO's "Guideline for Fault Current Assessment"<sup>15</sup> describes the methodology for that analysis.

Transmission security analysis includes the assessment of various combinations of credible system conditions intended to stress the system. As transmission security analysis is deterministic, these various credible combinations of system conditions are evaluated throughout the study period to identify reliability needs. Intermittent generation is represented based on expected output during the modeled system conditions.<sup>16</sup>

Transmission security margins are included in this assessment to identify plausible changes in conditions or assumptions that might adversely impact the reliability of the system. The transmission security margin is the ability to meet load plus losses and system reserve (*i.e.*, total capacity requirement) using NYCA generation, interchange, and including temperature-based generation derates (total resources). This assessment is performed using a deterministic approach through powerflow simulations combined with post-processing spreadsheet-based calculations.<sup>17</sup>

---

<sup>15</sup>Attachment I of Transmission, Expansion, and Interconnection Manual.

<sup>16</sup>The RNA assumptions matrix is posted with the April 18, 2024 TPAS/ESPPG meeting materials, which are available [here](#).

<sup>17</sup> At its June 23, 2022, meeting, the NYISO Operating Committee approved revisions to the Reliability Planning Process Manual that reflect the use of transmission security margins and other enhancements.




For the transmission security margin assessment, margins are evaluated for the statewide system margin, as well as Lower Hudson Valley, New York City, and Long Island localities. In this evaluation, a BPTF reliability need is identified when the margin is less than zero under expected weather, normal transfer criteria conditions for the Lower Hudson Valley, New York City, and Long Island localities. Additional details regarding the impact of heatwaves, cold snaps, and other system conditions are provided in Appendix E.

For the purposes of identifying reliability needs on the BPTF using transmission security margin calculations, thermal generation MW capability is considered available based on NERC five-year class averages for the relevant type of unit.<sup>18</sup> Derates for thermal generation are included due to the aging fleet without expected replacement, while the share of intermittent, weather dependent, generation is growing.


Figure 9 shows the NERC five-year class-average outage rate for combined cycle, gas turbine, fossil steam turbine, and jet engine generators. Figure 10 shows the impact of the thermal derates on the total resources available statewide, as well as the Lower Hudson Valley, New York City, and Long Island localities in the summer. Reductions in thermal derates over time are driven by the assumed generator deactivations in this assessment.

**Figure 9: NERC Five-Year Class Average Outage Rate**



<sup>18</sup> The NERC five-year class average EFORD data is available [here](#). NERC class average derating factors used in the STAR do not have a mechanism for excluding 9300 events (generator outages due to transmission system problems), see further discussion in Oct. 7, 2024 ICAP/MIWG/PRLWG presentation.

**Figure 10: Thermal Unit Derate (MW) for New York**



The NYISO performed a transmission security assessment of the BPTF and identified no new reliability needs during the STAR study period.

#### Steady State Assessment

There are three potential steady state reliability issues; two potential issues were identified in winter peak conditions and one in summer peak conditions. The identified issues do not result in a Reliability Need, as they are addressed by modifications to planned system changes or consideration of known operational behavior. No other steady-state transmission security related needs were observed under other system conditions, including daytime light load conditions, which captured a high penetration of behind-the-meter solar resources.

The first identified steady-state transmission security issue is a low-voltage violation at the Porter 115 kV bus following various contingency combinations resulting in the loss of both Edic-to-Porter 345/115 kV transformers under expected winter peak conditions. This violation was first observed in the 2022 Quarter 3 STAR. The low-voltage violation at the Porter 115 kV bus is observed starting in winter 2025-26 due to (1) the retirement of the two Porter 230/115 kV buses, which is planned to occur that winter with the Smart Path Connect Project (interconnection queue #Q1125), and (2) the increasing demand in Zone E observed in winter. The evaluation did not observe the low-voltage violation at the Porter 115 kV bus under summer peak demand conditions because the demand forecast for Zone E is higher in winter than in summer. The low-voltage violation that is observed at the Porter 115 kV bus occurs due to the planned changes with the interconnection of the Smart Path Connect Project (Q#1125). The Q#1125 Facilities Study

identified that the 230 kV Edic-Porter Line 17 will be retained along with other modifications to address this issue.

The second potential steady-state transmission security issue identified for the study period under expected winter peak conditions is a thermal violation on the Moses AT3 230/115 kV transformer. This violation was first observed in the 2024 Quarter 3 STAR and is impacted by the inclusion of Q1213- St Lawrence Data and Agricultural Center in this 2025 Q1 STAR. The violation occurs under N-1-1 conditions, for contingency combinations that result in the loss of the other three Moses 230/115 kV transformers. This issue is driven by the growth of the North Country Data Center (NCDC) load and the addition of St Lawrence Data and Agricultural Center, combined with the increasing demand in Zone D observed in winter, and the unavailability of non-firm gas generation in the local area. This issue is addressed by the expected operational behavior of flexible large loads, which would reduce their electrical demand under peak conditions. In consideration of this expected flexibility, the thermal violation on the Moses AT3 230/115 kV transformer would not be observed. As such, there are no thermal criteria violations. However, a reliability risk to note is that more than 2,000 MW of additional load has requested to interconnect in Zone D downstream of the Moses 230/115 kV transformers. The NYISO will continue to monitor the status of these large loads and their anticipated operational behavior in future STARs.

The third potential steady-state transmission security issue identified for the study period under expected summer peak conditions is a thermal violation on the Lovett 345/138 kV transformer (Bank 192). This transformer entered service in October 2024 with installed ratings lower than what had been provided for planning purposes. Subsequent to the transformer going in-service, Orange & Rockland developed a modification to the station protection system to automatically isolate the transformer for overload conditions. This protection change was reflected in steady-state simulation by tripping the transformer when overloaded and no adverse impacts were observed on the BPTF.<sup>19</sup>

### **Dynamics Assessment**

No BPTF dynamic criteria violations were observed for this assessment. Additionally, no dynamic stability related non-BPTF generator deactivation reliability needs were observed for this assessment.

---

<sup>19</sup> For information: A portion of load in Orange & Rockland's non-BPTF service territory including the RECO load in New Jersey, which is served radially from the NYCA, may be lost under N-1-1 conditions for contingency combinations that result in the loss of three transmission paths into this load pocket, which includes the loss of a double circuit tower. These contingency combinations are beyond design criteria for non-BPTF, and this risk of load loss existed before the Lovett transformer entered service. As such, there are no thermal criteria violations identified.

### **Short Circuit Assessment**

No BPTF short-circuit criteria violations were observed in this assessment. Additionally, no short-circuit non-BPTF generator deactivation reliability needs were observed in this assessment.


### **Statewide System Margins**

The statewide system margin is a measure of the amount of generation and net imports available to supply firm load with the bulk power transmission system within applicable normal ratings and limits (i.e., normal transfer criteria) while maintaining 10-minute operating reserves. Statewide system margin is a useful metric that respects multiple reliability criteria, but there is currently not a specific reliability criterion about statewide system margin.


Under summer peak baseline expected weather load, normal transfer criteria, the statewide system margin ranges between 1,064 MW in 2025 to -12 MW in 2034 with flexible large loads modeled offline. When flexible large loads are modeled online during the summer peak day, the statewide system margin ranges between 453 MW in 2025 to -1,192 MW in 2034. Under winter peak baseline expected weather load, normal transfer criteria, the statewide system margin ranges between 4,221 MW in 2025 to -2,283 MW in 2034 with flexible large loads modeled offline. When flexible large loads are modeled online during the winter peak day, the statewide system margin ranges between 453 MW in 2025 to -1,192 MW in 2034.

The statewide system margin under summer peak baseline expected weather load is shown in Figure 11 and under winter peak baseline expected weather load in Figure 12.

**Figure 11: Statewide System Margin – Summer Peak**



**Figure 12: Statewide System Margin – Winter Peak**



The decreasing statewide system margin in both summer and winter can be attributed to increasing demand that is not matched by sufficient planned resources. Additionally, the unavailability of non-firm gas is a key driver of deficient statewide margins in the winter peak condition. A negative statewide system margin is not, on its own, a reliability criteria violation. It is, however, a leading indicator of the inability to securely meet system load under applicable normal transfer criteria, which is observed in the RNA transmission security results as described in Appendix F to the 2024 RNA.


Further risks to the statewide system margin, and transmission security margins in the Lower Hudson Valley, New York City, and Long Island localities include: (1) the CHPE project experiences a significant delay, (2) additional power plants become unavailable, (3) demand significantly exceeds current forecasts.

Additional details regarding the margin calculations are provided in Appendix E. Appendix E also shows impact on the margin of heatwaves, cold snaps, plant outages, and other system conditions.


### **Transmission Security Margin Assessment**

For the transmission security margin assessment, “tipping points” are evaluated for the Lower Hudson Valley, New York City, and Long Island localities. In the Lower Hudson Valley and Long Island localities, the BPTF system is designed to remain reliable in the event of two non-simultaneous outages (N-1-1). In the Con Edison service territory, the 345 kV transmission system and specific portions of the 138 kV transmission system are designed to remain reliable and return to normal ratings after the occurrence of two non-simultaneous outages (N-1-1-0). Figure 13 provides a summary of the margins for normal transfer criteria at the baseline and high demand forecasts during expected summer weather. Figure 14 provides a summary of the margins for normal transfer criteria at the baseline forecasts during expected winter weather.

**Figure 13: Statewide System Margin and Transmission Security Margins – Summer Peak**



**Figure 14: Statewide System Margin and Transmission Security Margins – Winter Peak**



Based on the assumptions for this STAR, the margins are sufficient in the Lower Hudson Valley and Long Island localities in both summer and winter on the peak day during expected weather conditions for all years.


#### **New York City Transmission Security Margin Baseline**

The margin within New York City in 2025 would be deficient by 281 MW for a duration of five hours on the summer peak day during expected weather conditions if the Gowanus and Narrows

peaker generators are unavailable. The New York City margin is shown in Figure 15. The hourly New York City margin for the peak day in 2025 is shown in Figure 16. Accounting for uncertainties in key demand forecast assumptions, using the higher bound of expected demand under baseline weather conditions (95 degrees Fahrenheit) in 2025, the margin within New York City would be deficient by as much as 461 MW for a duration of seven hours. With the planned addition of CHPE, there is an increase in the observed margin beginning summer 2026. However, the margin gradually erodes following CHPE's addition as the baseline demand grows throughout New York. As shown in Figure 15, by 2033, the margin within New York City is deficient by 17 MW during the peak hour, and by 2034 is deficient by 97 MW during the peak hour.


The deficient margin is primarily due to the increased demand forecasts within New York City combined with the assumed unavailability of simple-cycle combustion turbines to comply with the DEC's Peaker Rule in 2025. Decreased summer capabilities of generators within the area and increased generator forced outage rates also contribute to the deficiency.

**Figure 15: New York City Margin – Summer Peak**





**Figure 16: New York City Hourly Transmission Security Margin – Summer Peak**



### New York City Transmission Security Margin Sensitivities

NYISO performed sensitivities on the New York City (Zone J) transmission security margin to evaluate the impacts of updated forecast, and uncertainties in potential system changes or study assumptions. The following factors were evaluated for these sensitivity analyses: updated Zone J demand forecast, CHPE unavailability, heatwave conditions, accelerated deactivations of the NYPA small plants, unplanned failures or outages of aging fossil fuel generators, and different methods for determining the thermal unit derate factors.

#### Sensitivity: Zone J Forecast Update

The baseline transmission security margin utilizes the demand forecast as published in the 2024 Gold Book. This sensitivity evaluates the impact of the preliminary Zone J demand forecast to be published in the 2025 Gold Book following publication of this STAR report. A comparison of the Zone J coincident summer peak demand forecasts from the 2024 Gold Book and the 2025 Gold Book is shown in Figure 17. The impact to the transmission security margin is shown in Figure 18.

**Figure 17: Comparison of Zone J Demand Forecasts and MW Impact**

Comparison of 2024 Zone J Goldbook Forecast and 2025 Preliminary Zone J Forecast					
Item	2025	2026	2027	2028	2029
Zone J Baseline Demand Forecast (2024 Goldbook) (MW)	10,960	10,990	11,020	11,040	11,050
Zone J Baseline Demand Forecast (Preliminary 2025 Goldbook) (MW)	10,764	10,790	10,820	10,840	10,860
Impact (MW)	196	200	200	200	190
Item	2025	2026	2027	2028	2029
Zone J High Demand Forecast (2024 Goldbook) (MW)	11,140	11,270	11,400	11,530	11,660
Zone J High Demand Forecast (Preliminary 2025 Goldbook) (MW)	10,800	10,920	11,040	11,170	11,330
Impact (MW)	340	350	360	360	330

**Figure 18: Zone J Transmission Security Margin Sensitivity – Updated Zone J Demand Forecast**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	Updated Zone J Forecast Impact	196	200	200	200	190
C	Zone J TSM Updated Forecast Sensitivity (A+B)	(85)	689	740	720	700
D	Zone J High Demand Transmission Security Margin	(461)	209	160	30	(100)
E	Updated Zone J High Demand Forecast Impact	340	350	360	360	330
F	Zone J TSM Updated High Demand Forecast Sensitivity (D+E)	(121)	559	520	390	230

Subsequent sensitivities (below) are shown in reference to the base case baseline transmission security margin and this sensitivity with the updated demand forecast.


**Sensitivity: CHPE Unavailability**

Beyond 2025, the reliability margins within New York City will not be sufficient if the CHPE project experiences a significant delay or is otherwise unavailable during summer peak conditions. Figure 19 shows the impact of CHPE's unavailability on the transmission security margin. Specifically, the margin would continue to be deficient for the ten-year planning horizon without the CHPE project in service or other offsetting changes or solutions as shown in Figure 20. In addition, while CHPE is expected to supply capacity in the summer, the facility is not expected to supply capacity from Quebec to New York City under winter peak conditions. CHPE must enter full commercial service and demonstrate that it is capable of being operated to address the reliability needs identified in the 2023 Q2 STAR.

**Figure 19: Zone J Transmission Security Margin Sensitivity – CHPE Unavailability**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	CHPE Unavailability Impact	0	(800)	(800)	(800)	(800)
C	Zone J TSM CHPE Out Sensitivity (A+B)	(281)	(311)	(260)	(280)	(290)
D	Zone J Baseline TSM with Updated Forecast	(85)	689	740	720	700
E	CHPE Unavailability Impact	0	(800)	(800)	(800)	(800)
F	Zone J TSM with Updated Forecast and CHPE Out Sensitivity (D+E)	(85)	(111)	(60)	(80)	(100)

**Figure 20: New York City Transmission Security Margins with and without CHPE**



**Sensitivity: Extreme Heatwave Conditions**

The New York City transmission security margin deficiency would be significantly greater if New York City experiences a heatwave (98 degrees Fahrenheit) or an extreme heatwave (102 degrees Fahrenheit). Under heatwave conditions in 2025, margin deficiency up to 489 MW is predicted, while under extreme heatwave conditions in 2025, margin deficiency up to 1,002 MW is predicted. Figure 21 summarizes the impact of heatwave conditions on the reliability margin.

**Figure 21: Zone J Transmission Security Margin Sensitivity – Heatwave Conditions**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	Heatwave Impact	(208)	(209)	(210)	(211)	(211)
C	Zone J TSM Heatwave Sensitivity (A+B)	(489)	280	331	310	300
D	Extreme Heatwave Impact	(721)	(724)	(726)	(727)	(728)
E	Zone J TSM Extreme Heatwave Sensitivity (A+D)	(1,002)	(235)	(185)	(206)	(217)
F	Zone J TSM Updated Forecast Sensitivity	(85)	689	740	720	700
G	Updated Forecast Heatwave Impact	(202)	(203)	(204)	(205)	(205)
H	Zone J TSM Updated Forecast Heatwave Sensitivity (F+G)	(287)	486	537	516	496
I	Updated Forecast Extreme Heatwave Impact	(707)	(709)	(711)	(712)	(714)
J	Zone J TSM Updated Forecast Extreme Heatwave Sensitivity (F+I)	(792)	(20)	30	9	(13)

### Sensitivity: Aging Fossil Fuel-Fired Generation

This sensitivity evaluates the potential impact if a portion of the aging generation fleet in New York City failed or experienced unplanned outages. An increasing amount of New York’s fossil fuel-fired generation fleet is reaching an age at which, nationally, the majority of similar capacity has been deactivated. Specifically, 95% of steam turbines retire before 62 years of age and 95% of gas turbines retire before age 47. The chance of failure increases as generators age without significant refurbishment or replacement of equipment.

In New York City, over 3,300 MW of summer capability from fossil fuel-fired generation will surpass these age thresholds within the time period covered in this STAR as shown in Figure 22. The base case assumes existing generators remain in service unless they meet the deactivation rules in the Reliability Planning Process Manual. This sensitivity (Figure 23), shows the impact of potential failures of aging generation fleet in New York City and highlights the system’s reliance on a generation fleet that is more prone to failure as it ages.

**Figure 22: Zone J Units Reaching Critical Age**

Unit Name	Summer DMNC (MW)	2025	2026	2027	2028	2029
Arthur Kill ST 2	362	362				
Astoria 2	171	171				
Astoria 3	372	372				
Astoria 5	373	373				
East River 6	132	132				
East River 7	182	182				
Ravenswood ST 01	367		367			
Ravenswood ST 02	375		375			
Ravenswood ST 03	987				987	
<b>Summer DMNC Reaching Critical Age Total (MW)</b>		1,593	742	N/A	987	N/A
<b>Running Total (MW)</b>		1,593	2,335	2,335	3,323	3,323

**Figure 23: Zone J Transmission Security Margin Sensitivity – Aging Fossil Generation**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	<i>Aging Fossil Fleet Impact</i>	(1,426)	(2,090)	(2,090)	(2,974)	(2,974)
C	Zone J TSM Aging Fossil Fleet Sensitivity (A+B)	(1,707)	(1,601)	(1,550)	(2,454)	(2,464)
D	Zone J Baseline TSM with Updated Forecast	(85)	689	740	720	700
E	<i>Aging Fossil Fleet Impact</i>	(1,426)	(2,090)	(2,090)	(2,974)	(2,974)
F	Zone J TSM with Updated Forecast Aging Fossil Fleet Sensitivity (D+E)	(1,511)	(1,401)	(1,350)	(2,254)	(2,274)

Note: I+K to J was not recalculated following the assumed unavailability of specific aging generation units.

### Sensitivity: Accelerated NYPA Small Plant Retirements

The 2024 RNA considered New York State’s 2023-24 *Enacted State Budget* that requires NYPA to phase out electricity production from its small natural gas power plants. Under this legislation,

NYPA is required to publish a plan by May 2025 to phase out the production of electricity from its seven small natural gas power plants (simple-cycle combustion turbines) in New York City and Long Island by December 31, 2030. The units affected by the legislation total 517 MW with an age of only 24 years. The units located in Zone J are summarized in Figure 24. For the 2024 RNA, all seven plants were modeled as out-of-service beginning January 1, 2031. Depending on the details of NYPA's transition plan though, some or all of the units may need to retire earlier.

The NYISO performed this sensitivity (Figure 25) to show the impact if all seven NYPA small natural gas power plants retired beginning in summer 2025. While this sensitivity assumes imminent deactivation solely for informational purposes, it should not be interpreted to be a reflection of any plan or intent expressed by NYPA or that deactivation by summer 2025 is feasible. NYPA is required to follow the Generation Deactivation requirement in accordance with NYISO OATT Attachment FF, Section 38.3 and provide appropriate advance notice before it deactivates its Generators.

**Figure 24: NYPA Small Plants**

NYPA Small Plants (Zone J) Age				
Unit Name	In-Service Date	Nameplate (MW)	Summer Capability (MW)	Unit Age (Years)
Gowanus 5	2001-08-01	47.0	40.0	24
Gowanus 6	2001-08-01	47.0	39.9	24
Kent	2001-08-01	47.0	46.0	24
Pouch	2001-08-01	47.0	45.4	24
Hellgate 1	2001-08-01	47.0	39.9	24
Hellgate 2	2001-08-01	47.0	39.6	24
Harlem River 1	2001-08-01	47.0	39.9	24
Harlem River 2	2001-08-01	47.0	39.6	24
Vernon Blvd 2	2001-08-01	47.0	40.0	24
Vernon Blvd 3	2001-08-01	47.0	39.9	24

**Figure 25: Zone J Transmission Security Margin Sensitivity – NYPA Small Plants Accelerated Retirements**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	NYPA Small Plants Accelerated Retirements Impact	(367)	(367)	(367)	(367)	(367)
C	Zone J TSM Accelerated Retirements Sensitivity (A+B)	(648)	122	173	153	143
D	Zone J Baseline TSM with Updated Forecast	(85)	689	740	720	700
E	NYPA Small Plants Accelerated Retirements Impact	(367)	(367)	(367)	(367)	(367)
F	Zone J TSM with Updated Forecast Accelerated Retirements Sensitivity (D+E)	(452)	322	373	353	333

#### Sensitivity: Thermal Unit Derate Assumptions

For the purposes of identifying reliability needs on the BPTF using transmission security margin calculations, thermal generation MW capability is considered available based on NERC five-year class averages for the relevant type of unit. At the request of stakeholders, the NYISO assessed other options for thermal generation derate assumptions using NYCA specific data. Several of these

options do not consider generator outages from cause-code 9300 events (generator outages due to transmission system problems). The sensitivities described in Figure 26 and the sensitivity results summarized in Figure 27 use preliminary estimates of outage rates for illustrative purposes.

1. NERC EFORD five-year class averages with an offset to account for cause-code 9300
2. Zone J 5-Year average EFORD
3. Zone J 10-Year average EFORD

**Figure 26: Thermal Unit Derate Sensitivities EFORDs**

Method	Zone J Avg EFORD	Zone J Total EFORD (MW)
NERC Class Avg	7.87%	(642)
NERC Class Avg with 9300 Offset*	5.37%	(442)
NYCA Zonal 5-year Avg (accounts for 9300)*	3.26%	(260)
NYCA Zonal 10-year Avg (accounts for 9300)*	5.34%	(429)

\*Preliminary estimates of outages rates used for illustrative purposes.

**Figure 27: Zone J Transmission Security Margin Sensitivity – Thermal Unit Derate**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	NERC EFORD with 9300 Offset Impact	200	200	200	200	200
C	Zone J TSM 9300 Offset Impact Sensitivity (A+B)	(81)	689	740	720	710
D	Zone J 5-Year EFORD Impact	382	382	382	382	382
E	Zone J TSM 5-Year EFORD Sensitivity (A+D)	101	871	922	902	892
F	Zone J 10-Year EFORD Impact	213	213	213	213	213
G	Zone J TSM 10-Year EFORD Sensitivity (A+F)	(68)	702	753	733	723
H	Zone J Baseline TSM with Updated Forecast	(85)	689	740	720	700
I	NERC EFORD with 9300 Offset Impact	200	200	200	200	200
J	Zone J TSM with Updated Forecast 9300 Offset Impact Sensitivity (H+I)	115	889	940	920	900
K	Zone J 5-Year EFORD Impact	382	382	382	382	382
L	Zone J TSM with Updated Forecast 5-Year EFORD Sensitivity (H+K)	297	1,071	1,122	1,102	1,082
M	Zone J 10-Year EFORD Impact	213	213	213	213	213
N	Zone J TSM with Updated Forecast 10-Year EFORD Sensitivity (H+M)	128	902	953	933	913

### Summary of Sensitivity Analyses

Sensitivity analyses to the New York City transmission security margin calculation show that some potential system changes or revised assumptions, such as considering updated demand forecasts or changing thermal unit derate assumptions, may mitigate the deficiency identified in the STAR. However, other sensitivities show increased reliability risks due to uncertainties pertaining to factors including additional or accelerated generation retirements, or unavailability of power from CHPE. For instance, even with CHPE entering service in summer 2026, the transmission security margin will be narrow and any variation in other assumptions could result in a deficiency. Furthermore, the impact of weather on system performance remains an important reliability risk factor though extreme weather is beyond current design requirements.



Potential system changes could lead to one or more sensitivities to occur concurrently. Two combinations of sensitivities are provided below as samples of the compounding effect of uncertainty and both lead to deficient Zone J transmission security margins for the baseline and high demand forecasts through year 5.

1. Updated Zone J load forecast + Zone J 10-Year average EFORD + CHPE unavailability + accelerated NYPA small plant retirements for baseline and high demand (Figure 28)

**Figure 28: Zone J Transmission Security Margin Sensitivity Combination 1**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	Updated Zone J Forecast Impact	196	200	200	200	190
C	Zone J 10-Year EFORD Impact	213	213	213	213	213
D	CHPE Unavailability Impact	0	(800)	(800)	(800)	(800)
E	Accelerated NYPA Small Plant Retirement Impact	(388)	(388)	(388)	(388)	(388)
F	Zone J Baseline Transmission Security Margin - Sensitivity Combination 1	(260)	(286)	(235)	(255)	(275)
G	Updated Zone J Forecast High Demand Impact	(36)	(130)	(220)	(330)	(470)
H	Zone J High Demand Transmission Security Margin - Sensitivity Combination 1	(296)	(416)	(455)	(585)	(745)

2. Updated Zone J load forecast + Zone J 10-Year average EFORD + CHPE unavailability + unplanned fossil fleet unavailability for baseline and high demand (Figure 29)

**Figure 29: Zone J Transmission Security Margin Sensitivity Combination 2**

Line	Item	2025	2026	2027	2028	2029
A	Zone J Baseline Transmission Security Margin	(281)	489	540	520	510
B	Updated Zone J Forecast Impact	196	200	200	200	190
C	Zone J 10-Year EFORD Impact	213	213	213	213	213
D	Aging Fossil Fleet Impact	(1,508)	(2,211)	(2,211)	(3,145)	(3,145)
E	Zone J Baseline Transmission Security Margin - Sensitivity Combination 2	(1,380)	(1,309)	(1,257)	(2,212)	(2,232)
F	Updated Zone J Forecast High Demand Impact	(36)	(130)	(220)	(330)	(470)
G	Zone J High Demand Transmission Security Margin - Sensitivity Combination 2	(1,416)	(1,439)	(1,477)	(2,542)	(2,702)

## Solutions to Previously Identified Short Term Reliability Needs


On October 3, 2023, the NYISO received proposed solutions to the 2023 Quarter 2 STAR need within New York City. On November 20, 2023 the NYISO issued the Short-Term Reliability Process Report identifying the solution selection to address the 2025 New York City need.<sup>20</sup> The results of this determination were reviewed with stakeholders at the November 29, 2023 Management Committee meeting.<sup>21</sup> There were no viable and sufficient solutions submitted in the STRP solicitation that met the need in 2025. The NYISO determined that temporarily retaining the peaker generators on the Gowanus 2 & 3 and Narrows 1 & 2 barges is necessary to address the need until a permanent solution is in place. The NYISO's designation of the Gowanus 2 & 3 and Narrows 1 & 2

<sup>20</sup> Short-Term Reliability Process Report: 2025 Near-Term Reliability Need, November 20, 2023 ([here](#))

<sup>21</sup> Short-Term Reliability Process Report, Management Committee Meeting, November 29, 2023 ([here](#))


generators will allow their continued operation beyond May 2025 until the earlier of May 1, 2027, or the date a permanent solution is in place and a reliability need does not exist, consistent with the DEC Peaker Rule. The Gowanus and Narrows plant owner, Astoria Generating Company L.P., informed the NYISO that its generators are available to continue operation for so long as they are determined to be needed for reliability and are allowed to continue operating consistent with the Peaker Rule. With the continued operation of these peakers until the earlier of the date a permanent solution is in place (*i.e.*, CHPE) or May 2027, the Need for the currently forecasted demand is addressed if CHPE is not delayed beyond 2026, as shown in the following chart (Figure 30). Without the retention of these generators, the New York City area would not meet the mandatory reliability criteria during expected summer weather peak demand periods.

**Figure 30: New York City Margin with Designated Peakers**





**Figure 31: New York City Hourly Margin with Designated Peakers**



As identified in the NYISO’s 2023-2032 Comprehensive Reliability Plan, there are several key risk factors to the reliability of the grid, including generation unavailability and extreme weather. In addition to meeting the identified Near-Term Need and satisfying the mandatory reliability criteria, the retention of the generators on the Gowanus 2 & 3 and Narrows 1 & 2 barges helps to increase New York City bulk power transmission system resilience during unexpected facility outages or under extreme weather conditions, such as heatwaves (98 degrees Fahrenheit) and extreme heatwaves (102 degrees Fahrenheit) as shown in Figure 31.

The retained generators will participate in the NYISO’s economic dispatch which aligns generation operating schedules with real-time reliability needs. The operating characteristics of the units, primarily their high operating costs relative to other New York City generation and their ability to start quickly and operate with short run-times, will result in the NYISO limiting the run times of the units to the duration of real-time energy needs.

The NYISO’s designation of the Gowanus 2 & 3 and Narrows 1 & 2 generators to allow their continued operation beyond May 2025 continues to be necessary to address the reliability need identified in the 2023 Quarter 2 STAR.


## Local Non-BPTF Reliability Assessment

In addition to the assessment of the BPTFs conducted by the NYISO, Con Edison performed a

local non-BPTF reliability assessment and observed transmission security violations due to deficiencies observed in their non-bulk Greenwood 138 kV transmission load area (TLA). As provided by Con Edison, the observed deficiencies range from 140 MW to 360 MW depending on system conditions. If the Greenwood TLA deficiency is not addressed, neighboring TLAs, including the Vernon 138 kV TLA, would also have deficiencies.

The Greenwood TLA, shown in Figure 32, depends on power imports from the boundary substations and the generation connected within the TLA. Con Edison's assessment assumed that the Gowanus 2 & 3 and Narrows 1 & 2 barges are unavailable for the summer operating season, starting in 2026, and the NYPA small gas plants are unavailable starting in 2031. For the upcoming summer 2025 operating season, Con Edison assumed the barges to be available due to the overall Zone J (New York City) reliability need as established by the NYISO; without the barges, transmission security violations would be observed in the local area. These conditions will continue to be assessed and reported through quarterly STARS and Con Edison's local transmission owner plans.

**Figure 32: Greenwood 138 kV TLA**



Starting in 2026, thermal overloads and voltage violations are observed on the Greenwood 138

kV TLA boundary feeders in the steady state (N-0) condition, which are exacerbated under N-1 and N-1-1 conditions. Considering the utilization of all available PAR controls, the observed deficiency within this TLA is between 240 MW in 2026 to 300 MW in 2031 as shown in Figure 33. The deficiency drops in 2032 and 2034 due to Con Edison’s planned load transfers on the distribution system.

**Figure 33: Greenwood 138 kV TLA Deficiency**

Year	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Deficiency (MW)	-	170.0	220.0	220.0	270.0	320.0	360.0	250.0	140.0	170.0

Con Edison’s firm<sup>22</sup> solution is a fourth Gowanus – Greenwood 345/138 kV PAR controlled feeder which is currently in an engineering / procurement / construction phase(s) due to ‘immediate need’ if the barges are unavailable during the summer, and with required in-service date of May 2026. This solution is an interim solution (i.e., ‘bridge the gap’) to be supplemented by future system expansion projects in the local area (these projects are not yet firm projects). Until the fourth Gowanus – Greenwood 345/138 kV PAR controlled feeder is placed into service the barges would be required to be in-service.

This past winter, Con Edison implemented an operations contingency plan for portions of Brooklyn / Staten Island that required the commitment and dispatch of the Narrows and Gowanus barges to serve local load. The event coincided with a cold spell that resulted with higher-than-expected customer demand. The event was triggered under conditions well beyond design criteria where five elements were out of service.<sup>23</sup> Con Edison relied on the Narrows and Gowanus barges during this period to secure its local system, thus avoiding the need to disconnect customer load.

## Conclusions and Determination

Consistent with the analysis and explanations above, this assessment finds the planned BPTF system through the study period meets applicable reliability criteria, other than the reliability need previously identified in the 2023 Quarter 2 STAR.

<sup>22</sup> Con Edison made the fourth Gowanus – Greenwood feeder a firm project on January 21, 2025, ESPWG: [https://www.nyiso.com/documents/20142/49295323/CECONY's\\_LTP\\_Update\\_1\\_21\\_2025.pdf/abf6cfb4-10e6-eee4-3988-0a434f5a1dcb](https://www.nyiso.com/documents/20142/49295323/CECONY's_LTP_Update_1_21_2025.pdf/abf6cfb4-10e6-eee4-3988-0a434f5a1dcb)

<sup>23</sup> The generation and transmission facilities in this series of events are not explicitly named to maintain confidentiality: (1) local generator #1 declared a forced outage, (2) local generator #2 was on a previously scheduled maintenance outage for approx. 6 weeks, (3) additional generation was not available due to an on-going required upgrade to the local substation where the work had been occurring continuously for approx. 3 months, (4) transmission circuit # 1 tripped off-line, and then (5) transmission circuit #2 tripped off-line.

The NYISO's designation of the Gowanus 2 & 3 and Narrows 1 & 2 generators to allow their continued operation beyond May 2025 continues to be necessary to address the reliability need identified in the 2023 Quarter 2 STAR. Sensitivity analyses to the New York City transmission security margin calculation show that some potential system changes or revised assumptions, such as considering updated demand forecasts or changing thermal unit derate assumptions, may mitigate the deficiency identified in the STAR. However, other sensitivities show increased reliability risks due to uncertainties pertaining to factors including additional or accelerated generation retirements, or unavailability of power from CHPE. For instance, even with CHPE entering service in summer 2026, the transmission security margin will be narrow and any variation in other assumptions could result in a deficiency. Furthermore, the impact of weather on system performance remains an important reliability risk factor though extreme weather is beyond current design requirements.

In addition to this STAR's findings, Con Edison's local non-BPTF analysis found that the continued operation of the Gowanus and Narrows generators is necessary until the fourth Gowanus – Greenwood 345/138 kV PAR controlled feeder is placed into service.

No Generator Deactivation Reliability Needs were identified by LIPA following the retirement of Shoreham 2 IC by May 1, 2025. No Generator Deactivation Reliability Needs were identified Avangrid following the retirement of Madison Windpower by May 1, 2025.<sup>24</sup>

---

<sup>24</sup> National Grid Generation, LLC and Madison Wind Power, LLC must complete all required NYISO administrative processes and procedures prior to retirement of their Generators. See Technical Bulletin 185 Generator Deactivation Process and Technical Bulletin 250 Short-Term Reliability Process. The NYISO's determination in this Short-Term Reliability Process does not relieve National Grid Generation, LLC or Madison Wind Power, LLC of any obligations they have with respect to their participation in the NYISO markets. If National Grid Generation, LLC or Madison Wind Power, LLC rescinds its Generator Deactivation Notice or does not retire its Generator within 730 days of January 15, 2025, then it will be required to submit a new Generator Deactivation Notice in order to deactivate the Generator and will be required to repay study costs in accordance with Section 38.14 of the OATT.

## Appendix A: List of Short-Term Reliability Needs

The 2023 Quarter 2 STAR found a reliability need beginning in summer 2025 within New York City primarily driven by a combination of forecasted increases in peak demand and the assumed unavailability of certain generation in New York City affected by the “Peaker Rule.”<sup>25</sup> Specifically, the 2023 Quarter 2 STAR found that the New York City zone is deficient by as much as 446 MW for a duration of nine hours on the peak day during expected weather conditions when accounting for forecasted economic growth and policy-driven increases in demand. The reliability need is based on a deficient transmission security margin in the New York City locality that accounts for expected generator availability, transmission limitations, and updated demand forecasts using data published in the 2023 Load & Capacity Data Report (“Gold Book”).

## Appendix B: Short-Term Reliability Process Solution List

The Short-Term Reliability Process solution list and the status of these solutions is posted on the NYISO website at the following location:

<https://www.nyiso.com/documents/20142/19556596/SolutionStatus-03092021.pdf/>

---

<sup>25</sup> In 2019, the New York State Department of Environmental Conservation adopted a regulation to limit nitrogen oxides (NOx) emissions from simple-cycle combustion turbines, referred to as the “Peaker Rule” (<https://www.dec.ny.gov/regulations/116131.html>)

## Appendix C: Summary of Study Assumptions

This assessment used the major assumptions included in the 2024 RNA, with the key updates noted below. Consistent with the NYISO's obligations under its tariffs, the NYISO provided information to stakeholders on the modeling assumptions employed in this assessment. Details regarding the 2024 RNA study assumptions were reviewed with stakeholders at the April 18, 2024, joint Electric System Planning Working Group ("ESPWG")/Transmission Planning Advisory Subcommittee ("TPAS") meeting. Details regarding the 2025 Q1 STAR study assumptions were reviewed with stakeholders at the January 21, 2025, joint ESPWG/ TPAS meeting. The meeting materials are posted on the NYISO's website.<sup>26</sup> The figures below (Figure 34, Figure 35, Figure 36, and Figure 37) summarize the changes to generation, load, and transmission.

### Generation Assumptions

**Figure 34: Completed Generator Deactivations**

Owner/ Operator	Plant Name	Zone	Nameplate (MW)	CRIS (MW)		Capability (MW)		Status	Deactivation Date (2)	STAR Evaluation (3)
				Summer	Winter	Summer	Winter			
International Paper Company	Ticonderoga (1)	F	9.0	7.6	7.5	9.5	9.8	I	5/1/2017	-
	Ravenswood 2-4	J	42.9	39.8	50.6	30.7	41.6	I	4/1/2018	-
Helix Ravenswood, LLC	Ravenswood 3-1	J	42.9	40.5	51.5	31.9	40.8	I	4/1/2018	-
	Ravenswood 3-2	J	42.9	38.1	48.5	29.4	40.3	I	4/1/2018	-
	Ravenswood 3-4	J	42.9	35.8	45.5	31.2	40.8	I	4/1/2018	-
Exelon Generation Company LLC	Monroe Livingston	B	2.4	2.4	2.4	2.4	2.4	R	9/1/2019	-
Innovative Energy Systems, Inc.	Steuben County LF	C	3.2	3.2	3.2	3.2	3.2	R	9/1/2019	-
Consolidated Edison Co. of NY, Inc	Hudson Ave 4	J	16.3	13.9	18.2	14.0	16.3	R	9/10/2019	-
New York State Elec. & Gas Corp.	Auburn - State St	C	7.4	5.8	6.2	4.1	7.3	R	10/1/2019	-
Somerset Operating Company, LLC	Somerset	A	655.1	686.5	686.5	676.4	684.4	R	3/12/2020	-
Entergy Nuclear Power Marketing, LLC	Indian Point 2	H	1,299.0	1,026.5	1,026.5	1,011.5	1,029.4	R	4/30/2020	-
Cayuga Operating Company, LLC	Cayuga 1	C	155.3	154.1	154.1	151.0	152.0	R	6/4/2020	-
Entergy Nuclear Power Marketing, LLC	Indian Point 3	H	1,012.0	1,040.4	1,040.4	1,036.3	1,038.3	R	4/30/2021	-
Helix Ravenswood, LLC	Ravenswood GT 1.1	J	25.0	20.2	25.7	16.1	22.4	I	12/1/2021	2022 Q1
Helix Ravenswood, LLC	Ravenswood GT 1	J	18.6	8.8	11.5	7.7	11.1	I	1/1/2022	2022 Q1
Exelon Generation Company LLC	Madison County LF	E	1.6	1.6	1.6	1.6	1.6	I	4/1/2022	2022 Q2
Nassau Energy, LLC	Trigen CC	K	55.0	51.6	60.1	38.5	51.0	R	7/15/2022	2022 Q2
Consolidated Edison Co. of NY, Inc.	Hudson Ave 3	J	16.3	16.0	20.9	12.3	15.6	R	11/1/2022	2022 Q2
Consolidated Edison Co. of NY, Inc.	Hudson Ave 5	J	16.3	15.1	19.7	15.3	18.6	R	11/1/2022	2022 Q2
Astoria Generating Company, L.P.	Gowanus 1-1 through 1-8	J	160.0	138.7	181.1	133.1	182.2	R	11/1/2022	2022 Q2
Astoria Generating Company, L.P.	Gowanus 4-1 through 4-8	J	160.0	140.1	182.9	138.8	183.4	R	11/1/2022	2022 Q2
NRG Power Marketing LLC	Astoria GT 2-1	J	46.5	41.2	50.7	34.9	46.5	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 2-2	J	46.5	42.4	52.2	34.3	45.6	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 2-3	J	46.5	41.2	50.7	36.3	46.7	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 2-4	J	46.5	41.0	50.5	32.5	45.4	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 3-1	J	46.5	41.2	50.7	34.6	45.0	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 3-2	J	46.5	43.5	53.5	35.7	45.3	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 3-3	J	46.5	43.0	52.9	33.9	44.6	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 3-4	J	46.5	43.0	52.9	34.9	45.5	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 4-1	J	46.5	42.6	52.4	33.6	43.8	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 4-2	J	46.5	41.4	51.0	34.3	44.3	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 4-3	J	46.5	41.1	50.6	35.4	46.4	R	5/1/2023	2022 Q2
NRG Power Marketing LLC	Astoria GT 4-4	J	46.5	42.8	52.7	35.2	44.1	R	5/1/2023	2022 Q2
Helix Ravenswood, LLC	Ravenswood 10	J	25.0	21.2	27.0	16.1	20.3	R	5/1/2023	2022 Q3
Helix Ravenswood, LLC	Ravenswood 01	J	18.6	8.8	11.5	7.7	11.1	R	10/14/2023	2023 Q3
Helix Ravenswood, LLC	Ravenswood 11	J	25.0	20.2	25.7	16.1	22.4	R	10/14/2023	2023 Q3
Western New York Wind Corp	Western NY Wind Power	B	6.6	0.0	0.0	0.0	0.0	R	10/15/2023	2023 Q4
Central Hudson Gas & Electric Corp.	South Cairo GT	G	21.6	19.8	25.9	18.7	23.1	R	3/1/2024	2023 Q4
Cubit Power One Inc.	Arthur Kill Cogen	J	11.1	11.1	11.1	11.1	10.2	I	3/2/2024	2024 Q2
Total			4,450.0	4,072.2	4,366.6	3,880.3	4,222.8			

#### Notes

- (1) Part of SCR program
- (2) This table only includes units that have entered into IIFO or have completed the generator deactivation process.
- (3) "-" denotes that the generator deactivation was assessed prior to the creation of the Short-Term Reliability Process

<sup>26</sup> Short-Term Assessment of Reliability: 2025 Q1 Key Study Assumptions, ESPWG/TPAS, January 21, 2025 ([here](#)). 2024 RNA Key Study Assumptions, ESPWG/TPAS, April 18, 2024 ([here](#)),

**Figure 35: Proposed Generator Deactivations**

Owner/ Operator	Plant Name (1)	Zone	Nameplate	CRIS (MW)		Capability (MW)		Status	Deactivation date (2)	STAR Evaluation
			(MW)	Summer	Winter	Summer	Winter			
Consolidated Edison Co. of NY, Inc.	74 St. GT 1 & 2	J	37	39.1	49.2	0.0	0.0	R	5/1/2023	2022 Q2
Central Hudson Gas & Electric Corp.	Coxsackie GT	G	21.6	21.6	26.0	19.7	22.7	R	12/31/2025 (3)	2024 Q1
Eastern Generation, LLC	Astoria GT 01	J	16	15.7	20.5	13.8	17.6	R	5/1/2025 (4)	2024 Q3
National Grid	Shoreham 2	K	18.6	18.5	23.5	17.4	21.5	R	5/1/2025	2025 Q1
Madison Windpower, LLC	Madison Windpower	E	11.6	11.5	11.5	11.6	11.6	R	5/1/2025	2025 Q1
Total			104.8	106.4	130.7	62.5	73.4			

Notes:

(1) This table includes units that have proposed to Retire or enter Mothball Outage and have a completed generator deactivation notice but have yet to complete the generator deactivation process.

(2) Date in which the generator proposed Retire (R) or enter Mothball Outage (MO)

(3) In March 2024, Central Hudson submitted an update to its DEC peaker compliance plan to extend the retirement date of Coxsackie GT until December 31, 2025 until a permanent transmission and distribution solution to local non-BPTF transmission security issues is completed.

(4) The initial proposed retirement was on or after May 1, 2023, and was studied in the 2022 Q4 STAR. However, the unit modified its Peaker Rule compliance plan to be available for operation through May 1, 2025. The unit has submitted a new generator deactivation notice with a new proposed retirement date by May 1, 2025.

**Figure 36: Large Generation Additions**

Proposed Project Inclusion: Large Generation					
Queue	Project Name	MW	Type	Zone	Proposed Date
619	East Point Solar	50	Solar	F	Feb-24
618	High River Solar	90	Solar	F	Jun-24
717	Morris Ridge Solar Energy Center	177	Solar	C	Sep-24
637	Flint Mine Solar	100	Solar	G	Oct-24
766/987	Sunrise Wind II	924	Offshore Wind	K	Mar-26
737	Empire Wind 1	816	Offshore Wind	J	Dec-26

**Figure 37: Small Generation Additions**

Proposed Project Inclusion: Small Generation					
	Name	MW	Type	Zone	Proposed Date
572	Greene County 1	20	Solar	G	Jan-23
573	Greene County 2	10	Solar	G	Mar-23
545	Sky High Solar	20	Solar	C	Jun-23
744	Magruder BESS	20	Energy Storage	G	Sep-23
581	Hills Solar	20	Solar	E	Feb-24
586	Watkins Rd Solar	20	Solar	E	Feb-24
584	Dog Corners Solar	20	Solar	C	Apr-24
833	Dolan Solar	20	Solar	F	Apr-24
565	Tayandenega Solar	20	Solar	F	Jun-24
1003	Clear View Solar	20	Solar	C	Jun-24
564	Rock District Solar	20	Solar	F	Jul-24
807	Hilltop Solar	20	Solar	F	Jul-24
670	SunEast Skyline Solar LLC	20	Solar	E	Aug-24
734	Ticonderoga Solar	20	Solar	F	Aug-24
832	CS Hawthorn Solar	20	Solar	F	Aug-24
804	KCE NY 10*	20	Energy Storage	A	Nov-24
828	Valley Solar	20	Solar	C	Nov-24
590	Scipio Solar	18	Solar	C	Dec-24
591	Highview Solar	20	Solar	C	Dec-24
575	Little Pond Solar	20	Solar	G	Jan-25
848	Fairway Solar	20	Solar	E	Mar-25
592	Niagara Solar	20	Solar	B	Jun-25
855	NY13 Solar	20	Solar	F	Jun-25
865	Flat Hill Solar	20	Solar	E	Dec-25
885	Grassy Knoll Solar	20	Solar	E	Dec-25

**Notes:**

\*Project does not have CRIS.



## Demand Assumptions

The 2025 Quarter 1 STAR uses the baseline coincident peak demand forecasts for the study years consistent with the 2024 Gold Book.

## Transmission Assumptions

The study assumptions for existing transmission facilities that are modeled as out-of-service are listed in Figure 38. Figure 39 shows the Con Edison series reactor status utilized in the 2024 RNA as well as for this STAR. There are no changes to the Con Edison series reactor assumptions in this STAR compared to the 2024 RNA. Figure 40 and Figure 41 provide a summary of the transmission projects included in the 2024 RNA Base Cases as listed in the 2024 Gold Book.

**Figure 38: Existing Transmission Facilities Modeled Out-of-Service**

From	To	kV	ID	Out-of-Service Through	
				Prior STAR	Current STAR
Marion	Farragut	345	B3402	Long-Term	
Marion	Farragut	345	C3403	Long-Term	
Plattsburgh (1)	Plattsburgh	230/115	AT1	3/2025	
Stolle Rd	Stolle Rd	115	T11-52	12/2024	6/2025
E. 13th Street	E. 13th Street	345/69	BK17	12/2024	2/2025
Station 23	Station 42	115	920	-	12/2025

Notes

(1) A spare transformer is placed in-service during the outage

**Figure 39: Con Edison Proposed Series Reactor Status**

Terminals		ID	kV	Prior to Summer 2023	Starting Summer 2023
Dunwoodie	Mott Haven	71	345	By-Passed	In-Service
Dunwoodie	Mott Haven	72	345	By-Passed	In-Service
Sprainbrook	W. 49th Street	M51	345	By-Passed	In-Service
Sprainbrook	W. 49th Street	M52	345	By-Passed	In-Service
Farragut	Gowanus	41	345	In-Service	By-Passed
Farragut	Gowanus	42	345	In-Service	By-Passed
Sprainbrook	East Garden City	Y49	345	In-Service	By-Passed

The change in the planned status of the specified series reactors is only implemented for the summer.

**Figure 40: Major Transmission Projects Included in 2024 RNA Base Cases**

Queue	Project Name	MW	POI	Zone	Proposed Date
631/887	TDI Champlain Hudson Power Express (CHPE)	1250	Astoria Annex 345kV	J	May-26
1125	Northern New York Priority Transmission Project (NNYPTP)	N/A	Moses/Adirondack/Porter path	D&E	Dec-25
1289	Propel NY Energy - Alternate Sol 5	N/A	Sprain Brook, Tremont, East Garden City, Shore Road, additional Long Island Substations	I,J,K	May-30
-	Brooklyn Clean Energy Hub	N/A	Between Farragut 345 kV and Rainey 345 kV	J	Jun-28
-	Gowanus/Greenwood PAR Regulated Feeder	N/A	Gowanus 345 kV/Greenwood 138 kV TLA	J	May-25
-	Goethals/Foxhills PAR Regulated Feeder	N/A	Goethals 345 kV/Greenwood 138 kV TLA	J	May-25
-	Eastern Queens Clean Energy Hub	N/A	Between Jamaica 138 kV and Valley Stream/Lake Success 138 kV	J	Jun-28

**Figure 41: Transmission Project Inclusion Rules Application for 2024 RNA Base Case**

Transmission Project Inclusion Rules Application: Class Year Transmission, TIP, and Firm LTP Projects Not Included in the RNA Base Cases											
Transmission Owner	Terminals		Line Length (Miles)	Proposed In-Service Date		Nominal Voltage (kV)		# of CKTs	Thermal Ratings (4)		Project Description / Conductor Size
				Prior to (2)	Year	Operating	Design		Summer	Winter	
Clean Path New York LLC	Fraser 345kV	Rainey 345kV	173	S	2027	492	492	1	1300 MW	1300 MW	±/+ 400kV Bipolar HVDC cable
NYSEG	Canandaigua	Stoney Ridge	24	W	2030	230	230	1	795 MVA	853 MVA	Rebuild the existing 24 mile 230 kV line #68 with mile 230 kV line with bundled 1192 Bunting ACSR ACSR conductor.
NYSEG	Hillside	Watercure	1	W	2030	230	230	1	819 MVA	972 MVA	Rebuild the existing 1 mile 230 kV line #69 with 2156 Bluebird ACSR conductor.
NYSEG	New Gardenville	New Gardenville	xfmr	W	2030	115/34.5	115/34.5	1	50	60	NYSEG Transformer #7 and Station Reconfiguration
NYSEG	New Gardenville	New Gardenville	xfmr	W	2030	115/34.5	115/34.5	2	50	60	NYSEG Transformer #8 and Station Reconfiguration
NYSEG	New Gardenville	New Gardenville	xfmr	W	2030	230/115	230/115	1	316 MVA	370 MVA	NYSEG Transformer #6 and Station Reconfiguration
NYSEG	Stolle Rd	High Sheldon	11	W	2030	230	230	1	795 MVA	853 MVA	Rebuild the existing 11-mile 230 kV line #67 with bundled 1192 Bunting ACSR conductor on an offset with steel monopole structures.
NYSEG	Stoney Ridge	Hillside	27	W	2030	230	230	1	795 MVA	886 MVA	Rebuild the existing 27 mile 230 kV line #72 with 2156 Bluebird ACSR conductor.

## Appendix D: Resource Adequacy Assumptions

### 2025 Q1 STAR MARS Assumptions Matrix

	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
Load Parameters			
1	Peak Load Forecast	Adjusted 2024 Gold Book NYCA baseline peak load forecast. It includes large loads from the NYISO interconnection queue, with forecasted impacts. Baseline load represents coincident summer peak demand and includes the reductions due to projected energy efficiency programs, building codes and standards, BtM storage impacts at peak, distributed energy resources and BtM solar photovoltaic resources; it also reflects expected impacts (increases) from projected electric vehicle usage and electrification. The GB 2024 baseline peak load forecast includes the impact (reduction) of behind-the-meter (BtM) solar at the time of NYCA peak. For the BtM Solar adjustment, gross load forecasts that include the impact of the BtM generation will be used for the 2024 RNA, as provided by the Demand Forecasting Team which then allows for a discrete modeling of the BtM solar resources using 5 years of inverter data.	Same method
1a	Proposed large loads	As included in the Baseline Peak Load Forecast from the Gold Book. Certain large loads that are assumed flexible (e.g., crypto, hydrogen) are modeled as EOP step.	Same method
2	Load Shapes (Multiple Load Shapes)	Used Multiple Load Shape MARS Feature (see <i>March 24, 2022 LFTF/ESPGW</i> ). 8,760-hour historical gross load shapes were used as base shapes for LFU bins: Load Bins 1 and 2: 2013 Load Bins 3 and 4: 2018 Load Bins 5 to 7: 2017 Historical load shapes are adjusted to meet zonal (as well as G-J) coincident and non-coincident peak forecasts (summer and winter), while maintaining the energy targets.  For the BtM Solar discrete modeling, gross load forecasts that include the impact of the BtM generation are used (additional details under the BtM Solar category below).	Same
3	Load Forecast Uncertainty (LFU)  The LFU model captures the impacts of weather conditions on future loads.	2024 LFU Updated via Load Forecast Task Force process.  Same summer LFU values as the ones presented in 2023 (as presented at the May 26, 2023 LFTF <a href="#">[link]</a> and also presented at the April 18, 2024 LFTF <a href="#">[link]</a> )  <b>New Additional Method for Winter:</b> <b>Winter Dynamic Load Forecast Uncertainty (LFU):</b> In order to reflect uncertainty stemming from electrification, electric vehicles (EVs), and large loads, the 2024 RNA will use a winter LFU multipliers model. Over the study period year 2 through year 10, dynamic winter LFU multipliers were calculated, reflecting the increasing share and load behavior of EV charging load, heating electrification, and large load projects. The dynamic winter LFU multipliers increase over the study horizon, reflecting the increasing winter weather sensitivity due to additional EV charging and electric heating load. Note: the first winter of the study period (winter 2024-25) match those calculated using recent winter load and weather data. Additional details are available in the April 18 TPAS/ESPGW/LFTF presentation <a href="#">[link]</a>	Same
Generation Parameters			

	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
1	Existing Generating Unit Capacities (e.g., thermal units, large hydro)	2024 Gold Book values: Summer is min of (DMNC, CRIS). Winter is min of (DMNC, CRIS). Adjusted for RNA Base Case inclusion rules application	Same method
2	Proposed New Units Inclusion Determination	2024 Gold Book with RNA Base Case inclusion rules applied	Same method
3	Retirement, Mothballed Units, IIFO	2024 Gold Book with RNA Base Case inclusion rules applied	Same method
4	Forced and Partial Outage Rates (e.g., thermal units)	Five-year (2019-2023) GADS data for each unit represented. Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period.  For new units or units that are in service for less than three years, NERC 5-year class average EFORd data are used.	Same method
5	Modeling of Non-firm Gas Unavailability During Winter Peak Conditions	<b>New:</b> In order to simulate anticipated risks from cold snaps on the gas availability, gas plants available MWs in NYCA are further derated, i.e., all gas-only units with non-firm gas within the NYCA are assumed unavailable. Also, certain dual-fuel units with duct-burn capability are derated. The forecasted winter coincident peak is used to determine when the gas derates are applied in the RNA Base Cases and for each load bin and Study Year.	Same method
6	Daily Maintenance	Fixed maintenance based on schedules received by the NYISO.	Same method
7	Weekly Planned Maintenance	MARS is automatically scheduling maintenance based on NYCA capacity and demand.  Data: 5y (2019-2023) of historical scheduled maintenance data from Operations and GADS system to determine the number of weeks on maintenance for each thermal unit.	Same method
8	Summer Maintenance	None	Same
9	Combustion Turbine Derates	Derate based on temperature correction curves.  Thermal derates are based on a ratio of peak load before LFU is applied and LFU applied load.  For new units: used data for a unit of same type in same zone, or neighboring zone data.	Same method
10	Existing Landfill Gas (LFG) Plants	Actual hourly plant output over the last 5 years. Program randomly selects an LFG shape of hourly production over the last 5 years for each model replication.  Probabilistic model is incorporated based on five years of input shapes, with one shape per replication randomly selected in the Monte Carlo process.	Same method

	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
11	Existing and Proposed <b>Land-Based Wind</b> Units	<p><b>New data source:</b> Model-based hourly data over the available past 5 years (2017-2021 developed by DNV-GL). For any unit that was included in the DNV data the data “as is” was used. For any unit not included a weighted zonal average was modeled.</p> <p>Probabilistic model is incorporated based on five years of input shapes with one shape per replication being randomly selected in Monte Carlo process.</p>	Same method
12	Proposed <b>Offshore Wind</b> Units	<p>RNA Base Case inclusion rules Applied to determine the generator status.</p> <p><b>New data source:</b> 5 years of hourly model-based data as developed by DNV-GL (2017-2021)</p>	Same method
13	Existing and Proposed <b>Utility-scale Solar Resources</b>	<p><b>New data source:</b> Probabilistic model chooses from the model-based data shapes covering past available 5 years (2017-2021), as developed by DNV-GL.</p> <p>One shape per replication is randomly selected in Monte Carlo process.</p>	Same method
14	<b>BtM Solar Resources</b>	<p><b>Supply side:</b> Past five years (2017-2021) of 8,760 hourly MW profiles based on sampled inverter data. The MARS random shape mechanism randomly picks one 8,760 hourly shape (of five) for each replication year; similar with the past planning modeling and aligns with the method used for wind, utility solar, landfill gas, and run-of-river facilities.</p> <p><b>Load side:</b> Gross load forecasts for the 2024 RNA, as developed by the NYISO forecasting team.</p>	Same method
15	Existing <b>BTM-NG Program</b>	<p>These units are former load modifiers that sell capacity into the ICAP market.</p> <p>Modeled as cogen type 1 (or type 2 as applicable) unit in MARS. Unit capacity set to CRIS value, load modeled with weekly pattern that can change monthly.</p>	Same method
16	Existing <b>Small Hydro</b> Resources (e.g., run of river)	Actual hourly plant output over the past 5 years period. Program randomly selects a hydro shape of hourly production over the 5-year window for each model replication. The randomly selected shape is multiplied by their current nameplate rating.	Same method
17	Existing <b>Large Hydro</b>	<p>Probabilistic Model based on 5 years of GADS data.</p> <p>Transition Rates representing the Equivalent Forced Outage Rates (EFORd) during demand periods over the most recent five-year period. Methodology consistent with thermal unit transition rates.</p>	Same method
18	Proposed front-of-meter <b>Battery Storage</b>	GE MARS ‘ES’ model is used. Units are given a maximum capacity, maximum stored energy, and a dispatch window.	Same method
19	Existing Energy Limited Resources ( <b>ELRs</b> )	<p>GE developed MARS functionality to be used for ELRs.</p> <p>Resource output is aligned with the NYISO’s peak load window when most loss-of-load events are expected to occur.</p>	Same method
Transaction – Imports/ Exports			


	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
1	Capacity Purchases	Grandfathered Rights and other awarded long-term rights  Modeled using MARS explicit contracts feature.	Same method
2	Capacity Sales	These are long-term contracts filed with FERC.  Modeled using MARS explicit contracts feature. Contracts sold from ROS (Zones: A-F). ROS ties to external pool are derated by sales MW amount	Same method
3	FCM Sales	Model sales for known years  Modeled using MARS explicit contracts feature. Contracts sold from ROS (Zones: A-F). ROS ties to external pool are derated by sales MW amount	Same method
4	UDRs	Updated with most recent elections/awards information (VFT, HTP, Neptune, CSC)  Added CHPE HVDC (from Hydro Quebec into Zone J) at 1250 MW (summer only) starting 2026.	Same method
5	External Deliverability Rights (EDRs)	<b>Cedars Uprate 80 MW.</b> Modeled reflecting External CRIS rights.	Same method
6	Wheel-Through Contract	<b>300 MW HQ through NYISO to ISO-NE.</b> Modeled as firm contract; reduced the transfer limit from HQ to NYISO by 300 MW and increased the transfer limit from NYISO to ISO-NE by 300 MW.	Same method
<b>MARS Topology:</b> a simplified bubble-and-pipe representation of the transmission system			
1	Interface Limits	Developed by review of previous studies and specific analysis during the RNA study process.	Same method
2	New Transmission	Based on TO-provided firm plans (via Gold Book/LTP 2023-2024 processes) and proposed merchant transmission facilities meeting the RNA Base Case inclusion rules.	Same method
3	AC Cable Forced Outage Rates	All existing cable transition rates updated with data received from ConEd and PSEG-LIPA to reflect most recent five-year history.	Same method
4	UDR unavailability	Five-year history of forced outages.	Same method
<b>Emergency Operating Procedures (EOPs)</b>			
1	EOP Steps Order	<b>New order:</b> Implementing NYSRC ICS/EC November 9, 2023 decision for the new EOP order recommendation: <ol style="list-style-type: none"> <li>1. Removing Operating Reserve</li> <li>2. Special Case Resources (SCRs) (Load and Generator)</li> <li>3. 5% Manual Voltage Reduction</li> <li>4. 30-Minute Operating Reserve to Zero</li> <li>5. Voluntary Load Curtailment</li> <li>6. Public Appeals</li> <li>7. 5% Remote Controlled Voltage Reduction</li> <li>8. Emergency Assistance from External Areas</li> <li>9. Part of the 10-Minute Operating Reserve (910 MW of 1310 MW) to Zero</li> </ol>	Same method

	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
2	Special Case Resources (SCR)	<p>SCRs sold for the program discounted to historic availability (“effective capacity”). Monthly variation based on historical experience.</p> <p>Summer values calculated from the latest available July registrations (July 2023 SCR enrollment) held constant for all years of study.</p> <p><b>New Method:</b></p> <p>SCRs are modeled as duration-limited resources. The duration limited units are constrained to be called once in a day when a loss of load event occurs, and are invoked between 5 and 7 hours (defined by zone), which is determined based on historical SCR performance in the applicable zone. Hourly response rates are used. The contribution by the SCRs vary monthly by applicable zone. These monthly values are also derived from historical performance of the SCRs. Additional details in the January 3, 2024 ICS/ICAP presentation <a href="#">[link]</a> and May 1, 2024 ICS <a href="#">[link]</a>.</p>	Same method
3	EDRP Resources	Not modeled if the values are less than 2 MW.	Same
4	Operating Reserves	<p>655 MW 30-min reserve to zero 910 MW (of 1310 MW) 10-min reserve to zero</p> <p>Note: the 10-min reserve modeling method is updated per NYISO’s recommendation (approved at the Oct. 3, 2023 NYSRC ICS <a href="#">[link]</a>) to maintain (or no longer deplete/use) 400 MW of the 1,310 MW 10-min operating reserve at the applicable EOP step. Therefore, the 10-min operating reserve MARS EOP step will use, as needed each MARS replication: 910 MW (=1,310 MW–400 MW).</p>	Same
5	Other EOPs (e.g., manual voltage reduction, voltage curtailments, public appeals, external assistance, as listed above)	Based on TO information, measured data, and NYISO forecasts. Will use 2024 elections, as available.	Same method
1	PJM	Simplified model: The 5 PJM MARS areas (bubbles) were consolidated into one starting 2020 RNA. As per RNA procedure.	Same method
2	ISONE	Simplified model: The 8 ISO-NE MARS areas (bubbles) were consolidated into one starting 2020 RNA	Same method
3	HQ	Per RNA Procedure.	Same method
4	IESO	Per RNA procedure.	Same method


	Parameter	2024 RNA Base Cases Key Assumptions (2024 Gold Book)	2025 Q1 STAR 2024 Q3, Q4 STAR Key Assumptions (2024 GB)
5	Reserve Sharing	All NPCC Control Areas indicate that they will share reserves equally among all members before sharing with PJM.	Same method
6	NYCA Emergency Assistance Limit	Implemented a statewide limit of 3,500 MW, additional to the “pipe” limits.	Same method
<b>Miscellaneous</b>			
1	MARS Model Version	4.14.2179	Same



## 2024 RNA MARS Topology<sup>27</sup>



MARS Topology for 2024 RNA Base Cases: Study Year 1 (2025)



MARS Topology for 2024 RNA Base Cases: Study Years 2 through 5 (2026-2029) (with CHPE)

<sup>27</sup> This is the MARS topology used for 2024 Reliability Needs Assessment studies and is not fully re-evaluated for each quarterly STAR.

## Appendix E: Transmission Security Margin Assessment

### Introduction

The purpose of this assessment is to identify plausible changes in conditions or assumptions that might adversely impact the reliability of the BPTF or “tip” the system into a violation of a transmission security criterion. This assessment is performed using a deterministic approach through a spreadsheet-based method using input from the 2024 Gold Book and the projects that meet the reliability planning inclusion rules for the 2025 Q1 STAR. At the May 5, 2022<sup>28</sup> and May 23, 2022<sup>29</sup> joint meetings of the Transmission Planning Advisory Subcommittee (TPAS) and the Electric System Planning Working Group (ESPWG), the NYISO discussed with stakeholders several enhancements to its reliability planning practices. The proposed changes to reliability planning practices include: (1) modeling intermittent resources according to their expected availability coincident with the represented system condition, (2) accounting for the availability of thermal generation based on NERC class average five-year outage rate data in transmission security assessments, and (3) incorporating the ability to identify reliability needs through the spreadsheet-based method of calculating transmission security margins (a.k.a. “tipping points”) within the Lower Hudson Valley (Zones G-J), New York City (Zone J), and Long Island (Zone K) localities, as well as other enhancements to reliability planning practices. At its June 23, 2022, meeting, the Operating Committee approved revisions to the Reliability Planning Process Manual that reflect these enhancements. For this assessment, the margins are evaluated statewide as well as Lower Hudson Valley, New York City, and Long Island localities.

A BPTF reliability need is identified when the transmission security margin under expected weather conditions in the Lower Hudson Valley, New York City, and Long Island localities are less than zero. Additional details regarding the statewide system margin, impact of extreme weather, or other scenario conditions are provided to more fully understand the uncertainties in the assessment.

For the evaluation of winter peak conditions, all gas-only units within the NYCA are assumed unavailable with consideration of firm gas fuel contracts. Dual-fuel units with gas-only duct-burn capability are assumed to be available at a lower capacity, accounting for the unavailability of duct-burn. This assessment assumes the remaining units have available fuel for the peak period. This shortage impacts approximately 6,350 MW of gas generation throughout the NYCA.

---

<sup>28</sup> [https://www.nyiso.com/documents/20142/30451285/08\\_Reliability\\_Practices\\_TPAS-ESPWG\\_2022-05-05.pdf/](https://www.nyiso.com/documents/20142/30451285/08_Reliability_Practices_TPAS-ESPWG_2022-05-05.pdf/).

<sup>29</sup> <https://www.nyiso.com/documents/20142/30860639/04%20Response%20to%20SHQuestions%20and%20Feedback%20on%202022%20RNA%202022%20Quarter%20%20STAR.pdf/>.

Transmission security analysis represents discrete snapshots in time of various credible combinations of system conditions. Therefore, the identification of reliability needs only indicate the magnitude of the need (*e.g.*, a thermal overload expressed in terms of percentage of the applicable rating) under those specific system conditions. Additional details are required to fully describe the nature of the need. To describe the nature of the transmission security and statewide system margins more fully, the NYISO uses load shapes to reflect the expected behavior of the load over 24 hours on the summer peak day for the 10-year study horizon. Details of the load shapes are provided later in this appendix.

### Statewide System Margin

The statewide system margin for New York is evaluated under baseline expected weather for summer and winter conditions with normal transfer criteria. The statewide system margin is the ability to meet the forecasted load and largest loss-of-source contingency (*i.e.*, total capacity requirement) against the NYCA generation (including derates) and external area interchanges. The NYCA generation (from line-item A in the following figures) is comprised of the existing generation plus additions of future generation resources, as well as the removal of deactivating generation, that meet the reliability planning process base case inclusion rules. The dispatch of renewable generation is aligned with current transmission planning practices for transmission security. Derates for thermal resources based on their NERC five-year class average EFORD are also included.<sup>30</sup> Additionally, for the statewide system margin, the NYCA generation includes the Oswego export limit with all lines in service.

As shown in Figure 42, under summer peak baseline expected weather load, normal transfer criteria, the statewide system margin (line-item I) ranges between 1,064 MW in 2025 to -12 MW in 2034 with flexible large loads modeled as offline. When flexible large loads are modeled online during the summer peak day, the statewide system margin (line-item I) ranges between 453 MW in 2025 to -1,192 MW in 2034 as shown in Figure 43. Figure 44 shows the statewide system margin for summer with and without the flexible large loads online for comparison. Figure 45 shows the summer peak statewide system margin through the study horizon for baseline load and the impacts of the higher demand load forecast, SCRs, and with full operating reserve with flexible large loads offline. Figure 46 shows the summer peak statewide system margin through the study horizon for baseline load and the impacts of the higher demand load forecast, SCRs, and with full operating reserve and with flexible large loads modeled as online. Figure 47 shows the hourly statewide system margin for the summer peak day for 2025, 2029, and 2034 with flexible large loads online.

As shown in Figure 48, under winter peak baseline expected weather load, normal transfer criteria, the

---

<sup>30</sup> [NERC five-year class average EFORD data](#)

statewide system margin (line-item J) ranges between 4,221 MW in 2025 to -2,283 MW in 2034 with flexible large loads modeled as offline. When flexible large loads are modeled as online during the winter peak day, the statewide system margin (line-item J) ranges between 3,459 MW in 2025 to -3463 in 2034 as shown in Figure 49. Figure 50 shows the statewide system margin for winter with and without the flexible large loads online for comparison. Figure 51 shows the winter peak statewide system margin through the study horizon for baseline load and the impacts of, SCRs, with full operating reserve and with flexible large loads modeled as offline. Figure 52 shows the winter peak statewide system margin through the study horizon for baseline load and the impacts of SCRs, and with full operating reserve and with flexible large loads modeled as online.

The decreasing statewide system margin in both summer and winter can be attributed to increasing demand that is not matched by incoming proposed generation that meets inclusion rules. Additionally, the unavailability of non-firm gas is a key driver of deficient statewide margins in the winter peak condition. A negative statewide system margin is not, on its own, a violation of the Reliability Criteria. It is, however, a leading indicator that the system is unable to securely meet system load under applicable normal transfer criteria, which is observed in the RNA transmission security results as described previously in this appendix.

**Figure 42: Summer Peak Statewide System Margin Calculation (Flexible Large Loads Offline)**

Line	Item	Summer Peak - Baseline Expected Summer Weather, Normal Transfer Criteria (MW)									
		2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
A	NYCA Generation (1)	38,045	39,069	39,885	39,885	39,885	39,885	39,429	39,429	39,429	39,429
B	NYCA Generation Derates (2)	(6,476)	(7,419)	(8,165)	(8,187)	(8,198)	(8,210)	(8,173)	(8,184)	(8,195)	(8,195)
C	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
D	External Area Interchanges (3)	1,844	3,094	3,094	3,094	3,094	3,094	3,094	3,094	3,094	3,094
E	<b>Total Resources (A+B+C+D)</b>	33,413	34,743	34,814	34,791	34,780	34,769	34,351	34,339	34,328	34,328
F	Demand Forecast (5)	(31,039)	(30,902)	(30,930)	(30,950)	(31,160)	(31,400)	(31,700)	(32,140)	(32,650)	(33,030)
G	Largest Loss-of-Source Contingency	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
H	<b>Total Capability Requirement (F+G)</b>	(32,349)	(32,212)	(32,240)	(32,260)	(32,470)	(32,710)	(33,010)	(33,450)	(33,960)	(34,340)
I	<b>Statewide System Margin (E+H)</b>	1,064	2,531	2,574	2,531	2,310	2,059	1,341	889	368	(12)
J	Higher Demand Impact	(550)	(1,010)	(1,340)	(1,810)	(2,060)	(2,330)	(2,600)	(2,810)	(2,980)	(3,270)
K	<b>Higher Demand Statewide System Margin (I+J)</b>	514	1,521	1,234	721	250	(271)	(1,259)	(1,921)	(2,612)	(3,282)
L	SCRs (6), (7)	989	989	989	989	989	989	989	989	989	989
M	<b>Statewide System Margin with SCR (K+L)</b>	1,503	2,511	2,223	1,711	1,239	718	(270)	(931)	(1,623)	(2,293)
N	Operating Reserve	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
O	<b>Statewide System Margin with Full Operating Reserve (M+N) (4)</b>	193	1,201	913	401	(71)	(592)	(1,580)	(2,241)	(2,933)	(3,603)

**Notes:**

1. Reflects the 2024 Gold Book existing summer capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 15% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2024 Gold Book Table I-9a) and solar PV peak reductions (2024 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class
3. Interchanges are based on ERAG MMWG values.
4. For informational purposes.
5. Reflects the 2024 Gold Book Forecast with flexible large loads considered offline.
6. SCRs are not applied for transmission security analysis of normal operations, but are included for emergency operations.
7. Includes a derate of 384 MW for SCRs


**Figure 43: Summer Peak Statewide System Margin Calculation (Flexible Large Loads Online)**

Line	Item	Summer Peak - Baseline Expected Summer Weather, Normal Transfer Criteria (MW)									
		2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
A	NYCA Generation (1)	38,045	39,069	39,885	39,885	39,885	39,885	39,429	39,429	39,429	39,429
B	NYCA Generation Derates (2)	(6,476)	(7,419)	(8,165)	(8,187)	(8,198)	(8,210)	(8,173)	(8,184)	(8,195)	(8,195)
C	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
D	External Area Interchanges (3)	1,844	3,094	3,094	3,094	3,094	3,094	3,094	3,094	3,094	3,094
E	<b>Total Resources (A+B+C+D)</b>	33,413	34,743	34,814	34,791	34,780	34,769	34,351	34,339	34,328	34,328
F	Demand Forecast (5)	(31,650)	(31,900)	(32,110)	(32,130)	(32,340)	(32,580)	(32,880)	(33,320)	(33,830)	(34,210)
G	Largest Loss-of-Source Contingency	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
H	<b>Total Capability Requirement (F+G)</b>	(32,960)	(33,210)	(33,420)	(33,440)	(33,650)	(33,890)	(34,190)	(34,630)	(35,140)	(35,520)
I	<b>Statewide System Margin (E+H)</b>	453	1,533	1,394	1,351	1,130	879	161	(291)	(812)	(1,192)
J	Higher Demand Impact	(550)	(1,010)	(1,340)	(1,810)	(2,060)	(2,330)	(2,600)	(2,810)	(2,980)	(3,270)
K	<b>Higher Demand Statewide System Margin (I+J)</b>	(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
L	SCRs (6), (7)	989	989	989	989	989	989	989	989	989	989
M	<b>Statewide System Margin with SCR (K+L)</b>	892	1,513	1,043	531	59	(462)	(1,450)	(2,111)	(2,803)	(3,473)
N	Operating Reserve	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
O	<b>Statewide System Margin with Full Operating Reserve (M+N) (4)</b>	(418)	203	(267)	(779)	(1,251)	(1,772)	(2,760)	(3,421)	(4,113)	(4,783)


**Notes:**

1. Reflects the 2024 Gold Book existing summer capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 15% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2024 Gold Book Table I-9a) and solar PV peak reductions (2024 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Interchanges are based on ERAG MMWG values.
4. For informational purposes.
5. Reflects the 2024 Gold Book Forecast.
6. SCRs are not applied for transmission security analysis of normal operations, but are included for emergency operations.
7. Includes a derate of 384 MW for SCRs

Figure 44: Summer Peak Statewide System Margin – Flexible Large Loads Comparison



**Figure 45: Summer Peak Statewide System Margin Chart (Flexible Large Loads Offline)**





**Figure 46: Summer Peak Statewide System Margin Chart (Flexible Large Loads Online)**





Figure 47: Summer Peak Statewide System Hourly Margin Chart



**Figure 48: Winter Peak Statewide System Margin Calculation (Flexible Large Loads Offline)**

Line	Item	Winter Peak - Baseline Expected Winter Weather, Normal Transfer Criteria (MW)									
		2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	2034-35
A	NYCA Generation (1)	40,980	42,720	42,720	42,720	42,720	42,262	42,262	42,262	42,262	42,262
B	NYCA Generation Derates (2)	(6,417)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)
C	Unavailability of Non-Firm Gas (6)	(6,319)	(6,319)	(6,319)	(6,319)	(6,319)	(5,861)	(5,861)	(5,861)	(5,861)	(5,861)
D	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
E	External Area Interchanges (3)	735	735	735	735	735	735	735	735	735	735
F	<b>Total Resources (A+B+C+D+E)</b>	28,979	29,327	29,327	29,327	29,327	29,327	29,327	29,327	29,327	29,327
G	Demand Forecast (5)	(23,448)	(23,622)	(24,090)	(24,580)	(25,170)	(25,840)	(26,720)	(27,670)	(28,770)	(30,300)
H	Largest Loss-of-Source Contingency	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
I	<b>Total Capability Requirement (G+H)</b>	(24,758)	(24,932)	(25,400)	(25,890)	(26,480)	(27,150)	(28,030)	(28,980)	(30,080)	(31,610)
J	<b>Statewide System Margin (F+I)</b>	4,221	4,395	3,927	3,437	2,847	2,177	1,297	347	(753)	(2,283)
K	SCRs (7), (8)	684	684	684	684	684	684	684	684	684	684
L	<b>Statewide System Margin with SCR (J+K)</b>	4,905	5,079	4,611	4,121	3,531	2,861	1,981	1,031	(69)	(1,599)
M	Operating Reserve	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
N	<b>Statewide System Margin with Full Operating Reserve (L+M) (4)</b>	3,595	3,769	3,301	2,811	2,221	1,551	671	(279)	(1,379)	(2,909)

**Notes:**

1. Reflects the 2024 Gold Book existing winter capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 10% of the total nameplate, off-shore wind at 20% of the total nameplate. For winter the expected solar PV output at peak is 0 MW. Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Interchanges are based on ERAG MMWG values.
4. For informational purposes.
5. Reflects the 2024 Gold Book Forecast with flexible large loads offline.
6. Includes all gas only units that do not have a firm gas contract. Also includes reductions in units with duct burner capabilities. Duct burner derates on dual fuel combined cycle units with non-firm gas account for approximately 500 MW of derated capacity.
7. SCRs are not applied for transmission security analysis of normal operations, but are included for emergency operations.
8. Includes a derate of 221 MW for SCRs.


**Figure 49: Winter Peak Statewide System Margin Calculation (Flexible Large Loads Online)**

Line	Item	Winter Peak - Baseline Expected Winter Weather, Normal Transfer Criteria (MW)									
		2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	2034-35
A	NYCA Generation (1)	40,980	42,720	42,720	42,720	42,720	42,262	42,262	42,262	42,262	42,262
B	NYCA Generation Derates (2)	(6,417)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)	(7,809)
C	Unavailability of Non-Firm Gas (6)	(6,319)	(6,319)	(6,319)	(6,319)	(6,319)	(5,861)	(5,861)	(5,861)	(5,861)	(5,861)
D	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
E	External Area Interchanges (3)	735	735	735	735	735	735	735	735	735	735
F	<b>Total Resources (A+B+C+D+E)</b>	28,979	29,327	29,327	29,327	29,327	29,327	29,327	29,327	29,327	29,327
G	Demand Forecast (5)	(24,210)	(24,730)	(25,270)	(25,760)	(26,350)	(27,020)	(27,900)	(28,850)	(29,950)	(31,480)
H	Largest Loss-of-Source Contingency	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
I	<b>Total Capability Requirement (G+H)</b>	(25,520)	(26,040)	(26,580)	(27,070)	(27,660)	(28,330)	(29,210)	(30,160)	(31,260)	(32,790)
J	<b>Statewide System Margin (F+I)</b>	3,459	3,287	2,747	2,257	1,667	997	117	(833)	(1,933)	(3,463)
K	SCRs (7), (8)	684	684	684	684	684	684	684	684	684	684
L	<b>Statewide System Margin with SCR (J+K)</b>	4,143	3,971	3,431	2,941	2,351	1,681	801	(149)	(1,249)	(2,779)
M	Operating Reserve	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
N	<b>Statewide System Margin with Full Operating Reserve (L+M) (4)</b>	2,833	2,661	2,121	1,631	1,041	371	(509)	(1,459)	(2,559)	(4,089)


**Notes:**

1. Reflects the 2024 Gold Book existing winter capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 10% of the total nameplate, off-shore wind at 20% of the total nameplate. For winter the expected solar PV output at peak is 0 MW. Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Interchanges are based on ERAG MMWG values.
4. For informational purposes.
5. Reflects the 2024 Gold Book Forecast.
6. Includes all gas only units that do not have a firm gas contract. Also includes reductions in units with duct burner capabilities. Duct burner derates on dual fuel combined cycle units with non-firm gas account for approximately 500 MW of derated capacity.
7. SCRs are not applied for transmission security analysis of normal operations, but are included for emergency operations.
8. Includes a derate of 221 MW for SCRs.


Figure 50: Winter Peak Statewide System Margin – Flexible Large Loads Comparison



**Figure 51: Winter Peak Statewide System Margin Chart (Flexible Large Loads Offline)**



**Figure 52: Winter Peak Statewide System Margin Chart (Flexible Large Loads Online)**



### **Lower Hudson Valley (Zones G-J)**

The Lower Hudson Valley or southeastern New York (SENY) locality comprises Zones G-J and includes the electrical connections to the RECO load in PJM. To determine the transmission security margin for this area, the NYISO determines the most limiting combination of two non-simultaneous contingency events (N-1-1) to the transmission security margin. As the system changes, the limiting contingency combination may also change.

In summer 2025, the limiting contingency combination is the loss of Ravenswood 3 followed by the loss of Pleasant Valley-Wood St. 345 kV (F30/F31). Starting in summer 2026, the limiting contingency combination changes to the loss of Knickerbocker – Pleasant Valley 345 kV followed by the loss of Athens-Van Wagner 345 kV (91). The limiting contingency combination for winter throughout the study period is the loss of Ravenswood 3 followed by the loss of Pleasant Valley-Wood St. 345 kV (F30/F31).

Figure 53 and Figure 54 show the calculation of the summer and winter Lower Hudson Valley transmission security margin for baseline expected weather, expected load conditions for the statewide coincident peak hour with normal transfer criteria. Figure 55 summarizes the margin calculation tables. The Lower Hudson Valley maintains positive transmission security margins throughout the STAR study horizon.



**Figure 53: Summer Peak Lower Hudson Valley Margin Calculation**

Summer Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
	Item	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
A	G-J Demand Forecast	(15,066)	(15,118)	(15,179)	(15,244)	(15,323)	(15,414)	(15,535)	(15,701)	(15,891)	(16,056)
B	RECO Demand	(419)	(419)	(419)	(419)	(419)	(419)	(419)	(419)	(419)	(419)
C	<b>Total Demand (A+B)</b>	(15,485)	(15,537)	(15,598)	(15,663)	(15,742)	(15,833)	(15,954)	(16,120)	(16,310)	(16,475)
D	UPNY-SENY Limit (3)	5,700	4,700	4,700	4,700	4,700	4,500	4,500	4,500	4,500	4,500
E	ABC PARs to J	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)
F	K - SENY	47	47	0	47	47	185	99	44	(33)	(96)
G	<b>Total SENY AC Import (D+E+F)</b>	5,736	4,736	4,689	4,736	4,736	4,674	4,588	4,533	4,456	4,393
H	Loss of Source Contingency	(987)	0	0	0	0	0	0	0	0	0
I	<b>Resource Need (C+G+H)</b>	(10,737)	(10,801)	(10,909)	(10,927)	(11,006)	(11,159)	(11,366)	(11,587)	(11,854)	(12,082)
J	G-J Generation (1)	13,054	13,054	13,870	13,870	13,870	13,870	13,460	13,460	13,460	13,460
K	G-J Generation Derates (2)	(1,225)	(1,228)	(1,965)	(1,967)	(1,970)	(1,971)	(1,930)	(1,931)	(1,931)	(1,933)
L	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
M	Net ICAP External Imports	315	1,565	1,565	1,565	1,565	1,565	1,565	1,565	1,565	1,565
N	<b>Total Resources Available (J+K+L+M)</b>	12,145	13,392	13,470	13,469	13,466	13,464	13,096	13,094	13,094	13,093
O	<b>Transmission Security Margin (I+N)</b>	1,408	2,590	2,561	2,542	2,460	2,305	1,730	1,507	1,240	1,011
P	Higher Demand Impact	(215)	(334)	(454)	(583)	(711)	(849)	(968)	(1,071)	(1,159)	(1,278)
Q	<b>Higher Demand Transmission Security Margin (O+P)</b>	1,193	2,256	2,107	1,959	1,749	1,456	762	436	81	(267)

Notes:

1. Reflects the 2024 Gold Book existing summer capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 10% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2024 Gold Book Table I-9a) and solar PV peak reductions (2024 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Limits for 2025 are based on the summer peak 2025 representations evaluated in the post-2020 RNA updates. Limits for 2026 through 2029 are based on summer peak 2029 representations evaluated in the 2024 RNA. Limits for 2030 through 2034 are based on the summer peak 2034 representations evaluated in the 2024 RNA.


**Figure 54: Winter Peak Lower Hudson Valley Margin Calculation**

Winter Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
	Item	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	2034-35
A	G-J Demand Forecast	(10,327)	(10,446)	(10,587)	(10,765)	(10,962)	(11,185)	(11,603)	(12,029)	(12,398)	(13,127)
B	RECO Demand	(231)	(231)	(231)	(243)	(243)	(243)	(243)	(243)	(248)	(248)
C	<b>Total Demand (A+B)</b>	(10,558)	(10,677)	(10,818)	(11,008)	(11,205)	(11,428)	(11,846)	(12,272)	(12,646)	(13,375)
D	UPNY-SENY Limit (3)	5,700	5,300	5,300	5,300	5,300	5,700	5,700	5,700	5,700	5,700
E	ABC PARs to J	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)
F	K - SENY	47	47	47	47	47	1,013	1,013	1,013	1,013	1,013
G	<b>Total SENY AC Import (D+E+F)</b>	5,736	5,336	5,336	5,336	5,336	6,702	6,702	6,702	6,702	6,702
H	Loss of Source Contingency	(968)	(1,090)	(1,090)	(1,090)	(1,090)	(1,090)	(1,090)	(1,090)	(1,090)	(1,090)
I	<b>Resource Need (C+G+H)</b>	(5,790)	(6,431)	(6,572)	(6,762)	(6,959)	(5,816)	(6,234)	(6,660)	(7,034)	(7,763)
J	G-J Generation (1)	14,530	15,346	15,346	15,346	15,346	14,934	14,934	14,934	14,934	14,934
K	G-J Generation Derates (2)	(1,166)	(1,819)	(1,819)	(1,819)	(1,819)	(1,818)	(1,818)	(1,818)	(1,818)	(1,818)
L	Shortage of Gas Fuel Supply (4)	(2,495)	(2,495)	(2,495)	(2,495)	(2,495)	(2,084)	(2,084)	(2,084)	(2,084)	(2,084)
M	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
N	Net ICAP External Imports	315	315	315	315	315	315	315	315	315	315
O	<b>Total Resources Available (J+K+L+M+N)</b>	11,184	11,347	11,347	11,347	11,347	11,348	11,348	11,348	11,348	11,348
P	<b>Transmission Security Margin (I+O)</b>	5,394	4,916	4,775	4,585	4,388	5,532	5,114	4,688	4,314	3,585

**Notes:**

1. Reflects the 2024 Gold Book existing winter capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 10% of the total nameplate, off-shore wind at 20% of the total nameplate. For winter the expected solar PV output at peak is 0 MW. Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023
3. Limits for 2025-26 are based on the summer peak 2025 representations evaluated in the post-2020 RNA updates (as a conservative winter peak assumption these limits utilize the summer values). Limits for 2026-27 through 2029-30 are based on winter peak 2029-30 representations evaluated in the 2024 RNA. Limits for 2030-31 through 2034-35 are based on the winter peak 2034-35 representations evaluated in the 2024 RNA.
4. Unavailability of non-firm gas is modeled per NYSRC Reliability Rule 154a which became effective May 2024. Includes all gas only units that do not have a firm gas contract. Also includes reductions in units with duct burner capabilities.

**Figure 55: Lower Hudson Valley Margin Chart – Summer and Winter**



## New York City (Zone J)

The New York City locality comprises Zone J. Within the Con Edison service territory, the 345 kV transmission system, along with specific portions of the 138 kV transmission system, is designed for the occurrence of two non-simultaneous contingencies and a return to normal (N-1-1-0).<sup>31</sup> Therefore, unlike the Lower Hudson Valley and Long Island localities, the New York City transmission security margin is calculated based on the most limiting N-1-1-0 contingency combination. As the system changes, the limiting contingency combination may also change.

In summer 2025, the most limiting N-1-1-0 contingency combination is the loss of Ravenswood 3 followed by the loss of Mott Haven – Rainey 345 kV (Q12). Starting in summer 2026 and continuing throughout the remainder of the study period, the limiting contingency combination changes to the loss of the CHPE HVDC cable followed by the loss of Ravenswood 3. In winter 2025-2026 through winter 2029-2030, the limiting contingency combination is the loss of Ravenswood 3 followed by the loss of Mott Haven – Rainey 345 kV (Q12). Starting in winter 2030-2031 and continuing throughout the remainder of the study period, the limiting contingency combination changes to the loss of Ravenswood 3 followed by the loss of Bayonne. The CHPE cable is not included in limiting contingencies in winter due to the assumption that following the in-service status of CHPE in December 2025, it is scheduled at 0 MW for the winter seasons.

This assessment recognizes that there is uncertainty in the demand forecast driven by uncertainties in key assumptions such as population and economic growth, energy efficiency, the installation of BtM renewable energy resources, and electric vehicle adoption and charging patterns. These risks are considered in the transmission security margin calculations by incorporating the lower and higher forecast bounds as a range of conditions during expected weather, as shown in Figure 56. Baseline demand lies approximately in the middle of the uncertainty band and is used for the baseline margin (line-item L) in Figure 57. The upper range of this forecast band is used for the higher demand margin (line-item N). Heatwave conditions, also shown in Figure 56 are separate single forecasts.

Figure 57 shows the calculation of the New York City transmission security margin at the statewide coincident peak hour for baseline expected weather and expected load conditions for summer with normal transfer criteria. The New York City transmission security margin coincident with the statewide system peak ranges from 489 MW in summer 2026, increases to 580 in summer 2030, decreases to -17 MW by summer 2033, and decreases further to -97 MW by summer 2034 (line-item L). Figure 58 plots the summer margin results under baseline and high forecast demand levels. As shown in Figure 59, major drivers of the

<sup>31</sup> [Con Edison, TP-7100-18 Transmission Planning Criteria, dated August 2019.](#)

New York City margin results throughout the study period include the addition of the CHPE project, planned removal of certain NYPA generators by the summer of 2031, moderate increases in the baseline demand forecast, and significant forecast uncertainty in later study years.

The figures below also show a margin deficiency in summer 2025. This reflects the margin result without the capacity provided by certain units that are temporarily retained to continue to operate past May 2025 under the Peaker Rule to address a Near-Term Reliability Need identified in the 2023 Q2 STAR. With the retention of these generators, the New York City locality has a positive transmission security margin in 2025 under expected summer weather peak demand periods. Summer 2026 margins are positive without these retained generators due to the CHPE project's planned in-service date.

As transmission security analysis represents discrete snapshots in time of various credible combinations of system conditions, when reliability needs are identified only the magnitude of the need can be identified under those system conditions. Additional details are required to fully describe the nature of the need such as evaluating the hourly load shape and its impact on the need. To describe the nature of the New York City transmission security margin, load shapes are developed for the Zone J component of the statewide load shape. For this assessment, load shapes are not developed past 2034 and are only developed for the summer conditions.

Utilizing the load shape for the baseline expected weather summer peak day, the New York City transmission security margin for each hour is shown in Figure 60 for the 2025 summer peak day without the capacity provided by the Gowanus and Narrows barges and Figure 61 for the 2025 summer peak day with the capacity provided by those units. The hourly margins are created by using the load curve forecast for each hour in the margin calculation (Figure 57 line-item A) with additional adjustments to account for the appropriate derate for solar generation and energy limited resources in each hour (Figure 57 line-item H). All other values in the margin calculation are held constant. Hourly margin data for all years within the study period is tabulated in Figure 64.

Under the baseline forecast for coincident summer peak demand, the New York City transmission security margin would be deficient starting in 2033 with the deficiency of 17 MW for one hour and growing to 97 MW for three hours in 2034. The New York City transmission security margin for each hour is shown in Figure 62 for the 2033 summer peak day and Figure 63 for the 2034 summer peak day for the baseline forecast and high demand forecast. Accounting for uncertainties in key demand forecast assumptions, the higher bound of expected demand under baseline weather conditions (95 degrees Fahrenheit) in 2034 results in a deficiency of up to 1,137 MW over 11 hours.


Certain scenarios of extreme weather or adverse system changes present risks of worsened summer

transmission security margins in New York City. Figure 65 and Figure 66 provide a summary of expected margins under these risk scenarios. Extreme weather scenarios include a 1-in-10-year heatwave and a 1-in-100-year heatwave, resulting in load levels higher than the baseline summer peak forecast. Under a 1-in-10-year heatwave, positive margins are maintained until the summer of 2031. Under a 1-in-100-year heatwave, margins are negative throughout the study period. Other risk scenarios examine the impact of adverse changes to the planned system. Delay of the CHPE HVDC transmission project results in negative margins throughout the study period if delayed indefinitely, or until a hypothetical delayed in-service date.

In addition to the risk scenarios noted above, the retirement of certain key generators or groups of generators may result in a degraded transmission security margin. Considering the summer baseline peak load transmission security margin, several different single generator outages (or combinations of generator outages) including whole plant outages, within New York City beyond those included in the STAR Base Case assumptions could result in a deficient transmission security margin. Details of specific generator outage impacts on the New York City transmission security margin are shown in Figure 74 of Appendix F. Note that margin numbers in Figure 74 are based on the high demand forecast rather than the baseline forecast.

Figure 67 shows the New York City transmission security margin calculation under winter peak baseline expected weather load conditions with normal transfer criteria. For winter peak, the margin is sufficient for all years and ranges from 2,629 MW in winter 2025-2026 to 2,319 in winter 2034-35 (line-item L). Results are presented graphically in Figure 68.

**Figure 56: New York City Demand Forecasts and Forecast Uncertainty**



**Figure 57: New York City Transmission Security Margin Calculation – Summer Peak**


Summer Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
Line	Item	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
A	<b>Zone J Demand Forecast (4)</b>	(10,960)	(10,990)	(11,020)	(11,040)	(11,050)	(11,080)	(11,130)	(11,220)	(11,310)	(11,390)
B	I+K to J (3)	3,900	4,700	4,700	4,700	4,700	4,800	4,800	4,800	4,800	4,800
C	ABC PARs to J	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)
D	<b>Total J AC Import (B+C)</b>	3,889	4,689	4,689	4,689	4,689	4,789	4,789	4,789	4,789	4,789
E	Loss of Source Contingency	(987)	(2,237)	(2,237)	(2,237)	(2,237)	(2,237)	(2,237)	(2,237)	(2,237)	(2,237)
F	<b>Resource Need (A+D+E)</b>	(8,058)	(8,538)	(8,568)	(8,588)	(8,598)	(8,528)	(8,578)	(8,668)	(8,758)	(8,838)
G	J Generation (1)	8,104	8,104	8,920	8,920	8,920	8,920	8,510	8,510	8,510	8,510
H	J Generation Derates (2)	(642)	(642)	(1,377)	(1,377)	(1,377)	(1,377)	(1,334)	(1,334)	(1,334)	(1,334)
I	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
J	Net ICAP External Imports	315	1,565	1,565	1,565	1,565	1,565	1,565	1,565	1,565	1,565
K	<b>Total Resources Available (G+H+I+J)</b>	7,777	9,027	9,109	9,109	9,109	9,109	8,741	8,741	8,741	8,741
L	<b>Baseline Transmission Security Margin (F+K)</b>	(281)	489	540	520	510	580	163	73	(17)	(97)
M	Higher Demand Impact	(180)	(280)	(380)	(490)	(610)	(720)	(810)	(880)	(950)	(1,040)
N	<b>Higher Demand Transmission Security Margin (L+M)</b>	(461)	209	160	30	(100)	(140)	(647)	(807)	(967)	(1,137)

Notes:


1. Reflects the 2024 Gold Book existing summer capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 10% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2024 Gold Book Table I-9a) and solar PV peak reductions (2024 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. The limit 2025 is based on the summer peak 2025 representations evaluated in the post-2020 RNA updates. Limits for 2026 through 2029 are based on the summer peak 2029 representations evaluated in the 2024 RNA. Limits for 2030 through 2034 are based on the summer peak 2034 representations evaluated in the 2024 RNA.
4. Reflects the 2024 Gold Book Forecast.




Figure 58: New York City Transmission Security Margin Results – Summer Peak




**Figure 59: New York City Transmission Security Margin Summary – Summer Peak**




**Figure 60: New York City Hourly Transmission Security Margin – 2025 Summer Peak Day – No Retained Peakers**




**Figure 61: New York City Hourly Transmission Security Margin – 2025 Summer Peak Day – With Retained Peakers**



**Figure 62: New York City Hourly Transmission Security Margin – 2033 Summer Peak Day**



**Figure 63: New York City Hourly Transmission Security Margin – 2034 Summer Peak Day**



**Figure 64: New York City Hourly Transmission Security Margin – 2025 through 2034 Summer Peak Days**


Summer Peak - Baseline Expected Summer Weather, Normal Transfer Criteria (MW)											Summer Peak - Higher Policy with Expected Summer Weather, Normal Transfer Criteria (MW)										
J Transmission Security Margin											J Transmission Security Margin										
Hour	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	Hour	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
HB0	2,356	3,022	3,070	3,074	3,074	3,169	2,780	2,719	2,658	2,618	HB0	2,259	2,829	2,787	2,677	2,597	2,598	2,143	2,038	1,924	1,803
HB1	2,694	3,360	3,408	3,414	3,415	3,509	3,121	3,060	2,998	2,961	HB1	2,605	3,180	3,138	3,031	2,957	2,962	2,509	2,409	2,297	2,177
HB2	2,967	3,634	3,682	3,689	3,690	3,784	3,396	3,336	3,274	3,237	HB2	2,884	3,464	3,422	3,317	3,247	3,256	2,806	2,708	2,598	2,480
HB3	3,142	3,810	3,856	3,863	3,863	3,956	3,568	3,507	3,443	3,405	HB3	3,063	3,646	3,605	3,499	3,431	3,441	2,991	2,895	2,785	2,666
HB4	3,184	3,852	3,898	3,903	3,902	3,992	3,602	3,538	3,472	3,431	HB4	3,107	3,690	3,648	3,543	3,473	3,482	3,030	2,932	2,819	2,698
HB5	3,036	3,703	3,747	3,752	3,749	3,836	3,442	3,375	3,304	3,258	HB5	2,955	3,536	3,494	3,385	3,314	3,319	2,862	2,758	2,641	2,513
HB6	2,655	3,322	3,371	3,375	3,373	3,460	3,066	2,996	2,924	2,874	HB6	2,561	3,140	3,099	2,992	2,915	2,917	2,457	2,349	2,227	2,095
HB7	2,123	2,795	2,850	2,857	2,858	2,947	2,553	2,483	2,410	2,358	HB7	2,009	2,587	2,552	2,447	2,368	2,367	1,904	1,791	1,666	1,530
HB8	1,572	2,250	2,316	2,328	2,335	2,428	2,038	1,969	1,899	1,847	HB8	1,433	2,014	1,987	1,888	1,810	1,809	1,344	1,231	1,105	969
HB9	1,124	1,809	1,884	1,901	1,914	2,012	1,623	1,558	1,490	1,437	HB9	963	1,549	1,529	1,436	1,359	1,359	896	780	656	519
HB10	784	1,476	1,559	1,580	1,599	1,702	1,316	1,254	1,191	1,139	HB10	607	1,195	1,184	1,096	1,020	1,023	562	446	323	191
HB11	518	1,215	1,303	1,326	1,351	1,457	1,075	1,017	958	909	HB11	328	919	913	828	751	758	298	184	65	(65)
HB12	295	993	1,086	1,109	1,138	1,246	867	812	757	711	HB12	97	687	683	601	522	531	71	(42)	(160)	(286)
HB13	117	815	907	929	959	1,068	688	635	581	536	HB13	(86)	502	498	414	332	339	(121)	(236)	(353)	(480)
HB14	(34)	660	750	768	795	901	518	462	405	357	HB14	(237)	345	337	250	162	164	(301)	(421)	(542)	(673)
HB15	(156)	531	615	627	646	747	357	295	233	179	HB15	(355)	218	204	108	13	5	(467)	(596)	(724)	(862)
HB16	(278)	398	473	474	485	577	178	107	37	(26)	HB16	(470)	92	66	(40)	(149)	(167)	(650)	(791)	(930)	(1,078)
HB17	(281)	384	447	437	438	518	110	30	(51)	(122)	HB17	(461)	88	51	(67)	(188)	(217)	(714)	(865)	(1,014)	(1,174)
HB18	(165)	489	540	520	510	580	163	73	(17)	(97)	HB18	(330)	209	160	30	(100)	(140)	(647)	(807)	(967)	(1,137)
HB19	54	702	744	717	700	763	340	245	148	64	HB19	(98)	437	381	243	108	63	(450)	(615)	(779)	(956)
HB20	260	905	943	915	895	958	534	437	340	256	HB20	116	651	592	452	317	271	(240)	(404)	(569)	(745)
HB21	521	1,168	1,207	1,183	1,166	1,234	815	724	631	554	HB21	386	922	864	728	600	561	58	(98)	(256)	(425)
HB22	879	1,528	1,569	1,553	1,540	1,613	1,201	1,117	1,031	963	HB22	752	1,294	1,238	1,107	991	960	466	321	174	15
HB23	1,349	2,002	2,044	2,035	2,025	2,104	1,699	1,621	1,541	1,482	HB23	1,233	1,782	1,729	1,604	1,500	1,478	995	863	724	575
Summer Peak - Heatwave, Emergency Transfer Criteria (MW)											Summer Peak - 1-in-100-Year Extreme Heatwave, Emergency Transfer Criteria (MW)										
J Transmission Security Margin											J Transmission Security Margin										
Hour	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	Hour	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
HB0	1,737	2,527	2,593	2,484	2,486	2,582	2,192	2,031	1,994	1,956	HB0	1,423	2,212	2,277	2,170	2,172	2,266	1,876	1,704	1,667	1,627
HB1	2,095	2,887	2,955	2,849	2,852	2,945	2,556	2,401	2,366	2,328	HB1	1,800	2,591	2,659	2,554	2,557	2,649	2,259	2,094	2,058	2,020
HB2	2,378	3,173	3,243	3,139	3,142	3,234	2,845	2,695	2,661	2,624	HB2	2,100	2,893	2,963	2,861	2,863	2,955	2,566	2,406	2,371	2,334
HB3	2,533	3,329	3,400	3,297	3,300	3,390	3,001	2,853	2,818	2,781	HB3	2,265	3,060	3,131	3,029	3,031	3,121	2,731	2,574	2,539	2,500
HB4	2,513	3,308	3,378	3,273	3,275	3,362	2,971	2,821	2,784	2,744	HB4	2,245	3,039	3,108	3,004	3,005	3,093	2,701	2,541	2,504	2,462
HB5	2,284	3,077	3,144	3,035	3,034	3,118	2,724	2,566	2,525	2,479	HB5	2,005	2,796	2,863	2,754	2,754	2,838	2,443	2,275	2,233	2,186
HB6	1,839	2,632	2,700	2,587	2,586	2,670	2,274	2,108	2,065	2,016	HB6	1,542	2,334	2,401	2,288	2,288	2,371	1,975	1,798	1,754	1,703
HB7	1,297	2,097	2,171	2,055	2,057	2,143	1,748	1,573	1,529	1,477	HB7	983	1,781	1,854	1,739	1,741	1,827	1,431	1,245	1,200	1,146
HB8	761	1,572	1,655	1,541	1,550	1,641	1,248	1,069	1,027	975	HB8	429	1,239	1,322	1,209	1,217	1,309	915	724	681	628
HB9	324	1,144	1,235	1,122	1,136	1,232	842	660	620	568	HB9	(24)	795	886	774	789	885	494	300	258	205
HB10	17	843	941	831	852	952	566	384	347	296	HB10	(347)	479	576	467	489	589	202	7	(31)	(82)
HB11	(171)	658	759	651	677	781	398	216	182	134	HB11	(550)	278	378	272	299	403	20	(175)	(210)	(259)
HB12	(281)	548	648	543	574	681	300	119	86	41	HB12	(679)	148	249	146	177	285	(96)	(291)	(325)	(371)
HB13	(397)	426	523	420	452	560	179	(4)	(39)	(83)	HB13	(823)	(1)	97	(5)	28	137	(245)	(442)	(478)	(523)
HB14	(315)	497	587	243	272	379	(5)	(195)	(236)	(282)	HB14	(775)	37	128	(215)	(186)	(78)	(463)	(668)	(710)	(757)
HB15	(470)	330	410	300	324	425	36	(165)	(215)	(265)	HB15	(958)	(159)	(80)	(188)	(164)	(62)	(453)	(669)	(720)	(773)
HB16	(547)	237	302	183	197	289	(110)	(324)	(386)	(445)	HB16	(1,055)	(272)	(207)	(326)	(312)	(220)	(621)	(851)	(915)	(976)
HB17	(489)	280	331	202	205	286	(123)	(350)	(424)	(493)	HB17	(1,002)	(254)	(205)	(314)	(312)	(231)	(642)	(886)	(962)	(1,034)
HB18	(580)	175	210	310	300	369	(51)	(288)	(375)	(452)	HB18	(1,091)	(339)	(306)	(206)	(217)	(149)	(571)	(825)	(915)	(996)
HB19	(391)	358	385	240	222	284	(142)	(383)	(476)	(559)	HB19	(886)	(141)	(115)	(262)	(281)	(220)	(649)	(907)	(1,003)	(1,089)
HB20	(178)	571	598	451	430	491	64	(173)	(266)	(348)	HB20	(651)	95	121	(27)	(49)	11	(419)	(673)	(769)	(854)
HB21	158	915	950	808	791	856	435	210	126	50	HB21	(279)	475	508	366	348	412	(11)	(252)	(339)	(417)
HB22	616	1,382	1,425	1,291	1,278	1,348	934	724	650	582	HB22	216	980	1,021	888	873	943	527	303	227	157
HB23	1,170	1,944	1,995	1,869	1,858	1,934	1,525	1,332	1,268	1,207	HB23	809	1,582	1,630	1,506	1,495	1,569	1,159	953	887	826

**Figure 65: New York City Transmission Security Margin Risks**

New York City Transmission Security Margin Scenarios		2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
-	Base Case with Baseline Forecast	(281)	489	540	520	510	580	163	73	(17)	(97)
1	CHPE Unavailability Scenario	(281)	(311)	(260)	(280)	(290)	(120)	(537)	(627)	(717)	(797)
2	1-in-10 Year Heatwave	(489)	280	331	310	300	369	(51)	(144)	(237)	(320)
3	1-in-100 Year Heatwave	(1002)	(235)	(185)	(206)	(217)	(149)	(571)	(668)	(764)	(850)
<b>Risk Descriptions:</b>											
1. This scenario shows the unavailability of CHPE.											
2. This scenario shows the New York City transmission security margin for the statewide coincident peak hour under the 1-in-10-year heatwave condition with the assumption that the system is using emergency transfer criteria.											
3. This scenario shows the New York City transmission security margin for the statewide coincident peak hour under the 1-in-100-year heatwave condition with the assumption that the system is using emergency transfer criteria.											



Figure 66: New York City Transmission Security Margin Risks




**Figure 67: New York City Transmission Security Margin Calculation – Winter Peak**

Winter Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
Line	Item	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	2034-35
A	<b>Zone J Demand Forecast (4)</b>	(7,410)	(7,490)	(7,560)	(7,660)	(7,770)	(7,910)	(8,230)	(8,540)	(8,730)	(9,250)
B	I+K to J (3), (4)	3,900	3,900	3,900	3,900	3,900	4,900	4,900	4,900	4,900	4,900
C	ABC PARs to J	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)	(11)
D	<b>Total J AC Import (B+C)</b>	3,889	3,889	3,889	3,889	3,889	4,889	4,889	4,889	4,889	4,889
E	Loss of Source Contingency	(996)	(996)	(996)	(996)	(996)	(1,630)	(1,630)	(1,630)	(1,630)	(1,630)
F	<b>Resource Need (A+D+E)</b>	(4,517)	(4,597)	(4,667)	(4,767)	(4,877)	(4,651)	(4,971)	(5,281)	(5,471)	(5,991)
G	J Generation (1)	9,362	10,178	10,178	10,178	10,178	9,766	9,766	9,766	9,766	9,766
H	J Generation Derates (2)	(595)	(1,248)	(1,248)	(1,248)	(1,248)	(1,247)	(1,247)	(1,247)	(1,247)	(1,247)
I	Unavailability of Non-Firm Gas (5)	(1,936)	(1,936)	(1,936)	(1,936)	(1,936)	(1,524)	(1,524)	(1,524)	(1,524)	(1,524)
J	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
K	Net ICAP External Imports	315	315	315	315	315	315	315	315	315	315
L	<b>Total Resources Available (G+H+I+J+K)</b>	7,146	7,309	7,309	7,309	7,309	7,310	7,310	7,310	7,310	7,310
M	<b>Transmission Security Margin (F+L)</b>	2,629	2,712	2,642	2,542	2,432	2,659	2,339	2,029	1,839	1,319

**Notes:**

1. Reflects the 2024 Gold Book existing winter capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 10% of the total nameplate, off-shore wind at 20% of the total nameplate. For winter the expected solar PV output at peak is 0 MW. Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023
3. Limits for 2025-26 are based on the summer peak 2025 representations evaluated in the post-2020 RNA updates (as a conservative winter peak assumption these limits utilize the summer values). Limits for 2026-27 through 2029-30 are based on winter peak 2029-30 representations evaluated in the 2024 RNA. Limits for 2030-31 through 2034-35 are based on the winter peak 2034-35 representations evaluated in the 2024 RNA.
4. Reflects the 2024 Gold Book Forecast.
5. Unavailability of non-firm gas is modeled per NYSRC Reliability Rule 154a which became effective May 2024. Includes all gas only units that do not have a firm gas contract.

**Figure 68: New York City Transmission Security Margin Results - Winter Peak**



## Long Island (Zone K)

The Long Island locality comprises Zone K. Within the PSEG Long Island service territory, the BPTF system (primarily comprised of 138 kV transmission) is designed for N-1-1. To determine the transmission security margin for this area, the most limiting combination of two non-simultaneous contingency events (N-1-1) to the transmission security margin is determined.

For summer 2025 through summer 2029, the most limiting contingency combination is the loss of the Neptune HVDC cable followed by a stuck breaker event at Sprain Brook leading to loss of the Y49 cable. From summer 2030 onward, after the Long Island Public Policy transmission project is in service, the limiting contingency combination changes to the loss of the Y50 cable followed by a stuck breaker event at East Garden City. For winter 2025-2026 through winter 2029-2030, the most limiting contingency combination is the loss of the Neptune HVDC cable followed by a stuck breaker event at Sprain Brook. From winter 2030-2031 onward, after the Long Island Public Policy transmission project is in service, the limiting contingency combination changes to the loss of the Northport 1 unit followed by loss of a Shore Road-Lake Success 138 kV line (367).

Figure 69 and Figure 70 show the calculation of the summer and winter Long Island transmission security margin baseline expected weather, expected load conditions for the statewide coincident peak hour with normal transfer criteria. Figure 71 summarizes the margin calculation tables. Long Island maintains positive transmission security margins throughout the STAR study horizon. Significant increases in transmission security margins are seen after the Long Island Public Policy transmission project is placed in service.

**Figure 69: Summer Peak Long Island Margin Calculation**

Summer Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
Line	Item	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
A	<b>Zone K Demand Forecast (3)</b>	(4,956)	(4,955)	(4,968)	(4,982)	(5,009)	(5,030)	(5,074)	(5,129)	(5,205)	(5,268)
B	I+J to K	900	900	900	900	900	2,200	2,200	2,200	2,200	2,200
C	New England Import (NNC)	0	0	0	0	0	0	0	0	0	0
D	<b>Total K AC Import (B+C)</b>	900	900	900	900	900	2,200	2,200	2,200	2,200	2,200
E	Loss of Source Contingency	(660)	(660)	(660)	(660)	(660)	0	0	0	0	0
F	<b>Resource Need (A+D+E)</b>	(4,716)	(4,715)	(4,728)	(4,742)	(4,769)	(2,830)	(2,874)	(2,929)	(3,005)	(3,068)
G	K Generation (1)	5,097	6,021	6,021	6,021	6,021	6,021	5,976	5,976	5,976	5,976
H	K Generation Derates (2)	(630)	(1,463)	(1,464)	(1,465)	(1,465)	(1,466)	(1,463)	(1,463)	(1,464)	(1,464)
I	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
J	Net ICAP External Imports	660	660	660	660	660	660	660	660	660	660
K	<b>Total Resources Available (G+H+I+J)</b>	5,127	5,218	5,217	5,216	5,216	5,215	5,173	5,173	5,172	5,172
L	<b>Transmission Security Margin (F+K)</b>	411	503	489	474	447	2,385	2,299	2,244	2,167	2,104
M	Higher Demand Impact	(43)	(66)	(80)	(102)	(121)	(157)	(186)	(220)	(244)	(283)
N	<b>Higher Demand Transmission Security Margin (L+M)</b>	368	437	409	372	326	2,228	2,113	2,024	1,923	1,821

**Notes:**

1. Reflects the 2024 Gold Book existing summer capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 10% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2024 Gold Book Table I-9a) and solar PV peak reductions (2024 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORD data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Reflects the 2024 Gold Book Forecast.


**Figure 70: Winter Peak Long Island Margin Calculation**

Winter Peak - Baseline Expected Weather, Normal Transfer Criteria (MW)											
Line	Item	2025-26	2026-27	2027-28	2028-29	2029-30	2030-31	2031-32	2032-33	2033-34	2034-35
A	<b>Zone K Demand Forecast (4)</b>	(3,299)	(3,334)	(3,396)	(3,465)	(3,553)	(3,639)	(3,750)	(3,880)	(4,058)	(4,266)
B	I+J to K (3)	900	900	900	900	900	2,500	2,500	2,500	2,500	2,500
C	New England Import (NNC)	0	0	0	0	0	0	0	0	0	0
D	<b>Total K AC Import (B+C)</b>	900	900	900	900	900	2,500	2,500	2,500	2,500	2,500
E	Loss of Source Contingency	(660)	(660)	(660)	(660)	(660)	(400)	(400)	(400)	(400)	(400)
F	<b>Resource Need (A+D+E)</b>	(3,059)	(3,094)	(3,156)	(3,225)	(3,313)	(1,539)	(1,650)	(1,780)	(1,958)	(2,166)
G	K Generation (1)	5,505	6,429	6,429	6,429	6,429	6,383	6,383	6,383	6,383	6,383
H	K Generation Derates (2)	(634)	(1,374)	(1,374)	(1,374)	(1,374)	(1,374)	(1,374)	(1,374)	(1,374)	(1,374)
I	Shortage of Gas Fuel Supply (5)	(441)	(441)	(441)	(441)	(441)	(395)	(395)	(395)	(395)	(395)
J	Temperature Based Generation Derates	0	0	0	0	0	0	0	0	0	0
K	Net ICAP External Imports	660	660	660	660	660	660	660	660	660	660
L	<b>Total Resources Available (G+H+I+J+K)</b>	5,090	5,275	5,275	5,275	5,275	5,275	5,275	5,275	5,275	5,275
M	<b>Transmission Security Margin (F+L)</b>	2,031	2,181	2,119	2,050	1,962	3,736	3,625	3,495	3,317	3,109

**Notes:**

1. Reflects the 2024 Gold Book existing winter capacity plus projected additions and deactivations.
2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 10% of the total nameplate, off-shore wind at 20% of the total nameplate. For winter the expected solar PV output at peak is 0 MW. Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORd data published August 2023 (<https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx>).
3. Limits for 2025-26 are based on the summer peak 2025 representations evaluated in the post-2020 RNA updates (as a conservative winter peak assumption these limits utilize the summer values). Limits for 2026-27 through 2029-30 are based on winter peak 2029-30 representations evaluated in the 2024 RNA. Limits for 2030-31 through 2034-35 are based on the winter peak 2034-35 representations evaluated in the 2024 RNA.
4. Reflects the 2024 Gold Book Forecast.
5. Unavailability of non-firm gas is modeled per NYSRC Reliability Rule 154a which became effective May 2024. Includes all gas only units that do not have a firm gas contract.

**Figure 71: Long Island Margin Chart – Summer and Winter**



## Appendix F – Additional Outage Impacts to Margins

The figures in this section show the impact of additional generator and plant outages, or Additional Outage Impacts (AOI), on the statewide system margin and transmission security margins for each locality. The impact of the outages is shown relative to the base margins considering the higher demand forecast with flexible large loads modeled online.

- Figure 72: AOI - Statewide System Margin
- Figure 73: AOI - Lower Hudson Valley Transmission Security Margin
- Figure 74: AOI - New York City Transmission Security Margin
- Figure 75: AOI - Long Island Transmission Security Margin



**Figure 72: AOI - Statewide System Margin**

Additional Outage Impacts - Statewide System Margin													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Statewide System Margin Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Jamestown 5, 6 & 7	80.8	(8.48)	72.32	(170)	451	(18)	(531)	(1,002)	(1,523)	(2,512)	(3,173)	(3,864)	(4,534)
Jamestown 5	21.9	(2.30)	19.60	(117)	504	34	(478)	(949)	(1,471)	(2,459)	(3,120)	(3,811)	(4,481)
Jamestown 6	19.1	(2.01)	17.09	(115)	506	37	(476)	(947)	(1,468)	(2,456)	(3,118)	(3,809)	(4,479)
Jamestown 7	39.8	(4.18)	35.62	(133)	488	18	(494)	(965)	(1,487)	(2,475)	(3,136)	(3,827)	(4,497)
Indeck-Yerkes	43.8	(1.94)	41.86	(139)	482	12	(500)	(972)	(1,493)	(2,481)	(3,142)	(3,834)	(4,504)
Indeck-Olean	77.5	(3.43)	74.07	(171)	449	(20)	(533)	(1,004)	(1,525)	(2,513)	(3,175)	(3,866)	(4,536)
American Ref-Fuel 1 & 2	37.6	(3.95)	33.65	(131)	490	20	(492)	(963)	(1,485)	(2,473)	(3,134)	(3,825)	(4,495)
American Ref-Fuel 1	18.8	(1.97)	16.83	(114)	507	37	(475)	(947)	(1,468)	(2,456)	(3,117)	(3,809)	(4,479)
American Ref-Fuel 2	18.8	(1.97)	16.83	(114)	507	37	(475)	(947)	(1,468)	(2,456)	(3,117)	(3,809)	(4,479)
Fortistar - N.Tonawanda (BTM:NG)	53.3	(2.36)	50.94	(148)	472	3	(510)	(981)	(1,502)	(2,490)	(3,151)	(3,843)	(4,513)
Model City Energy	5.6	(0.71)	4.89	(102)	519	49	(463)	(935)	(1,456)	(2,444)	(3,105)	(3,797)	(4,467)
Modern LF	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Chaffee	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Chautauqua LFGE	0.0	0.00	0.00	(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Lockport CC1, CC2, and CC3	208.8	(9.25)	199.55	(297)	324	(146)	(658)	(1,129)	(1,651)	(2,639)	(3,300)	(3,991)	(4,661)
Lockport CC1	69.6	(3.08)	66.52	(164)	457	(13)	(525)	(996)	(1,517)	(2,506)	(3,167)	(3,858)	(4,528)
Lockport CC2	69.6	(3.08)	66.52	(164)	457	(13)	(525)	(996)	(1,517)	(2,506)	(3,167)	(3,858)	(4,528)
Lockport CC3	69.6	(3.08)	66.52	(164)	457	(13)	(525)	(996)	(1,517)	(2,506)	(3,167)	(3,858)	(4,528)
Allegany	62.8	(2.78)	60.02	(157)	463	(6)	(519)	(990)	(1,511)	(2,499)	(3,161)	(3,852)	(4,522)
R. E. Ginna	581.5	(10.99)	570.51	(668)	(47)	(517)	(1,029)	(1,500)	(2,021)	(3,010)	(3,671)	(4,362)	(5,032)
Batavia	47.7	(2.11)	45.59	(143)	478	8	(504)	(975)	(1,497)	(2,485)	(3,146)	(3,837)	(4,507)
Nine Mile Point 2	1,274.7	(27.53)	1,247.17	(1,085)	(465)	(934)	(1,447)	(1,918)	(2,439)	(3,427)	(4,089)	(4,780)	(5,450)
Mill Seat	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Hyland LFGE	4.8	(0.60)	4.20	(102)	519	50	(463)	(934)	(1,455)	(2,444)	(3,105)	(3,796)	(4,466)
Synergy Biogas	0.0	0.00	0.00	(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Red Rochester (BTM:NG)	13.3	(1.40)	11.90	(109)	512	42	(470)	(942)	(1,463)	(2,451)	(3,112)	(3,804)	(4,474)
James A. FitzPatrick	852.8	(18.42)	834.38	(932)	(311)	(781)	(1,293)	(1,764)	(2,285)	(3,274)	(3,935)	(4,626)	(5,296)
Oswego 6	803.0	(84.32)	718.69	(816)	(195)	(665)	(1,177)	(1,648)	(2,170)	(3,158)	(3,819)	(4,510)	(5,180)
Oswego 5	809.5	(85.00)	724.50	(822)	(201)	(671)	(1,183)	(1,654)	(2,175)	(3,164)	(3,825)	(4,516)	(5,186)
Nine Mile Point 1	621.4	(13.42)	607.98	(705)	(85)	(554)	(1,067)	(1,538)	(2,059)	(3,047)	(3,709)	(4,400)	(5,070)
Independence GS1, GS2, GS3, & GS4	980.4	(43.43)	936.97	(1,034)	(414)	(883)	(1,396)	(1,867)	(2,388)	(3,376)	(4,038)	(4,729)	(5,399)
Independence GS1	245.1	(10.86)	234.24	(332)	289	(180)	(693)	(1,164)	(1,685)	(2,674)	(3,335)	(4,026)	(4,696)
Independence GS2	245.1	(10.86)	234.24	(332)	289	(180)	(693)	(1,164)	(1,685)	(2,674)	(3,335)	(4,026)	(4,696)
Independence GS3	245.1	(10.86)	234.24	(332)	289	(180)	(693)	(1,164)	(1,685)	(2,674)	(3,335)	(4,026)	(4,696)
Independence GS4	245.1	(10.86)	234.24	(332)	289	(180)	(693)	(1,164)	(1,685)	(2,674)	(3,335)	(4,026)	(4,696)
Syracuse	83.2	(3.69)	79.51	(177)	444	(26)	(538)	(1,009)	(1,530)	(2,519)	(3,180)	(3,871)	(4,541)
Carr St.-E. Syr	89.8	(3.98)	85.82	(183)	438	(32)	(544)	(1,016)	(1,537)	(2,525)	(3,186)	(3,878)	(4,548)
Indeck-Oswego	51.8	(2.29)	49.51	(147)	474	4	(508)	(979)	(1,500)	(2,489)	(3,150)	(3,841)	(4,511)
Indeck-Silver Springs	51.4	(2.28)	49.12	(147)	474	5	(508)	(979)	(1,500)	(2,488)	(3,150)	(3,841)	(4,511)
Greenidge 4 (BTM:NG)	25.9	(2.72)	23.18	(121)	(1,047)	169	(36)	(240)	(494)	(834)	(1,328)	(1,823)	(2,393)
Ontario LFGE	11.2	(1.41)	9.79	(107)	514	44	(468)	(940)	(1,461)	(2,449)	(3,110)	(3,802)	(4,472)
High Acres	9.6	(1.21)	8.39	(106)	515	45	(467)	(938)	(1,459)	(2,448)	(3,109)	(3,800)	(4,470)
Seneca Energy 1 & 2	17.6	(2.22)	15.38	(113)	508	38	(474)	(945)	(1,466)	(2,455)	(3,116)	(3,807)	(4,477)
Seneca Energy 1	8.8	(1.11)	7.69	(105)	516	46	(466)	(937)	(1,459)	(2,447)	(3,108)	(3,799)	(4,469)
Seneca Energy 2	8.8	(1.11)	7.69	(105)	516	46	(466)	(937)	(1,459)	(2,447)	(3,108)	(3,799)	(4,469)
Broome LFGE	2.4	(0.30)	2.10	(100)	521	52	(461)	(932)	(1,453)	(2,441)	(3,103)	(3,794)	(4,464)
Massena	79.5	(3.52)	75.98	(173)	447	(22)	(535)	(1,006)	(1,527)	(2,515)	(3,177)	(3,868)	(4,538)
Clinton LFGE	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Saranac Energy CC1 & CC2	237.9	(10.54)	227.36	(325)	296	(174)	(686)	(1,157)	(1,678)	(2,667)	(3,328)	(4,019)	(4,689)
Saranac Energy CC1	121.8	(5.40)	116.40	(214)	407	(63)	(575)	(1,046)	(1,567)	(2,556)	(3,217)	(3,908)	(4,578)
Saranac Energy CC2	116.1	(5.14)	110.96	(208)	412	(57)	(570)	(1,041)	(1,562)	(2,550)	(3,212)	(3,903)	(4,573)
Sterling	49.7	(2.20)	47.50	(145)	476	6	(506)	(977)	(1,498)	(2,487)	(3,148)	(3,839)	(4,509)
Carthage Energy	56.4	(2.50)	53.90	(151)	470	(0)	(512)	(984)	(1,505)	(2,493)	(3,154)	(3,846)	(4,516)
Beaver Falls	78.1	(3.46)	74.64	(172)	449	(21)	(533)	(1,004)	(1,526)	(2,514)	(3,175)	(3,866)	(4,536)
Broome 2 LFGE	2.1	(0.26)	1.84	(99)	522	52	(460)	(932)	(1,453)	(2,441)	(3,102)	(3,794)	(4,464)
DANC LFGE	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Oneida-Herkimer LFGE	3.2	(0.40)	2.80	(100)	521	51	(461)	(933)	(1,454)	(2,442)	(3,103)	(3,795)	(4,465)
Athens 1, 2, and 3	993.8	(44.03)	949.77	(1,047)	(426)	(896)	(1,408)	(1,880)	(2,401)	(3,389)	(4,050)	(4,742)	(5,412)
Athens 1	329.4	(14.59)	314.81	(412)	209	(261)	(773)	(1,245)	(1,766)	(2,754)	(3,415)	(4,107)	(4,777)
Athens 2	333.3	(14.77)	318.53	(416)	205	(265)	(777)	(1,248)	(1,769)	(2,758)	(3,419)	(4,110)	(4,780)
Athens 3	331.1	(14.67)	316.43	(414)	207	(263)	(775)	(1,246)	(1,767)	(2,756)	(3,417)	(4,108)	(4,778)
Rensselaer	76.3	(3.38)	72.92	(170)	450	(19)	(531)	(1,003)	(1,524)	(2,512)	(3,173)	(3,865)	(4,535)
Wheelabrator Hudson Falls	10.4	(1.09)	9.31	(107)	514	45	(468)	(939)	(1,460)	(2,449)	(3,110)	(3,801)	(4,471)

Additional Outage Impacts - Statewide System Margin													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Statewide System Margin Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capacity (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Selkirk I & II	353.3	(15.65)	337.65	(435)	186	(284)	(796)	(1,267)	(1,789)	(2,777)	(3,438)	(4,129)	(4,799)
Selkirk-I	76.1	(3.37)	72.73	(170)	451	(19)	(531)	(1,002)	(1,524)	(2,512)	(3,173)	(3,864)	(4,534)
Selkirk-II	277.2	(12.28)	264.92	(362)	258	(211)	(723)	(1,195)	(1,716)	(2,704)	(3,365)	(4,057)	(4,727)
Indeck-Corinth	131.1	(5.81)	125.29	(223)	398	(71)	(584)	(1,055)	(1,576)	(2,565)	(3,226)	(3,917)	(4,587)
Castleton Energy Center	67.9	(3.01)	64.89	(162)	459	(11)	(523)	(995)	(1,516)	(2,504)	(3,165)	(3,857)	(4,527)
Bethlehem GS1, GS2, GS3	818.4	(36.26)	782.14	(880)	(259)	(728)	(1,241)	(1,712)	(2,233)	(3,221)	(3,883)	(4,574)	(5,244)
Bethlehem GS1	272.8	(12.09)	260.71	(358)	263	(207)	(719)	(1,190)	(1,712)	(2,700)	(3,361)	(4,052)	(4,722)
Bethlehem GS2	272.8	(12.09)	260.71	(358)	263	(207)	(719)	(1,190)	(1,712)	(2,700)	(3,361)	(4,052)	(4,722)
Bethlehem GS3	272.8	(12.09)	260.71	(358)	263	(207)	(719)	(1,190)	(1,712)	(2,700)	(3,361)	(4,052)	(4,722)
Colonie LFGTE	6.4	(0.81)	5.59	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
Albany LFGTE	5.6	(0.71)	4.89	(102)	519	49	(463)	(935)	(1,456)	(2,444)	(3,105)	(3,797)	(4,467)
Fulton LFGTE	3.2	(0.40)	2.80	(100)	521	51	(461)	(933)	(1,454)	(2,442)	(3,103)	(3,795)	(4,465)
Empire CC1 & CC2	587.4	(26.02)	561.38	(659)	(38)	(508)	(1,020)	(1,491)	(2,012)	(3,001)	(3,662)	(4,353)	(5,023)
Empire CC1	293.7	(13.01)	280.69	(378)	243	(227)	(739)	(1,210)	(1,732)	(2,720)	(3,381)	(4,072)	(4,742)
Empire CC2	293.7	(13.01)	280.69	(378)	243	(227)	(739)	(1,210)	(1,732)	(2,720)	(3,381)	(4,072)	(4,742)
Bowline 1 & 2	1,143.0	(120.02)	1,022.99	(1,120)	(500)	(969)	(1,482)	(1,953)	(2,474)	(3,462)	(4,124)	(4,815)	(5,485)
Bowline 1	577.8	(60.67)	517.13	(615)	6	(463)	(976)	(1,447)	(1,968)	(2,956)	(3,618)	(4,309)	(4,979)
Bowline 2	565.2	(59.35)	505.85	(603)	18	(452)	(964)	(1,436)	(1,957)	(2,945)	(3,606)	(4,298)	(4,968)
Danskammer 1, 2, 3, & 4	499.4	(52.44)	446.96	(544)	76	(393)	(906)	(1,377)	(1,898)	(2,886)	(3,548)	(4,239)	(4,909)
Danskammer 1	68.5	(7.19)	61.31	(159)	462	(7)	(520)	(991)	(1,512)	(2,501)	(3,162)	(3,853)	(4,523)
Danskammer 2	65.0	(6.83)	58.18	(156)	465	(4)	(517)	(988)	(1,509)	(2,498)	(3,159)	(3,850)	(4,520)
Danskammer 3	140.1	(14.71)	125.39	(223)	398	(72)	(584)	(1,055)	(1,576)	(2,565)	(3,226)	(3,917)	(4,587)
Danskammer 4	225.8	(23.71)	202.09	(299)	321	(148)	(661)	(1,132)	(1,653)	(2,641)	(3,303)	(3,994)	(4,664)
Roseton 1 & 2	1,228.2	(128.96)	1,099.24	(1,197)	(576)	(1,045)	(1,558)	(2,029)	(2,550)	(3,539)	(4,200)	(4,891)	(5,561)
Roseton 1	615.7	(64.65)	551.05	(648)	(28)	(497)	(1,010)	(1,481)	(2,002)	(2,990)	(3,652)	(4,343)	(5,013)
Roseton 2	612.5	(64.31)	548.19	(646)	(25)	(494)	(1,007)	(1,478)	(1,999)	(2,988)	(3,649)	(4,340)	(5,010)
Hillburn GT	36.0	(3.31)	32.69	(130)	491	21	(491)	(962)	(1,484)	(2,472)	(3,133)	(3,824)	(4,494)
Shoemaker GT	35.4	(3.25)	32.15	(130)	491	22	(491)	(962)	(1,483)	(2,471)	(3,133)	(3,824)	(4,494)
DCRRA	6.2	(0.65)	5.55	(103)	518	48	(464)	(935)	(1,457)	(2,445)	(3,106)	(3,797)	(4,467)
CPV Valley CC1 & CC2	645.4	(28.59)	616.81	(714)	(93)	(563)	(1,075)	(1,547)	(2,068)	(3,056)	(3,717)	(4,409)	(5,079)
CPV Valley CC1	322.7	(14.30)	308.40	(406)	215	(255)	(767)	(1,238)	(1,759)	(2,748)	(3,409)	(4,100)	(4,770)
CPV Valley CC2	322.7	(14.30)	308.40	(406)	215	(255)	(767)	(1,238)	(1,759)	(2,748)	(3,409)	(4,100)	(4,770)
Cricket Valley CC1, CC2, & CC3	1,050.8	(46.55)	1,004.25	(1,102)	(481)	(950)	(1,463)	(1,934)	(2,455)	(3,444)	(4,105)	(4,796)	(5,466)
Cricket Valley CC1	347.1	(15.38)	331.72	(429)	192	(278)	(790)	(1,261)	(1,783)	(2,771)	(3,432)	(4,123)	(4,793)
Cricket Valley CC2	345.0	(15.28)	329.72	(427)	194	(276)	(788)	(1,259)	(1,781)	(2,769)	(3,430)	(4,121)	(4,791)
Cricket Valley CC3	358.7	(15.89)	342.81	(440)	181	(289)	(801)	(1,273)	(1,794)	(2,782)	(3,443)	(4,135)	(4,805)
Wheelabrator Westchester	52.5	(5.51)	46.99	(144)	476	7	(506)	(977)	(1,498)	(2,486)	(3,148)	(3,839)	(4,509)
Arthur Kill ST 2 & 3	884.9	(92.91)	791.99	(889)	(269)	(738)	(1,251)	(1,722)	(2,243)	(3,231)	(3,893)	(4,584)	(5,254)
Arthur Kill ST 2	362.2	(38.03)	324.17	(422)	199	(270)	(783)	(1,254)	(1,775)	(2,764)	(3,425)	(4,116)	(4,786)
Arthur Kill ST 3	522.7	(54.88)	467.82	(565)	56	(414)	(926)	(1,398)	(1,919)	(2,907)	(3,568)	(4,260)	(4,930)
Brooklyn Navy Yard	247.5	(10.96)	236.54	(334)	287	(183)	(695)	(1,166)	(1,687)	(2,676)	(3,337)	(4,028)	(4,698)
Astoria 2, 3, & 5	916.9	(96.27)	820.63	(918)	(297)	(767)	(1,279)	(1,750)	(2,272)	(3,260)	(3,921)	(4,612)	(5,282)
Astoria 2	171.2	(17.98)	153.22	(251)	370	(99)	(612)	(1,083)	(1,604)	(2,593)	(3,254)	(3,945)	(4,615)
Astoria 3	372.4	(39.10)	333.30	(431)	190	(279)	(792)	(1,263)	(1,784)	(2,773)	(3,434)	(4,125)	(4,795)
Astoria 5	373.3	(39.20)	334.10	(432)	189	(280)	(793)	(1,264)	(1,785)	(2,773)	(3,435)	(4,126)	(4,796)
Ravenswood ST 01, 02, & 03	1,958.2	(191.73)	1,766.47	(1,864)	(1,243)	(1,713)	(2,225)	(2,696)	(3,217)	(4,206)	(4,867)	(5,558)	(6,228)
Ravenswood ST 01	367.0	(38.54)	328.47	(426)	195	(275)	(787)	(1,258)	(1,779)	(2,768)	(3,429)	(4,120)	(4,790)
Ravenswood ST 02	375.3	(39.41)	335.89	(433)	188	(282)	(794)	(1,266)	(1,787)	(2,775)	(3,436)	(4,128)	(4,798)
Ravenswood ST 03	987.3	(103.67)	883.63	(981)	(360)	(830)	(1,342)	(1,813)	(2,335)	(3,323)	(3,984)	(4,675)	(5,345)
Ravenswood CC 04	228.6	(10.13)	218.47	(316)	305	(165)	(677)	(1,148)	(1,669)	(2,658)	(3,319)	(4,010)	(4,680)
East River 1, 2, 6, & 7	620.5	(46.55)	573.95	(671)	(51)	(520)	(1,033)	(1,504)	(2,025)	(3,013)	(3,674)	(4,366)	(5,036)
East River 1	151.5	(6.71)	144.79	(242)	379	(91)	(603)	(1,075)	(1,596)	(2,584)	(3,245)	(3,937)	(4,607)
East River 2	155.0	(6.87)	148.13	(246)	375	(94)	(607)	(1,078)	(1,599)	(2,587)	(3,249)	(3,940)	(4,610)
East River 6	131.6	(13.82)	117.78	(215)	406	(64)	(576)	(1,048)	(1,569)	(2,557)	(3,218)	(3,910)	(4,580)
East River 7	182.4	(19.15)	163.25	(261)	360	(109)	(622)	(1,093)	(1,614)	(2,603)	(3,264)	(3,955)	(4,625)
Linden Cogen	737.1	(32.65)	704.45	(802)	(181)	(651)	(1,163)	(1,634)	(2,155)	(3,144)	(3,805)	(4,496)	(5,166)
KIAC_JFK (BTM:NG)	106.4	(4.71)	101.69	(199)	422	(48)	(560)	(1,031)	(1,553)	(2,541)	(3,202)	(3,893)	(4,563)
Gowanus 5 & 6	79.9	(8.39)	71.51	(169)	452	(18)	(530)	(1,001)	(1,522)	(2,511)	(3,172)	(3,863)	(4,533)
Gowanus 5	40.0	(4.20)	35.80	(133)	488	18	(494)	(966)	(1,487)	(2,475)	(3,136)	(3,828)	(4,498)
Gowanus 6	39.9	(4.19)	35.71	(133)	488	18	(494)	(965)	(1,487)	(2,475)	(3,136)	(3,827)	(4,497)
Kent	46.0	(4.83)	41.17	(139)	482	13	(500)	(971)	(1,492)	(2,481)	(3,142)	(3,833)	(4,503)
Pouch	45.4	(4.77)	40.63	(138)	483	13	(499)	(970)	(1,492)	(2,480)	(3,141)	(3,832)	(4,502)

Additional Outage Impacts - Statewide System Margin													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Statewide System Margin Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Hellgate 1 & 2	79.5	(8.35)	71.15	(169)	452	(17)	(530)	(1,001)	(1,522)	(2,511)	(3,172)	(3,863)	(4,533)
Hellgate 1	39.9	(4.19)	35.71	(133)	488	18	(494)	(965)	(1,487)	(2,475)	(3,136)	(3,827)	(4,497)
Hellgate 2	39.6	(4.16)	35.44	(133)	488	18	(494)	(965)	(1,486)	(2,475)	(3,136)	(3,827)	(4,497)
Harlem River 1 & 2	79.5	(8.35)	71.15	(169)	452	(17)	(530)	(1,001)	(1,522)	(2,511)	(3,172)	(3,863)	(4,533)
Harlem River 1	39.9	(4.19)	35.71	(133)	488	18	(494)	(965)	(1,487)	(2,475)	(3,136)	(3,827)	(4,497)
Harlem River 2	39.6	(4.16)	35.44	(133)	488	18	(494)	(965)	(1,486)	(2,475)	(3,136)	(3,827)	(4,497)
Vernon Blvd 2 & 3	79.9	(8.39)	71.51	(169)	452	(18)	(530)	(1,001)	(1,522)	(2,511)	(3,172)	(3,863)	(4,533)
Vernon Blvd 2	40.0	(4.20)	35.80	(133)	488	18	(494)	(966)	(1,487)	(2,475)	(3,136)	(3,828)	(4,498)
Vernon Blvd 3	39.9	(4.19)	35.71	(133)	488	18	(494)	(965)	(1,487)	(2,475)	(3,136)	(3,827)	(4,497)
Astoria CC 1 & 2	474.0	(21.00)	453.00	(550)	70	(399)	(912)	(1,383)	(1,904)	(2,892)	(3,554)	(4,245)	(4,915)
Astoria CC 1	237.0	(10.50)	226.50	(324)	297	(173)	(685)	(1,156)	(1,677)	(2,666)	(3,327)	(4,018)	(4,688)
Astoria CC 2	237.0	(10.50)	226.50	(324)	297	(173)	(685)	(1,156)	(1,677)	(2,666)	(3,327)	(4,018)	(4,688)
Astoria East Energy CC1 & CC2	579.2	(25.66)	553.54	(651)	(30)	(500)	(1,012)	(1,483)	(2,005)	(2,993)	(3,654)	(4,345)	(5,015)
Astoria East Energy - CC1	289.6	(12.83)	276.77	(374)	247	(223)	(735)	(1,207)	(1,728)	(2,716)	(3,377)	(4,069)	(4,739)
Astoria East Energy - CC2	289.6	(12.83)	276.77	(374)	247	(223)	(735)	(1,207)	(1,728)	(2,716)	(3,377)	(4,069)	(4,739)
Astoria Energy 2 - CC3 & CC4	570.6	(25.28)	545.32	(643)	(22)	(492)	(1,004)	(1,475)	(1,996)	(2,985)	(3,646)	(4,337)	(5,007)
Astoria Energy 2 - CC3	285.3	(12.64)	272.66	(370)	251	(219)	(731)	(1,202)	(1,724)	(2,712)	(3,373)	(4,064)	(4,734)
Astoria Energy 2 - CC4	285.3	(12.64)	272.66	(370)	251	(219)	(731)	(1,202)	(1,724)	(2,712)	(3,373)	(4,064)	(4,734)
Bayonne EC CT G1 through G10	598.6	(55.01)	543.59	(641)	(20)	(490)	(1,002)	(1,473)	(1,995)	(2,983)	(3,644)	(4,335)	(5,005)
Bayonne EC CTG1	62.0	(5.70)	56.30	(154)	467	(2)	(515)	(986)	(1,507)	(2,496)	(3,157)	(3,848)	(4,518)
Bayonne EC CTG2	58.0	(5.33)	52.67	(150)	471	1	(511)	(982)	(1,504)	(2,492)	(3,153)	(3,844)	(4,514)
Bayonne EC CTG3	58.0	(5.33)	52.67	(150)	471	1	(511)	(982)	(1,504)	(2,492)	(3,153)	(3,844)	(4,514)
Bayonne EC CTG4	61.1	(5.62)	55.48	(153)	468	(2)	(514)	(985)	(1,506)	(2,495)	(3,156)	(3,847)	(4,517)
Bayonne EC CTG5	58.5	(5.38)	53.12	(151)	470	1	(512)	(983)	(1,504)	(2,492)	(3,154)	(3,845)	(4,515)
Bayonne EC CTG6	59.0	(5.42)	53.58	(151)	470	0	(512)	(983)	(1,505)	(2,493)	(3,154)	(3,845)	(4,515)
Bayonne EC CTG7	59.3	(5.45)	53.85	(151)	470	(0)	(512)	(984)	(1,505)	(2,493)	(3,154)	(3,846)	(4,516)
Bayonne EC CTG8	60.0	(5.51)	54.49	(152)	469	(1)	(513)	(984)	(1,505)	(2,494)	(3,155)	(3,846)	(4,516)
Bayonne EC CTG9	61.3	(5.63)	55.67	(153)	468	(2)	(514)	(985)	(1,507)	(2,495)	(3,156)	(3,847)	(4,517)
Bayonne EC CTG10	61.4	(5.64)	55.76	(153)	468	(2)	(514)	(986)	(1,507)	(2,495)	(3,156)	(3,847)	(4,517)
Greenport IC 4, 5, & 6	5.6	(0.80)	4.80	(102)	519	49	(463)	(935)	(1,456)	(2,444)	(3,105)	(3,797)	(4,467)
Greenport IC 4	1.0	(0.14)	0.86	(98)	523	53	(459)	(931)	(1,452)	(2,440)	(3,101)	(3,793)	(4,463)
Greenport IC 5	1.5	(0.21)	1.29	(99)	522	53	(460)	(931)	(1,452)	(2,441)	(3,102)	(3,793)	(4,463)
Greenport IC 6	3.1	(0.44)	2.66	(100)	521	51	(461)	(932)	(1,454)	(2,442)	(3,103)	(3,794)	(4,464)
Freeport 1-2, 1-3, & 2-3	21.1	(2.42)	18.68	(116)	505	35	(477)	(948)	(1,470)	(2,458)	(3,119)	(3,810)	(4,480)
Freeport 1-2	2.5	(0.36)	2.14	(100)	521	52	(461)	(932)	(1,453)	(2,441)	(3,103)	(3,794)	(4,464)
Freeport 1-3	2.9	(0.42)	2.48	(100)	521	51	(461)	(932)	(1,453)	(2,442)	(3,103)	(3,794)	(4,464)
Freeport 2-3	15.7	(1.65)	14.05	(111)	509	40	(473)	(944)	(1,465)	(2,453)	(3,115)	(3,806)	(4,476)
Charles P Keller 09 through 14	16.0	(1.50)	14.50	(112)	509	39	(473)	(944)	(1,465)	(2,454)	(3,115)	(3,806)	(4,476)
Charles P Keller 09	1.9	(0.18)	1.72	(99)	522	52	(460)	(931)	(1,453)	(2,441)	(3,102)	(3,793)	(4,463)
Charles P Keller 10	1.9	(0.18)	1.72	(99)	522	52	(460)	(931)	(1,453)	(2,441)	(3,102)	(3,793)	(4,463)
Charles P Keller 11	2.8	(0.26)	2.54	(100)	521	51	(461)	(932)	(1,453)	(2,442)	(3,103)	(3,794)	(4,464)
Charles P Keller 12	3.0	(0.28)	2.72	(100)	521	51	(461)	(932)	(1,454)	(2,442)	(3,103)	(3,794)	(4,464)
Charles P Keller 13	3.0	(0.28)	2.72	(100)	521	51	(461)	(932)	(1,454)	(2,442)	(3,103)	(3,794)	(4,464)
Charles P Keller 14	3.4	(0.32)	3.08	(100)	520	51	(462)	(933)	(1,454)	(2,442)	(3,104)	(3,795)	(4,465)
Wading River 1, 2, & 3	231.4	(24.30)	207.10	(305)	316	(153)	(666)	(1,137)	(1,658)	(2,646)	(3,308)	(3,999)	(4,669)
Wading River 1	79.7	(8.37)	71.33	(169)	452	(18)	(530)	(1,001)	(1,522)	(2,511)	(3,172)	(3,863)	(4,533)
Wading River 2	76.4	(8.02)	68.38	(166)	455	(15)	(527)	(998)	(1,519)	(2,508)	(3,169)	(3,860)	(4,530)
Wading River 3	75.3	(7.91)	67.39	(165)	456	(14)	(526)	(997)	(1,518)	(2,507)	(3,168)	(3,859)	(4,529)
Barrett ST 01 & 02	383.0	(40.22)	342.79	(440)	181	(289)	(801)	(1,273)	(1,794)	(2,782)	(3,443)	(4,135)	(4,805)
Barrett ST 01	195.0	(20.48)	174.53	(272)	349	(121)	(633)	(1,104)	(1,625)	(2,614)	(3,275)	(3,966)	(4,636)
Barrett ST 02	188.0	(19.74)	168.26	(266)	355	(114)	(627)	(1,098)	(1,619)	(2,608)	(3,269)	(3,960)	(4,630)
Barrett GT 01 through 12	246.2	(23.90)	222.30	(320)	301	(168)	(681)	(1,152)	(1,673)	(2,662)	(3,323)	(4,014)	(4,684)
Barrett GT 01	14.0	(1.47)	12.53	(110)	511	41	(471)	(942)	(1,463)	(2,452)	(3,113)	(3,804)	(4,474)
Barrett GT 02	13.6	(1.43)	12.17	(110)	511	42	(471)	(942)	(1,463)	(2,452)	(3,113)	(3,804)	(4,474)
Barrett 03	13.7	(1.44)	12.26	(110)	511	42	(471)	(942)	(1,463)	(2,452)	(3,113)	(3,804)	(4,474)
Barrett 04	15.8	(1.66)	14.14	(112)	509	40	(473)	(944)	(1,465)	(2,453)	(3,115)	(3,806)	(4,476)
Barrett 05	13.5	(1.42)	12.08	(109)	511	42	(471)	(942)	(1,463)	(2,451)	(3,113)	(3,804)	(4,474)
Barrett 06	14.1	(1.48)	12.62	(110)	511	41	(471)	(942)	(1,464)	(2,452)	(3,113)	(3,804)	(4,474)
Barrett 08	12.3	(1.29)	11.01	(108)	512	43	(470)	(941)	(1,462)	(2,450)	(3,112)	(3,803)	(4,473)
Barrett 09	31.2	(2.87)	28.33	(126)	495	25	(487)	(958)	(1,479)	(2,468)	(3,129)	(3,820)	(4,490)
Barrett 10	39.6	(3.64)	35.96	(133)	487	18	(495)	(966)	(1,487)	(2,475)	(3,137)	(3,828)	(4,498)
Barrett 11	39.0	(3.58)	35.42	(133)	488	18	(494)	(965)	(1,486)	(2,475)	(3,136)	(3,827)	(4,497)
Barrett 12	39.4	(3.62)	35.78	(133)	488	18	(494)	(966)	(1,487)	(2,475)	(3,136)	(3,828)	(4,498)



Additional Outage Impacts - Statewide System Margin													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Statewide System Margin Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IFO)									
Northport 1, 2, 3, and 4	1,553.9	(163.16)	1,390.74	(1,488)	(867)	(1,337)	(1,849)	(2,321)	(2,842)	(3,830)	(4,491)	(5,182)	(5,852)
Northport 1	398.0	(41.79)	356.21	(454)	167	(302)	(815)	(1,286)	(1,807)	(2,796)	(3,457)	(4,148)	(4,818)
Northport 2	399.4	(41.94)	357.46	(455)	166	(304)	(816)	(1,287)	(1,808)	(2,797)	(3,458)	(4,149)	(4,819)
Northport 3	388.5	(40.79)	347.71	(445)	176	(294)	(806)	(1,277)	(1,799)	(2,787)	(3,448)	(4,139)	(4,809)
Northport 4	368.0	(38.64)	329.36	(427)	194	(276)	(788)	(1,259)	(1,780)	(2,769)	(3,430)	(4,121)	(4,791)
Port Jefferson GT 02 & 03	80.6	(8.46)	72.14	(170)	451	(18)	(531)	(1,002)	(1,523)	(2,511)	(3,173)	(3,864)	(4,534)
Port Jefferson GT 02	40.6	(4.26)	36.34	(134)	487	17	(495)	(966)	(1,487)	(2,476)	(3,137)	(3,828)	(4,498)
Port Jefferson GT 03	40.0	(4.20)	35.80	(133)	488	18	(494)	(966)	(1,487)	(2,475)	(3,136)	(3,828)	(4,498)
Port Jefferson 3 & 4	383.7	(40.29)	343.41	(441)	180	(290)	(802)	(1,273)	(1,794)	(2,783)	(3,444)	(4,135)	(4,805)
Port Jefferson 3	189.7	(19.92)	169.78	(267)	354	(116)	(628)	(1,100)	(1,621)	(2,609)	(3,270)	(3,962)	(4,632)
Port Jefferson 4	194.0	(20.37)	173.63	(271)	350	(120)	(632)	(1,103)	(1,625)	(2,613)	(3,274)	(3,965)	(4,635)
Hempstead (RR)	74.8	(7.85)	66.95	(164)	456	(13)	(526)	(997)	(1,518)	(2,506)	(3,167)	(3,859)	(4,529)
Glenwood GT 02, 04, & 05	146.7	(15.40)	131.30	(229)	392	(77)	(590)	(1,061)	(1,582)	(2,571)	(3,232)	(3,923)	(4,593)
Glenwood GT 02	59.3	(6.23)	53.07	(150)	470	1	(512)	(983)	(1,504)	(2,492)	(3,154)	(3,845)	(4,515)
Glenwood GT 04	43.3	(4.55)	38.75	(136)	485	15	(497)	(969)	(1,490)	(2,478)	(3,139)	(3,830)	(4,500)
Glenwood GT 05	44.1	(4.63)	39.47	(137)	484	14	(498)	(969)	(1,490)	(2,479)	(3,140)	(3,831)	(4,501)
Holtsville 01 through 10	525.3	(48.28)	477.02	(574)	46	(423)	(936)	(1,407)	(1,928)	(2,916)	(3,578)	(4,269)	(4,939)
Holtsville 01	55.0	(5.05)	49.95	(147)	473	4	(509)	(980)	(1,501)	(2,489)	(3,150)	(3,842)	(4,512)
Holtsville 02	57.0	(5.24)	51.76	(149)	472	2	(510)	(982)	(1,503)	(2,491)	(3,152)	(3,844)	(4,514)
Holtsville 03	51.1	(4.70)	46.40	(144)	477	7	(505)	(976)	(1,497)	(2,486)	(3,147)	(3,838)	(4,508)
Holtsville 04	54.3	(4.99)	49.31	(147)	474	5	(508)	(979)	(1,500)	(2,489)	(3,150)	(3,841)	(4,511)
Holtsville 05	53.4	(4.91)	48.49	(146)	475	5	(507)	(978)	(1,499)	(2,488)	(3,149)	(3,840)	(4,510)
Holtsville 06	49.1	(4.51)	44.59	(142)	479	9	(503)	(974)	(1,496)	(2,484)	(3,145)	(3,836)	(4,506)
Holtsville 07	53.0	(4.87)	48.13	(146)	475	6	(507)	(978)	(1,499)	(2,487)	(3,149)	(3,840)	(4,510)
Holtsville 08	52.1	(4.79)	47.31	(145)	476	7	(506)	(977)	(1,498)	(2,487)	(3,148)	(3,839)	(4,509)
Holtsville 09	54.2	(4.98)	49.22	(147)	474	5	(508)	(979)	(1,500)	(2,489)	(3,150)	(3,841)	(4,511)
Holtsville 10	46.1	(4.24)	41.86	(139)	482	12	(500)	(972)	(1,493)	(2,481)	(3,142)	(3,834)	(4,504)
Shoreham GT 3 & 4	83.3	(8.75)	74.55	(172)	449	(21)	(533)	(1,004)	(1,526)	(2,514)	(3,175)	(3,866)	(4,536)
Shoreham GT3	42.1	(4.42)	37.68	(135)	486	16	(496)	(967)	(1,489)	(2,477)	(3,138)	(3,829)	(4,499)
Shoreham GT4	41.2	(4.33)	36.87	(134)	487	17	(495)	(967)	(1,488)	(2,476)	(3,137)	(3,829)	(4,499)
East Hampton GT 01, 2, 3, & 4	24.2	(2.53)	21.67	(119)	502	32	(480)	(951)	(1,473)	(2,461)	(3,122)	(3,813)	(4,483)
East Hampton GT 01	18.2	(1.67)	16.53	(114)	507	37	(475)	(946)	(1,467)	(2,456)	(3,117)	(3,808)	(4,478)
East Hampton 2	2.0	(0.29)	1.71	(99)	522	52	(460)	(931)	(1,453)	(2,441)	(3,102)	(3,793)	(4,463)
East Hampton 3	2.0	(0.29)	1.71	(99)	522	52	(460)	(931)	(1,453)	(2,441)	(3,102)	(3,793)	(4,463)
East Hampton 4	2.0	(0.29)	1.71	(99)	522	52	(460)	(931)	(1,453)	(2,441)	(3,102)	(3,793)	(4,463)
Southold 1	9.4	(0.99)	8.41	(106)	515	45	(467)	(938)	(1,459)	(2,448)	(3,109)	(3,800)	(4,470)
S Hampton 1	7.8	(0.82)	6.98	(104)	516	47	(466)	(937)	(1,458)	(2,446)	(3,108)	(3,799)	(4,469)
Freeport CT 1 & 2	88.9	(9.33)	79.57	(177)	444	(26)	(538)	(1,009)	(1,531)	(2,519)	(3,180)	(3,871)	(4,541)
Freeport CT 1	45.9	(4.82)	41.08	(138)	482	13	(500)	(971)	(1,492)	(2,480)	(3,142)	(3,833)	(4,503)
Freeport CT 2	43.0	(4.52)	38.49	(136)	485	15	(497)	(968)	(1,489)	(2,478)	(3,139)	(3,830)	(4,500)
Flynn	139.5	(6.18)	133.32	(231)	390	(80)	(592)	(1,063)	(1,584)	(2,573)	(3,234)	(3,925)	(4,595)
Greenport GT1	51.2	(4.71)	46.49	(144)	477	7	(505)	(976)	(1,497)	(2,486)	(3,147)	(3,838)	(4,508)
Far Rockaway GT1 & GT2	104.6	(9.61)	94.99	(192)	428	(41)	(554)	(1,025)	(1,546)	(2,534)	(3,196)	(3,887)	(4,557)
Far Rockaway GT1	48.9	(4.49)	44.41	(142)	479	9	(503)	(974)	(1,495)	(2,484)	(3,145)	(3,836)	(4,506)
Far Rockaway GT2	55.7	(5.12)	50.58	(148)	473	3	(509)	(980)	(1,502)	(2,490)	(3,151)	(3,842)	(4,512)
Bethpage	52.0	(2.30)	49.70	(147)	474	4	(508)	(979)	(1,501)	(2,489)	(3,150)	(3,841)	(4,511)
Bethpage 3	76.0	(3.37)	72.63	(170)	451	(19)	(531)	(1,002)	(1,524)	(2,512)	(3,173)	(3,864)	(4,534)
Bethpage GT4	43.6	(4.58)	39.02	(136)	484	15	(498)	(969)	(1,490)	(2,478)	(3,140)	(3,831)	(4,501)
Stony Brook (BTM:NG)	0.0	0.00	0.00	(97)	523	54	(459)	(930)	(1,451)	(2,439)	(3,101)	(3,792)	(4,462)
Brentwood	45.0	(4.73)	40.28	(138)	483	14	(499)	(970)	(1,491)	(2,480)	(3,141)	(3,832)	(4,502)
Pilgrim GT1 & GT2	83.8	(8.80)	75.00	(172)	448	(21)	(534)	(1,005)	(1,526)	(2,514)	(3,176)	(3,867)	(4,537)
Pilgrim GT1	41.9	(4.40)	37.50	(135)	486	16	(496)	(967)	(1,488)	(2,477)	(3,138)	(3,829)	(4,499)
Pilgrim GT2	41.9	(4.40)	37.50	(135)	486	16	(496)	(967)	(1,488)	(2,477)	(3,138)	(3,829)	(4,499)
Pinelawn Power 1	73.4	(3.25)	70.15	(168)	453	(16)	(529)	(1,000)	(1,521)	(2,510)	(3,171)	(3,862)	(4,532)
Caithness_CC_1	306.9	(13.60)	293.30	(391)	230	(239)	(752)	(1,223)	(1,744)	(2,733)	(3,394)	(4,085)	(4,755)
Islip (RR)	8.5	(0.89)	7.61	(105)	516	46	(466)	(937)	(1,459)	(2,447)	(3,108)	(3,799)	(4,469)
Babylon (RR)	15.6	(1.64)	13.96	(111)	509	40	(473)	(944)	(1,465)	(2,453)	(3,115)	(3,806)	(4,476)
Huntington (RR)	24.7	(2.59)	22.11	(120)	501	32	(481)	(952)	(1,473)	(2,461)	(3,123)	(3,814)	(4,484)

#### Notes

- Utilizes the Higher Demand Statewide System Margin for Summer Peak with Expected Weather.
- Utilizes the next largest generation contingency outage which is the loss of the Cricket Valley CC1, CC2, & CC3.

**Figure 73: AOI - Lower Hudson Valley Transmission Security Margin**

Additional Outage Impacts - Lower Hudson Valley													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Lower Hudson Valley Transmission Security Margin, Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW)				1,193	2,256	2,107	1,959	1,749	1,456	762	436	81	(267)
(1)													
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Bowline 1 & 2	1,143.0	(120.02)	1,022.99	170	1,233	1,084	936	726	433	(261)	(587)	(942)	(1,290)
Bowline 1	577.8	(60.67)	517.13	676	1,739	1,590	1,442	1,232	939	245	(81)	(436)	(784)
Bowline 2	565.2	(59.35)	505.85	687	1,750	1,601	1,453	1,243	950	256	(70)	(425)	(773)
Danskammer 1, 2, 3, & 4	499.4	(52.44)	446.96	746	1,809	1,660	1,512	1,302	1,009	315	(11)	(366)	(714)
Danskammer 1	68.5	(7.19)	61.31	1,132	2,195	2,046	1,898	1,688	1,395	701	374	20	(329)
Danskammer 2	65.0	(6.83)	58.18	1,135	2,198	2,049	1,901	1,691	1,398	704	378	23	(325)
Danskammer 3	140.1	(14.71)	125.39	1,068	2,131	1,982	1,833	1,623	1,331	636	310	(44)	(393)
Danskammer 4	225.8	(23.71)	202.09	991	2,054	1,905	1,757	1,547	1,254	560	234	(121)	(469)
Roseton 1 & 2	1,228.2	(128.96)	1,099.24	94	1,157	1,008	860	650	357	(337)	(663)	(1,018)	(1,366)
Roseton 1	615.7	(64.65)	551.05	642	1,705	1,556	1,408	1,198	905	211	(115)	(470)	(818)
Roseton 2	612.5	(64.31)	548.19	645	1,708	1,559	1,411	1,201	908	214	(112)	(467)	(815)
Hillburn GT	36.0	(3.31)	32.69	1,160	2,224	2,074	1,926	1,716	1,423	729	403	49	(300)
Shoemaker GT	35.4	(3.25)	32.15	1,161	2,224	2,075	1,927	1,717	1,424	730	404	49	(299)
DCRRA	6.2	(0.65)	5.55	1,188	2,251	2,101	1,953	1,743	1,451	756	430	76	(273)
CPV Valley CC1 & CC2	645.4	(28.59)	616.81	576	1,640	1,490	1,342	1,132	839	145	(181)	(536)	(884)
CPV Valley CC1	322.7	(14.30)	308.40	885	1,948	1,799	1,650	1,440	1,148	453	127	(227)	(576)
CPV Valley CC2	322.7	(14.30)	308.40	885	1,948	1,799	1,650	1,440	1,148	453	127	(227)	(576)
Cricket Valley CC1, CC2, & CC3	1,050.8	(46.55)	1,004.25	189	1,252	1,103	955	745	452	(242)	(568)	(923)	(1,271)
Cricket Valley CC1	347.1	(15.38)	331.72	861	1,925	1,775	1,627	1,417	1,124	430	104	(250)	(599)
Cricket Valley CC2	345.0	(15.28)	329.72	863	1,927	1,777	1,629	1,419	1,126	432	106	(248)	(597)
Cricket Valley CC3	358.7	(15.89)	342.81	850	1,914	1,764	1,616	1,406	1,113	419	93	(262)	(610)
Wheelabrator Westchester	52.5	(5.51)	46.99	1,146	2,209	2,060	1,912	1,702	1,409	715	389	34	(314)
Arthur Kill ST 2 & 3	884.9	(92.91)	791.99	401	1,464	1,315	1,167	957	664	(30)	(356)	(711)	(1,059)
Arthur Kill ST 2	362.2	(38.03)	324.17	869	1,932	1,783	1,635	1,425	1,132	438	112	(243)	(591)
Arthur Kill ST 3	522.7	(54.88)	467.82	725	1,789	1,639	1,491	1,281	988	294	(32)	(387)	(735)
Brooklyn Navy Yard	247.5	(10.96)	236.54	957	2,020	1,870	1,722	1,512	1,220	525	199	(155)	(504)
Astoria 2, 3, & 5	916.9	(96.27)	820.63	372	1,436	1,286	1,138	928	635	(59)	(385)	(739)	(1,088)
Astoria 2	171.2	(17.98)	153.22	1,040	2,103	1,954	1,806	1,596	1,303	609	283	(72)	(420)
Astoria 3	372.4	(39.10)	333.30	860	1,923	1,774	1,626	1,416	1,123	429	103	(252)	(601)
Astoria 5	373.3	(39.20)	334.10	859	1,922	1,773	1,625	1,415	1,122	428	102	(253)	(601)
Ravenswood ST 01, 02, & 03	1,729.6	(181.61)	1,547.99	(68)	708	559	411	201	(92)	(786)	(1,112)	(1,467)	(1,815)
Ravenswood ST 01	367.0	(38.54)	328.47	865	1,928	1,778	1,630	1,420	1,128	433	107	(247)	(596)
Ravenswood ST 02	375.3	(39.41)	335.89	857	1,920	1,771	1,623	1,413	1,120	426	100	(255)	(603)
Ravenswood ST 03	987.3	(103.67)	883.63	597	1,373	1,223	1,075	865	572	(122)	(448)	(802)	(1,151)
Ravenswood CC 04	228.6	(10.13)	218.47	975	2,038	1,888	1,740	1,530	1,238	543	217	(137)	(486)
East River 1, 2, 6, & 7	620.5	(46.55)	573.95	619	1,682	1,533	1,385	1,175	882	188	(138)	(493)	(841)
East River 1	151.5	(6.71)	144.79	1,048	2,112	1,962	1,814	1,604	1,311	617	291	(64)	(412)
East River 2	155.0	(6.87)	148.13	1,045	2,108	1,959	1,811	1,601	1,308	614	288	(67)	(415)
East River 6	131.6	(13.82)	117.78	1,075	2,139	1,989	1,841	1,631	1,338	644	318	(37)	(385)
East River 7	182.4	(19.15)	163.25	1,030	2,093	1,944	1,796	1,586	1,293	599	273	(82)	(430)
Linden Cogen	737.1	(32.65)	704.45	489	1,552	1,402	1,254	1,044	752	57	(269)	(623)	(972)
KIAC JFK (BTM:NG)	106.4	(4.71)	101.69	1,091	2,155	2,005	1,857	1,647	1,354	660	334	(20)	(369)
Gowanus 5 & 6	79.9	(8.39)	71.51	1,122	2,185	2,035	1,887	1,677	1,385	690	364	10	(339)
Gowanus 5	40.0	(4.20)	35.80	1,157	2,221	2,071	1,923	1,713	1,420	726	400	45	(303)
Gowanus 6	39.9	(4.19)	35.71	1,157	2,221	2,071	1,923	1,713	1,420	726	400	46	(303)
Kent	46.0	(4.83)	41.17	1,152	2,215	2,066	1,918	1,708	1,415	721	395	40	(308)
Pouch	45.4	(4.77)	40.63	1,152	2,216	2,066	1,918	1,708	1,415	721	395	41	(308)
Hellgate 1 & 2	79.5	(8.35)	71.15	1,122	2,185	2,036	1,888	1,678	1,385	691	365	10	(338)
Hellgate 1	39.9	(4.19)	35.71	1,157	2,221	2,071	1,923	1,713	1,420	726	400	46	(303)
Hellgate 2	39.6	(4.16)	35.44	1,158	2,221	2,071	1,923	1,713	1,421	726	400	46	(303)
Harlem River 1 & 2	79.5	(8.35)	71.15	1,122	2,185	2,036	1,888	1,678	1,385	691	365	10	(338)
Harlem River 1	39.9	(4.19)	35.71	1,157	2,221	2,071	1,923	1,713	1,420	726	400	46	(303)
Harlem River 2	39.6	(4.16)	35.44	1,158	2,221	2,071	1,923	1,713	1,421	726	400	46	(303)
Vernon Blvd 2 & 3	79.9	(8.39)	71.51	1,122	2,185	2,035	1,887	1,677	1,385	690	364	10	(339)
Vernon Blvd 2	40.0	(4.20)	35.80	1,157	2,221	2,071	1,923	1,713	1,420	726	400	45	(303)
Vernon Blvd 3	39.9	(4.19)	35.71	1,157	2,221	2,071	1,923	1,713	1,420	726	400	46	(303)
Astoria CC 1 & 2	474.0	(21.00)	453.00	740	1,803	1,654	1,506	1,296	1,003	309	(17)	(372)	(720)
Astoria CC 1	237.0	(10.50)	226.50	967	2,030	1,880	1,732	1,522	1,230	535	209	(145)	(494)
Astoria CC 2	237.0	(10.50)	226.50	967	2,030	1,880	1,732	1,522	1,230	535	209	(145)	(494)
Astoria East Energy CC1 & CC2	579.2	(25.66)	553.54	640	1,703	1,553	1,405	1,195	903	208	(118)	(472)	(821)
Astoria East Energy - CC1	289.6	(12.83)	276.77	916	1,980	1,830	1,682	1,472	1,179	485	159	(196)	(544)
Astoria East Energy - CC2	289.6	(12.83)	276.77	916	1,980	1,830	1,682	1,472	1,179	485	159	(196)	(544)

Additional Outage Impacts - Lower Hudson Valley													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Lower Hudson Valley Transmission Security Margin, Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				1,193	2,256	2,107	1,959	1,749	1,456	762	436	81	(267)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Astoria Energy 2 - CC3 & CC4	570.6	(25.28)	545.32	648	1,711	1,562	1,413	1,203	911	217	(110)	(464)	(813)
Astoria Energy 2 - CC3	285.3	(12.64)	272.66	920	1,984	1,834	1,686	1,476	1,183	489	163	(191)	(540)
Astoria Energy 2 - CC4	285.3	(12.64)	272.66	920	1,984	1,834	1,686	1,476	1,183	489	163	(191)	(540)
Bayonne EC CT G1 through G10	598.6	(55.01)	543.59	650	1,713	1,563	1,415	1,205	913	218	(108)	(462)	(811)
Bayonne EC CTG1	62.0	(5.70)	56.30	1,137	2,200	2,051	1,903	1,693	1,400	706	380	25	(324)
Bayonne EC CTG2	58.0	(5.33)	52.67	1,140	2,204	2,054	1,906	1,696	1,403	709	383	29	(320)
Bayonne EC CTG3	58.0	(5.33)	52.67	1,140	2,204	2,054	1,906	1,696	1,403	709	383	29	(320)
Bayonne EC CTG4	61.1	(5.62)	55.48	1,138	2,201	2,051	1,903	1,693	1,401	706	380	26	(323)
Bayonne EC CTG5	58.5	(5.38)	53.12	1,140	2,203	2,054	1,906	1,696	1,403	709	383	28	(320)
Bayonne EC CTG6	59.0	(5.42)	53.58	1,140	2,203	2,053	1,905	1,695	1,403	708	382	28	(321)
Bayonne EC CTG7	59.3	(5.45)	53.85	1,139	2,202	2,053	1,905	1,695	1,402	708	382	27	(321)
Bayonne EC CTG8	60.0	(5.51)	54.49	1,139	2,202	2,052	1,904	1,694	1,402	707	381	27	(322)
Bayonne EC CTG9	61.3	(5.63)	55.67	1,137	2,201	2,051	1,903	1,693	1,400	706	380	26	(323)
Bayonne EC CTG10	61.4	(5.64)	55.76	1,137	2,201	2,051	1,903	1,693	1,400	706	380	26	(323)

#### Notes

- Utilizes the High Demand Transmission Security Margin for Summer Peak with Expected Weather.
- In 2025 the most limiting contingency combination includes the loss of Ravenswood 3. For this calculation the margin based on the loss of two transmission elements is utilized. Other combinations with loss of generation may be more limiting.



**Figure 74: AOI - New York City Transmission Security Margin**

Additional Outage Impacts - New York City													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
New York City Transmission Security Margin, Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				(461)	209	160	30	(100)	(140)	(647)	(807)	(967)	(1,137)
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Arthur Kill ST 2 & 3	884.9	(92.91)	791.99	(1,253)	(583)	(632)	(762)	(892)	(932)	(1,439)	(1,599)	(1,759)	(1,929)
Arthur Kill ST 2	362.2	(38.03)	324.17	(785)	(115)	(164)	(294)	(424)	(464)	(971)	(1,131)	(1,291)	(1,461)
Arthur Kill ST 3	522.7	(54.88)	467.82	(929)	(259)	(308)	(438)	(568)	(608)	(1,115)	(1,275)	(1,435)	(1,605)
Brooklyn Navy Yard	247.5	(10.96)	236.54	(698)	(28)	(76)	(206)	(336)	(376)	(883)	(1,043)	(1,203)	(1,373)
Astoria 2, 3, & 5	916.9	(96.27)	820.63	(1,282)	(612)	(660)	(790)	(920)	(960)	(1,468)	(1,628)	(1,788)	(1,958)
Astoria 2	171.2	(17.98)	153.22	(615)	55	7	(123)	(253)	(293)	(800)	(960)	(1,120)	(1,290)
Astoria 3	372.4	(39.10)	333.30	(795)	(125)	(173)	(303)	(433)	(473)	(980)	(1,140)	(1,300)	(1,470)
Astoria 5	373.3	(39.20)	334.10	(795)	(125)	(174)	(304)	(434)	(474)	(981)	(1,141)	(1,301)	(1,471)
Ravenswood ST 01, 02, & 03 (2)	1,729.6	(181.61)	1,547.99	(1,822)	(1,152)	(1,200)	(1,330)	(1,460)	(1,500)	(2,008)	(2,168)	(2,328)	(2,498)
Ravenswood ST 01	367.0	(38.54)	328.47	(790)	(120)	(168)	(298)	(428)	(468)	(975)	(1,135)	(1,295)	(1,465)
Ravenswood ST 02	375.3	(39.41)	335.89	(797)	(127)	(176)	(306)	(436)	(476)	(983)	(1,143)	(1,303)	(1,473)
Ravenswood ST 03 (2)	987.3	(103.67)	883.63	(1,158)	(488)	(156)	(666)	(796)	(836)	(1,343)	(1,503)	(1,663)	(1,833)
Ravenswood CC 04	228.6	(10.13)	218.47	(680)	(10)	(58)	(188)	(318)	(358)	(865)	(1,025)	(1,185)	(1,355)
East River 1, 2, 6, & 7	620.5	(46.55)	573.95	(1,035)	(365)	(414)	(544)	(674)	(714)	(1,221)	(1,381)	(1,541)	(1,711)
East River 1	151.5	(6.71)	144.79	(606)	64	16	(114)	(244)	(284)	(792)	(952)	(1,112)	(1,282)
East River 2	155.0	(6.87)	148.13	(609)	61	12	(118)	(248)	(288)	(795)	(955)	(1,115)	(1,285)
East River 6	131.6	(13.82)	117.78	(579)	91	43	(87)	(217)	(257)	(765)	(925)	(1,085)	(1,255)
East River 7	182.4	(19.15)	163.25	(625)	45	(3)	(133)	(263)	(303)	(810)	(970)	(1,130)	(1,300)
Linden Cogen	737.1	(32.65)	704.45	(1,166)	(496)	(544)	(674)	(804)	(844)	(1,351)	(1,511)	(1,671)	(1,841)
KIAC_JFK (BTM:NG)	106.4	(4.71)	101.69	(563)	107	59	(71)	(201)	(241)	(749)	(909)	(1,069)	(1,239)
Gowanus 5 & 6	79.9	(8.39)	71.51	(533)	137	89	(41)	(171)	(211)	(718)	(878)	(1,038)	(1,208)
Gowanus 5	40.0	(4.20)	35.80	(497)	173	124	(6)	(136)	(176)	(683)	(843)	(1,003)	(1,173)
Gowanus 6	39.9	(4.19)	35.71	(497)	173	125	(5)	(135)	(175)	(683)	(843)	(1,003)	(1,173)
Kent	46.0	(4.83)	41.17	(502)	168	119	(11)	(141)	(181)	(688)	(848)	(1,008)	(1,178)
Pouch	45.4	(4.77)	40.63	(502)	168	120	(10)	(140)	(180)	(688)	(848)	(1,008)	(1,178)
Hellgate 1 & 2	79.5	(8.35)	71.15	(532)	138	89	(41)	(171)	(211)	(718)	(878)	(1,038)	(1,208)
Hellgate 1	39.9	(4.19)	35.71	(497)	173	125	(5)	(135)	(175)	(683)	(843)	(1,003)	(1,173)
Hellgate 2	39.6	(4.16)	35.44	(497)	173	125	(5)	(135)	(175)	(682)	(842)	(1,002)	(1,172)
Harlem River 1 & 2	79.5	(8.35)	71.15	(532)	138	89	(41)	(171)	(211)	(718)	(878)	(1,038)	(1,208)
Harlem River 1	39.9	(4.19)	35.71	(497)	173	125	(5)	(135)	(175)	(683)	(843)	(1,003)	(1,173)
Harlem River 2	39.6	(4.16)	35.44	(497)	173	125	(5)	(135)	(175)	(682)	(842)	(1,002)	(1,172)
Vernon Blvd 2 & 3	79.9	(8.39)	71.51	(533)	137	89	(41)	(171)	(211)	(718)	(878)	(1,038)	(1,208)
Vernon Blvd 2	40.0	(4.20)	35.80	(497)	173	124	(6)	(136)	(176)	(683)	(843)	(1,003)	(1,173)
Vernon Blvd 3	39.9	(4.19)	35.71	(497)	173	125	(5)	(135)	(175)	(683)	(843)	(1,003)	(1,173)
Astoria CC 1 & 2	474.0	(21.00)	453.00	(914)	(244)	(293)	(423)	(553)	(593)	(1,100)	(1,260)	(1,420)	(1,590)
Astoria CC 1	237.0	(10.50)	226.50	(688)	(18)	(66)	(196)	(326)	(366)	(873)	(1,033)	(1,193)	(1,363)
Astoria CC 2	237.0	(10.50)	226.50	(688)	(18)	(66)	(196)	(326)	(366)	(873)	(1,033)	(1,193)	(1,363)
Astoria East Energy CC1 & CC2	579.2	(25.66)	553.54	(1,015)	(345)	(393)	(523)	(653)	(693)	(1,200)	(1,360)	(1,520)	(1,690)
Astoria East Energy - CC1	289.6	(12.83)	276.77	(738)	(68)	(116)	(246)	(376)	(416)	(924)	(1,084)	(1,244)	(1,414)
Astoria East Energy - CC2	289.6	(12.83)	276.77	(738)	(68)	(116)	(246)	(376)	(416)	(924)	(1,084)	(1,244)	(1,414)
Astoria Energy 2 - CC3 & CC4	570.6	(25.28)	545.32	(1,007)	(337)	(385)	(515)	(645)	(685)	(1,192)	(1,352)	(1,512)	(1,682)
Astoria Energy 2 - CC3	285.3	(12.64)	272.66	(734)	(64)	(112)	(242)	(372)	(412)	(920)	(1,080)	(1,240)	(1,410)
Astoria Energy 2 - CC4	285.3	(12.64)	272.66	(734)	(64)	(112)	(242)	(372)	(412)	(920)	(1,080)	(1,240)	(1,410)
Bayonne EC CT G1 through G10	598.6	(55.01)	543.59	(1,005)	(335)	(383)	(513)	(643)	(683)	(1,190)	(1,350)	(1,510)	(1,680)
Bayonne EC CTG1	62.0	(5.70)	56.30	(518)	152	104	(26)	(156)	(196)	(703)	(863)	(1,023)	(1,193)
Bayonne EC CTG2	58.0	(5.33)	52.67	(514)	156	108	(22)	(152)	(192)	(700)	(860)	(1,020)	(1,190)
Bayonne EC CTG3	58.0	(5.33)	52.67	(514)	156	108	(22)	(152)	(192)	(700)	(860)	(1,020)	(1,190)
Bayonne EC CTG4	61.1	(5.62)	55.48	(517)	153	105	(25)	(155)	(195)	(702)	(862)	(1,022)	(1,192)
Bayonne EC CTG5	58.5	(5.38)	53.12	(514)	156	107	(23)	(153)	(193)	(700)	(860)	(1,020)	(1,190)
Bayonne EC CTG6	59.0	(5.42)	53.58	(515)	155	107	(23)	(153)	(193)	(700)	(860)	(1,020)	(1,190)
Bayonne EC CTG7	59.3	(5.45)	53.85	(515)	155	106	(24)	(154)	(194)	(701)	(861)	(1,021)	(1,191)
Bayonne EC CTG8	60.0	(5.51)	54.49	(516)	154	106	(24)	(154)	(194)	(701)	(861)	(1,021)	(1,191)
Bayonne EC CTG9	61.3	(5.63)	55.67	(517)	153	105	(25)	(155)	(195)	(703)	(863)	(1,023)	(1,193)
Bayonne EC CTG10	61.4	(5.64)	55.76	(517)	153	105	(25)	(155)	(195)	(703)	(863)	(1,023)	(1,193)

**Notes**

1. Utilizes the Higher Demand Transmission Security Margin for Summer Peak with Expected Weather.
2. In all years the most limiting contingency includes the loss of Ravenswood 3. For this calculation the margin based on the loss of two transmission elements is utilized. Other combinations with loss of generation may be more limiting.

**Figure 75: AOI - Long Island Transmission Security Margin**

Additional Outage Impacts - Long Island													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Long Island Transmission Security Margin, Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				368	437	409	372	326	2,228	2,113	2,024	1,923	1,821
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Greenport IC 4, 5, & 6	5.6	(0.80)	4.80	363	432	404	368	321	2,223	2,108	2,019	1,918	1,816
Greenport IC 4	1.0	(0.14)	0.86	367	436	408	372	325	2,227	2,112	2,023	1,922	1,820
Greenport IC 5	1.5	(0.21)	1.29	366	436	408	371	325	2,226	2,112	2,022	1,922	1,820
Greenport IC 6	3.1	(0.44)	2.66	365	434	406	370	323	2,225	2,111	2,021	1,920	1,818
Freeport 1-2, 1-3, & 2-3	21.1	(2.42)	18.68	349	418	390	354	307	2,209	2,095	2,005	1,904	1,802
Freeport 1-2	2.5	(0.36)	2.14	366	435	407	370	324	2,226	2,111	2,022	1,921	1,819
Freeport 1-3	2.9	(0.42)	2.48	365	435	406	370	323	2,225	2,111	2,021	1,921	1,819
Freeport 2-3	15.7	(1.65)	14.05	354	423	395	358	312	2,214	2,099	2,010	1,909	1,807
Charles P Killer 09 through 14	16.0	(1.50)	14.50	353	423	394	358	311	2,213	2,099	2,009	1,909	1,807
Charles P Keller 09	1.9	(0.18)	1.72	366	435	407	371	324	2,226	2,112	2,022	1,921	1,819
Charles P Keller 10	1.9	(0.18)	1.72	366	435	407	371	324	2,226	2,112	2,022	1,921	1,819
Charles P Keller 11	2.8	(0.26)	2.54	365	434	406	370	323	2,225	2,111	2,021	1,921	1,819
Charles P Keller 12	3.0	(0.28)	2.72	365	434	406	370	323	2,225	2,111	2,021	1,920	1,818
Charles P Keller 13	3.0	(0.28)	2.72	365	434	406	370	323	2,225	2,111	2,021	1,920	1,818
Charles P Keller 14	3.4	(0.32)	3.08	365	434	406	369	323	2,225	2,110	2,021	1,920	1,818
Wading River 1, 2, & 3	231.4	(24.30)	207.10	161	230	202	165	119	2,021	1,906	1,817	1,716	1,614
Wading River 1	79.7	(8.37)	71.33	296	366	338	301	255	2,156	2,042	1,952	1,852	1,750
Wading River 2	76.4	(8.02)	68.38	299	369	341	304	257	2,159	2,045	1,955	1,855	1,753
Wading River 3	75.3	(7.91)	67.39	300	370	342	305	258	2,160	2,046	1,956	1,856	1,754
Barrett ST 01 & 02	383.0	(40.22)	342.79	25	94	66	30	(17)	1,885	1,770	1,681	1,580	1,478
Barrett ST 01	195.0	(20.48)	174.53	193	263	234	198	151	2,053	1,939	1,849	1,749	1,647
Barrett ST 02	188.0	(19.74)	168.26	199	269	241	204	158	2,060	1,945	1,855	1,755	1,653
Barrett GT 01 through 12	246.2	(23.90)	222.30	145	215	187	150	104	2,005	1,891	1,801	1,701	1,599
Barrett GT 01	14.0	(1.47)	12.53	355	425	396	360	313	2,215	2,101	2,011	1,911	1,809
Barrett GT 02	13.6	(1.43)	12.17	356	425	397	360	314	2,216	2,101	2,012	1,911	1,809
Barrett 03	13.7	(1.44)	12.26	355	425	397	360	314	2,216	2,101	2,011	1,911	1,809
Barrett 04	15.8	(1.66)	14.14	354	423	395	358	312	2,214	2,099	2,010	1,909	1,807
Barrett 05	13.5	(1.42)	12.08	356	425	397	360	314	2,216	2,101	2,012	1,911	1,809
Barrett 06	14.1	(1.48)	12.62	355	424	396	360	313	2,215	2,101	2,011	1,911	1,809
Barrett 08	12.3	(1.29)	11.01	357	426	398	361	315	2,217	2,102	2,013	1,912	1,810
Barrett 09	31.2	(2.87)	28.33	339	409	381	344	298	2,199	2,085	1,995	1,895	1,793
Barrett 10	39.6	(3.64)	35.96	332	401	373	336	290	2,192	2,077	1,988	1,887	1,785
Barrett 11	39.0	(3.58)	35.42	332	402	374	337	290	2,192	2,078	1,988	1,888	1,786
Barrett 12	39.4	(3.62)	35.78	332	401	373	337	290	2,192	2,077	1,988	1,887	1,785
Northport 1, 2, 3, and 4	1,553.9	(163.16)	1,390.74	(1,023)	(954)	(982)	(1,018)	(1,065)	837	722	633	532	430
Northport 1	398.0	(41.79)	356.21	12	81	53	16	(30)	1,872	1,757	1,667	1,567	1,465
Northport 2	399.4	(41.94)	357.46	10	80	51	15	(32)	1,870	1,756	1,666	1,566	1,464
Northport 3	388.5	(40.79)	347.71	20	89	61	25	(22)	1,880	1,766	1,676	1,575	1,473
Northport 4	368.0	(38.64)	329.36	38	108	80	43	(4)	1,898	1,784	1,694	1,594	1,492
Port Jefferson GT 02 & 03	80.6	(8.46)	72.14	296	365	337	300	254	2,156	2,041	1,952	1,851	1,749
Port Jefferson GT 02	40.6	(4.26)	36.34	331	401	373	336	290	2,191	2,077	1,987	1,887	1,785
Port Jefferson GT 03	40.0	(4.20)	35.80	332	401	373	337	290	2,192	2,077	1,988	1,887	1,785
Port Jefferson 3 & 4	383.7	(40.29)	343.41	24	94	66	29	(18)	1,884	1,770	1,680	1,580	1,478
Port Jefferson 3	189.7	(19.92)	169.78	198	267	239	203	156	2,058	1,943	1,854	1,753	1,651
Port Jefferson 4	194.0	(20.37)	173.63	194	263	235	199	152	2,054	1,940	1,850	1,750	1,648
Hempstead (RR)	74.8	(7.85)	66.95	301	370	342	305	259	2,161	2,046	1,957	1,856	1,754
Glenwood GT 02, 04, & 05	146.7	(15.40)	131.30	236	306	278	241	195	2,096	1,982	1,892	1,792	1,690
Glenwood GT 02	59.3	(6.23)	53.07	315	384	356	319	273	2,175	2,060	1,971	1,870	1,768
Glenwood GT 04	43.3	(4.55)	38.75	329	398	370	334	287	2,189	2,074	1,985	1,884	1,782
Glenwood GT 05	44.1	(4.63)	39.47	328	398	369	333	286	2,188	2,074	1,984	1,884	1,782
Holtsville 01 through 10	525.3	(48.28)	477.02	(109)	(40)	(68)	(105)	(151)	1,751	1,636	1,547	1,446	1,344
Holtsville 01	55.0	(5.05)	49.95	318	387	359	322	276	2,178	2,063	1,974	1,873	1,771
Holtsville 02	57.0	(5.24)	51.76	316	385	357	321	274	2,176	2,061	1,972	1,871	1,769
Holtsville 03	51.1	(4.70)	46.40	321	391	363	326	279	2,181	2,067	1,977	1,877	1,775
Holtsville 04	54.3	(4.99)	49.31	318	388	360	323	277	2,178	2,064	1,974	1,874	1,772
Holtsville 05	53.4	(4.91)	48.49	319	389	360	324	277	2,179	2,065	1,975	1,875	1,773
Holtsville 06	49.1	(4.51)	44.59	323	392	364	328	281	2,183	2,069	1,979	1,879	1,777
Holtsville 07	53.0	(4.87)	48.13	320	389	361	324	278	2,180	2,065	1,976	1,875	1,773
Holtsville 08	52.1	(4.79)	47.31	320	390	362	325	279	2,180	2,066	1,976	1,876	1,774
Holtsville 09	54.2	(4.98)	49.22	319	388	360	323	277	2,179	2,064	1,974	1,874	1,772
Holtsville 10	46.1	(4.24)	41.86	326	395	367	331	284	2,186	2,071	1,982	1,881	1,779



Additional Outage Impacts - Long Island													
Year				2025	2026	2027	2028	2029	2030	2031	2032	2033	2034
Long Island Transmission Security Margin, Summer Peak - High Demand Forecast Expected Summer Weather, Normal Transfer Criteria (MW) (1)				368	437	409	372	326	2,228	2,113	2,024	1,923	1,821
Unit Name	Summer DMNC (MW)	NERC 5-Year Class Average De-Rate (MW)	Summer De-Rated Capability (MW)	Transmission Security Margin Considering Outage of Generator/Plant (Retire, Mothball, or IIFO)									
Shoreham GT 3 & 4	83.3	(8.75)	74.55	293	362	334	298	251	2,153	2,039	1,949	1,849	1,747
Shoreham GT3	42.1	(4.42)	37.68	330	399	371	335	288	2,190	2,076	1,986	1,885	1,783
Shoreham GT4	41.2	(4.33)	36.87	331	400	372	336	289	2,191	2,076	1,987	1,886	1,784
East Hampton GT 01, 2, 3, & 4	24.2	(2.53)	21.67	346	415	387	351	304	2,206	2,092	2,002	1,901	1,799
East Hampton GT 01	18.2	(1.67)	16.53	351	421	392	356	309	2,211	2,097	2,007	1,907	1,805
East Hampton 2	2.0	(0.29)	1.71	366	435	407	371	324	2,226	2,112	2,022	1,921	1,819
East Hampton 3	2.0	(0.29)	1.71	366	435	407	371	324	2,226	2,112	2,022	1,921	1,819
East Hampton 4	2.0	(0.29)	1.71	366	435	407	371	324	2,226	2,112	2,022	1,921	1,819
Southold 1	9.4	(0.99)	8.41	359	429	401	364	317	2,219	2,105	2,015	1,915	1,813
S Hampton 1	7.8	(0.82)	6.98	361	430	402	365	319	2,221	2,106	2,017	1,916	1,814
Freeport CT 1 & 2	88.9	(9.33)	79.57	288	357	329	293	246	2,148	2,034	1,944	1,844	1,742
Freeport CT 1	45.9	(4.82)	41.08	327	396	368	331	285	2,187	2,072	1,983	1,882	1,780
Freeport CT 2	43.0	(4.52)	38.49	329	399	370	334	287	2,189	2,075	1,985	1,885	1,783
Flynn	139.5	(6.18)	133.32	234	304	276	239	193	2,094	1,980	1,890	1,790	1,688
Greenport GT1	51.2	(4.71)	46.49	321	391	362	326	279	2,181	2,067	1,977	1,877	1,775
Far Rockaway GT1 & GT2	104.6	(9.61)	94.99	273	342	314	277	231	2,133	2,018	1,929	1,828	1,726
Far Rockaway GT1	48.9	(4.49)	44.41	323	393	365	328	281	2,183	2,069	1,979	1,879	1,777
Far Rockaway GT2	55.7	(5.12)	50.58	317	386	358	322	275	2,177	2,063	1,973	1,873	1,771
Bethpage	52.0	(2.30)	49.70	318	387	359	323	276	2,178	2,064	1,974	1,873	1,771
Bethpage 3	76.0	(3.37)	72.63	295	364	336	300	253	2,155	2,041	1,951	1,851	1,749
Bethpage GT4	43.6	(4.58)	39.02	329	398	370	333	287	2,189	2,074	1,985	1,884	1,782
Stony Brook (BTM:NG)	0.0	0.00	0.00	368	437	409	372	326	2,228	2,113	2,024	1,923	1,821
Brentwood	45.0	(4.73)	40.28	327	397	369	332	286	2,187	2,073	1,983	1,883	1,781
Pilgrim GT1 & GT2	83.8	(8.80)	75.00	293	362	334	297	251	2,153	2,038	1,949	1,848	1,746
Pilgrim GT1	41.9	(4.40)	37.50	330	400	371	335	288	2,190	2,076	1,986	1,886	1,784
Pilgrim GT2	41.9	(4.40)	37.50	330	400	371	335	288	2,190	2,076	1,986	1,886	1,784
Pinelawn Power 1	73.4	(3.25)	70.15	298	367	339	302	256	2,158	2,043	1,954	1,853	1,751
Caithness_CC_1	306.9	(13.60)	293.30	74	144	116	79	33	1,934	1,820	1,730	1,630	1,528
Islip (RR)	8.5	(0.89)	7.61	360	429	401	365	318	2,220	2,106	2,016	1,916	1,814
Babylon (RR)	15.6	(1.64)	13.96	354	423	395	358	312	2,214	2,099	2,010	1,909	1,807
Huntington (RR)	24.7	(2.59)	22.11	346	415	387	350	304	2,206	2,091	2,002	1,901	1,799

#### Notes

1. Utilizes the Higher Demand Transmission Security Margin for Summer Peak with Expected Weather.