

Summary of Modification Requests Deemed Non-Material

Project Queue#	Project Name	Contemplated Change
717	Morris Ridge Solar Energy Center	Reduction in feeders from 8 to 7
865	Flat Hill Solar	Changing inverters to SunGrow SG3600UD.
885	Grassy Knoll Solar	Changing inverters to SunGrow SG3600UD.
956	Holtsville 138kV Energy Storage	Changing their gen tie cable route and site location for a more convenient ROW. The POI remains the same. The tie line has also been correction from 0.1 to 0.5 miles.
1340	Atlantic Shores Offshore Wind Bight 4	Changing POI to Brooklyn Clean Energy Hub because POI Farragut 345kV was determined physically infeasible