

Summary of Modification Requests Deemed Non-Material

Project Queue#	Project Name	Contemplated Change
519	Canisteo Wind	Updating wind turbines to 67 Vestas V150-4.5 from 69 Vestas V150-4.2.
815	Bayonne Energy Center III	GSU and PSU parameters updates, changing the size and number of shunt capacitors, the inverter manufacture, and the station service load.
843	Sandy Creek Solar	Shift Q843 along the line behind the tap connection of Q864. Both projects are to be combined behind a single HV breaker.
864	Greens Corners Solar	Move the project POI 0.2 miles to the north to accommodate Q843.