

HQTE – NYISO Cedars – Dennison Interface Transfer Limit

Raj Dontireddy

Manager, Operations Engineering (NYISO)

Operating Committee (OC):

May 16, 2024

Topics

- Purpose
- Background
- Proposed Export Limits
- Next Steps

Purpose

- To analyze the export limit on Cedars – Dennison Intertie

Background

PP24

- **The CRT-Dennison Interface export limit is subject to Presidential Permit 24 (PP24) granted to APGI-owned facilities. U.S. Department of Energy export permits that address exports to Canada over the PP24 facilities currently limit exports to 100 MW.**

Q430 Project

- **The expansion of Cedar Rapids Transmission (CRT) Intertie into the Dennison substation (“the CRT-Dennison Interface”) project involving the reconducting of a three-mile-long Niagara Mohawk Power Corp and National Grid (“NM-NG” or “National Grid”) 115 kV Alcoa – Dennison #12 line and installation of 25MVA capacitor bank at the Dennison substation**

Proposed Export Limits

Proposed Export Limit

- **NYISO recommends the export limit on CRT – Dennison interface to be increased to 200 MW for the summer operating period and 225 MW for the winter operating period.**

Next Steps

Next Steps

- **Seeking Approval at the Operating Committee (OC) meeting on May 16, 2024**

Our Mission & Vision



Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

Questions?