

# Establishing Zone J Operating Reserves

---

Ashley Ferrer

MARKET DESIGN SPECIALIST – ENERGY MARKET DESIGN

Market Issues Working Group

January 15, 2019, Rensselaer, NY



# Agenda

- Introduction
- Background
- NYISO Recommendation

# Introduction

# Introduction

- At the January 8, 2019 MIWG/ICAPWG meeting, NYISO proposed accelerating the market design and deploying a Zone J operating reserves requirement in June 2019.
- This presentation focuses on establishing a Zone J reserve requirement in the market by June 2019.
- This project is part of the ‘More Granular Operating Reserves’ project.

# Zone J Operating Reserves Timeline

- **An accelerated stakeholder engagement process and deployment timeline is required to implement a Zone J reserve requirement in June 2019.**
  - A customer impact assessment would not be separately completed for this component of the overall project prior to seeking stakeholder approval to implement a Zone J reserve requirement.
- **Proposed schedule for accelerated deployment:**
  - January and February 2019 (MIWG/ICAPWG)
    - Present/discuss market design and associated tariff revisions.
  - March 2019
    - BIC and MC vote on market design.
  - April 2019
    - Assuming stakeholder approval, seek Board of Directors approval.
    - Assuming approval by the Board of Directors, file tariff revisions with FERC seeking approval to implement in June 2019.

# More Granular Operating Reserves Timeline

- The deliverable for evaluating load pocket reserves and reviewing reserve performance would be Q3 2019 Market Design Complete.
- A consumer impact assessment would be completed as part of the remaining components of the project.
- Proposed stakeholder engagement plan:
  - Q2 2019
    - Present/discuss Market Design Concept Proposal.
  - Q3 2019
    - Present/discuss complete Market Design proposal and associated tariff revisions.

# Background

# Background

- This project has the potential to provide locationally specific market signals consistent with reliability needs.
- Establishing a separate Zone J Operating Reserves requirement was originally recommended in the 2017 State of the Market and 2018 Management Response to Analysis Group's *Capacity Resource Performance in the NYISO Markets: An Assessment of Wholesale Market Options* (Performance Assurance Management Response).
- Stakeholders also raised concerns regarding the current market design in connection with reviewing scarcity pricing outcomes during EDRP/SCR activations in summer 2018.



# State of the Market Recommendations

- **Implementing Zone J Operating Reserves in the market could address the following recommendation from the 2017 State of the Market Report.<sup>1</sup>**
  - Potomac Economics recommended that the NYISO consider implementing local reserve requirements in New York City.

1. See Recommendation 2017-1 in the 2017 State of the Market Report, located at the following link:  
<https://www.nyiso.com/documents/20142/2223763/2017-State-Of-The-Market-Report.pdf/cd4ee8a0-1989-dfa0-b53e-2d642c65e46d>

# Performance Assurance Management Response

- The Performance Assurance Management Response<sup>1</sup> indicated that the NYISO should consider establishing and securing a separate 10 minute reserve requirement for New York City.
  - New York State Reliability Council (NYSRC) reliability rules require that “[s]ufficient ten (10) minute operating reserves shall be maintained in the NYC zone” – NYSRC Reliability Rules.
  - Doing so would provide locationally specific market signals consistent with the reliability need.

1. Presentation: <https://www.nyiso.com/documents/20142/1409110/Performance%20Assurance%20Feb%202021%20ICAPWG%20FINAL.pdf/a102c473-49bf-ef35-77fa-3f871782011c>;
2. Management Response: <https://www.nyiso.com/documents/20142/1409110/Performance%20Assurance%20Management%20Response%20Feb%202021%20MIWG%20FINAL.PDF/d0417e14-f437-c79c-a032-8a48191ae71d>

# Summer 2018 EDRP/SCR Events

- **NYISO activated EDRP/SCR in Zone J three times in summer 2018 for operating reserve needs.**
  - Information on these activations and scarcity price outcomes were reviewed at the September 26, 2018 MC meeting and October 2, 2018 MIWG/ICAPWG meeting.
  - EDRP/SCR activations ranged from 480-495 MW each day.
  - Following these EDRP/SCR events, Potomac Economics reiterated in its Third Quarter 2018 report<sup>1</sup> its 2017 SOM recommendation that NYISO incorporate NYC reserve requirements into the market software.
- **During those EDRP/SCR activations, NYISO procured additional 30 minute reserves within Zone J consistent with the scarcity pricing rules.**
  - Average scarcity reserve requirement ranged from 326-337 MW each day.
  - Reserve shortage pricing was triggered in the market for only a handful of intervals, while the outcomes show that absent the EDRP/SCR activations, the NYC reserve needs would have been deficient frequently.
- **Following these activations, some market participants and Potomac Economics expressed support to include Zone J/NYC reserve requirements within the market as soon as possible.**

1. See slides 12 and 13 in Potomac Economics' "Quarterly Report on the New York ISO Electricity Markets Third Quarter of 2018"  
<https://www.nyiso.com/documents/20142/2927097/NYISO-Quarterly-Report-2018-Q3.pdf/fea3f24e-d2ea-e497-58c9-365c4d5e4c6a>

# NYSRC Reliability Rules<sup>1</sup>

- **NYSRC Rule G.B.R.3 requires roughly 500 MW of 10-minute operating reserve in NYC.**
  - Currently, SCUC produces a report which compares the amount of 10-minute reserve procured to the 500 MW requirement.
  - If this local reliability rule requirement is deficient, then the NYISO notifies Con Edison so that the transmission owner can take manual action to procure the necessary reserve.
- **The NYSRC rules, in Table C-2, requires 500 MW of 10-minute operating reserve and 1,000 MW of 30-minute operating reserves be procured in NYC for NYCA reliability.**
  - Currently, if these requirements are not satisfied by the procurement of other existing reserve requirements, NYISO Operations, working with Con Edison, will take manual action to procure the necessary reserves.
  - If a deficiency of this reserve requirement is forecasted, NYISO would evaluate activating SCR/EDRP resources, among other actions.
- **These requirements are not currently reflected in the NYISO's market software.**

1. NYSRC Reliability Rules: <http://www.nysrc.org/pdf/Reliability%20Rules%20Manuals/RRC%20Manual%20V43%20Final%5b4070%5d.pdf>

# NYISO Recommendation



# Zone J Operating Reserve Procurement


- The NYISO proposes to establish a new NYC reserve region and procure 500 MW of 10-minute reserves and 1,000 MW of 30-minute reserves in Zone J, consistent with NYSRC reliability rules for NYCA reliability.
- Creating a Zone J reserve region and associated reserve requirements has the potential to provide:
  - More efficient scheduling and procurement of resources.
  - Locationally specific market price signals for the necessary resource availability and flexibility to meet system reliability needs.
  - More efficient price signals during SCR/EDRP activations.

# NYCA Operating Reserves with Zone J

NYCA (Zone A – K)	
A=most severe NYCA Operating Capability Loss (1310 MWs)	
10 Min Spinning Reserve	½ A=655 MWs NYSRC Rule
10 Min Total Reserve	A=1310 MWs NYSRC Rule
30 Min Reserve	2xA=2620 MWs NYSRC Rule

East (Zone F – K)	
A=most severe NYCA Operating Capability Loss (1310 MWs)	
10 Min Spinning Reserve	¼ A=330 MWs NERC, NPCC Rule
10 Min Total Reserve	1200 MWs NYSRC Rule
30 Min Reserve	1200 MWs NERC, NPCC Rule

A	WEST
B	GENESE
C	CENTRL
D	NORTH
E	MHK VL
F	CAPITL
G	HUD VL
H	MILLWD
I	DUNWOD
J	N.Y.C.
K	LONGIL



NYC (Zone J)	
10 Min Total Reserve	500 MWs
30 Min Reserve	1000 MWs

SENY (Zone G – K)	
10 Min Spinning Reserve	0 MWs
10 Min Total Reserve	0 MWs
30 Min Reserve	1300 MWs NYSRC Rule

Long Island (Zone K)	
10 Min Spinning Reserve	0 MWs
10 Min Total Reserve	120 MW NERC, NPCC Rule
30 Min Reserve	270 – 540 MWs Max limits NYSRC Rule

# Zone J Operating Reserve Pricing

- The NYISO is currently considering the appropriate operating reserve demand curve prices for NYC reserves and will present its proposed pricing as part of further discussions regarding this proposal.
- During Thunderstorm Alerts (TSA), the Zone J reserve requirements and associated demand curve prices would not change.
  - Today the SENY 30-minute demand curve price is \$500/MW at all times.
    - During a TSA, the SENY 30-minute operating reserve requirement is reduced to 0 MW from 1,300 MW.
  - This would allow for an expedited implementation.
    - The NYISO will further consider whether changes to the NYC reserve demand curve pricing and/or requirements are necessary/appropriate during TSAs as part of the larger More Granular Operating Reserves project.



# Understanding the Market Impacts

- **During the January 8, 2019 working group meeting, stakeholders requested that the NYISO consider providing information on the implications for including a Zone J Operating Reserve requirement within the energy market.**
  - Stakeholders agreed that this does not need to take the form of a formal Consumer Impact Analysis.
- **The NYISO has considered this request and agrees to provide information regarding the impacts of including Zone J Operating Reserve requirements within the energy market.**
  - The NYISO plans to provide this information by the end of February 2019.

# Next steps:

Continue discussions at the January 24, 2019 MIWG/ICAPWG meeting.

# Feedback/Questions?

email: [deckels@nyiso.com](mailto:deckels@nyiso.com)

# The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



[www.nyiso.com](http://www.nyiso.com)