

| GE 7HA.03 with SCR and Dual Fuel | | | | | | |
|---|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|--------------------------------------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Number of Gas Turbines | 1 | 1 | 1 | 1 | 1 | 1 |
| Representative Class Gas Turbine | GE 7HA.03 | GE 7HA.03 | GE 7HA.03 | GE 7HA.03 | GE 7HA.03 | GE 7HA.03 |
| Assumed Land Use, Acres | 15 | 15 | 15 | 15 | 12 | 15 |
| Fuel Design | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) |
| Heat Rejection | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger |
| NO _x Control | Dry Low Nox / Water Injection / SCR | Dry Low Nox / Water Injection / SCR | Dry Low Nox / Water Injection / SCR | Dry Low Nox / Water Injection / SCR | Dry Low Nox / Water Injection / SCR | Dry Low Nox / Water Injection / SCR |
| CO Control | CO Catalyst | CO Catalyst | CO Catalyst | CO Catalyst | CO Catalyst | CO Catalyst |
| Particulate Control | Good Combustion | Good Combustion | Good Combustion | Good Combustion | Good Combustion | Good Combustion |
| Technology Rating | Practice | Practice | Practice | Practice | Practice | Practice |
| Permitting & Construction Schedule (Years from FNTF) | Mature | Mature | Mature | Mature | Mature | Mature |
| | 3 | 3 | 3 | 3 | 3 | 3 |
| ESTIMATED PERFORMANCE (BASED ON NATURAL GAS OPERATION) | | | | | | |
| Summer Base Load Performance | | | | | | |
| Net Plant Output, kW | 400,200 | 411,800 | 408,000 | 408,000 | 413,900 | 417,000 |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,000 | 9,000 | 9,000 | 9,000 | 9,000 | 9,000 |
| Heat Input, MMBtu/hr | 3,600 | 3,710 | 3,670 | 3,670 | 3,730 | 3,750 |
| Summer DMNC Base Load Performance | | | | | | |
| Net Plant Output, kW | 394,500 | 406,500 | 400,900 | 400,900 | 404,400 | 407,100 |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,000 | 9,000 | 9,040 | 9,040 | 9,060 | 9,060 |
| Heat Input, MMBtu/hr | 3,600 | 3,700 | 3,620 | 3,620 | 3,660 | 3,690 |
| Winter Base Load Performance | | | | | | |
| Net Plant Output, kW | 414,300 | 429,100 | 426,900 | 426,900 | 434,700 | 438,100 |
| Net Plant Heat Rate, Btu/kWh (HHV) | 8,930 | 8,870 | 8,850 | 8,850 | 8,830 | 8,830 |
| Heat Input, MMBtu/hr | 3,700 | 3,810 | 3,780 | 3,780 | 3,840 | 3,870 |
| Winter DMNC Base Load Performance | | | | | | |
| Net Plant Output, kW | 419,500 | 431,700 | 428,500 | 428,500 | 435,000 | 438,100 |
| Net Plant Heat Rate, Btu/kWh (HHV) | 8,800 | 8,800 | 8,820 | 8,820 | 8,820 | 8,830 |
| Heat Input, MMBtu/hr | 3,700 | 3,800 | 3,780 | 3,780 | 3,840 | 3,870 |
| ICAP Base Load Performance | | | | | | |
| Net Plant Output, kW | 389,000 | 400,300 | 397,400 | 397,400 | 404,100 | 404,000 |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,070 | 9,060 | 9,070 | 9,070 | 9,060 | 9,060 |
| Heat Input, MMBtu/hr | 3,530 | 3,630 | 3,600 | 3,600 | 3,660 | 3,660 |

| GE 7HA.03 with SCR and Dual Fuel | | | | | | |
|---|----------------|----------------|-------------------|-------------------|-----------------|-----------------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$423 | \$432 | \$435 | \$495 | \$551 | \$537 |
| Dual Fuel Breakout Costs, 2024 MM\$ (w/o Owner's Costs) | \$26.9 | \$26.9 | \$26.9 | Included | Included | Included |
| Owner's Costs, 2024 MM\$ | \$148 | \$148 | \$142 | \$143 | \$171 | \$137 |
| Owner's Project Development | \$1.2 | \$1.2 | \$1.2 | \$1.2 | \$1.6 | \$1.2 |
| Owner's Operational Personnel Prior to COD | \$0.3 | \$0.3 | \$0.3 | \$0.3 | \$0.4 | \$0.3 |
| Owner's Engineer | \$1.6 | \$1.6 | \$1.6 | \$1.6 | \$2.0 | \$1.6 |
| Owner's Project Management | \$1.6 | \$1.6 | \$1.6 | \$1.6 | \$2.0 | \$1.6 |
| Owner's Legal Costs | \$0.7 | \$0.7 | \$0.7 | \$0.7 | \$0.8 | \$0.7 |
| Owner's Start-up Engineering and Commissioning | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 |
| Land | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Construction Power and Water | \$0.5 | \$0.5 | \$0.5 | \$0.5 | \$0.7 | \$0.5 |
| Permitting Support | \$0.7 | \$0.7 | \$0.7 | \$0.7 | \$1.0 | \$0.7 |
| Switchyard | \$18.19 | \$18.2 | \$18.2 | \$18.2 | \$51.0 | \$13.0 |
| Transmission Line and Electrical Interconnection | \$26.05 | \$26.0 | \$26.0 | \$26.0 | \$29.3 | \$23.0 |
| Gas Interconnection and Reinforcement | \$35.4 | \$35.4 | \$35.4 | \$35.4 | \$15.5 | \$36.6 |
| System Deliverability Upgrade Costs | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Water Supply Infrastructure | \$9.6 | \$9.6 | \$3.2 | \$3.2 | \$6.8 | \$1.6 |
| Emission Reduction Credits | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Public Outreach and Area Development | \$0.6 | \$0.6 | \$0.6 | \$0.6 | \$0.8 | \$0.6 |
| Startup/Testing (Fuel & Consumables) | \$3.2 | \$3.2 | \$3.2 | \$3.2 | \$4.1 | \$3.2 |
| Initial Fuel Inventory | \$6.9 | \$6.9 | \$6.9 | \$6.9 | \$6.9 | \$6.9 |
| Site Security | \$0.7 | \$0.7 | \$0.7 | \$0.7 | \$0.9 | \$0.7 |
| Operating Spare Parts | \$10.0 | \$10.0 | \$10.0 | \$10.0 | \$10.0 | \$10.0 |
| Builders Risk Insurance (0.45% of Construction Costs) | \$2.0 | \$2.1 | \$2.1 | \$2.2 | \$2.5 | \$2.4 |
| Owner's Contingency (5% for Screening Purposes) | \$28.4 | \$28.9 | \$28.7 | \$30.4 | \$34.4 | \$32.1 |
| AFUDC, 2024 MM\$ | | | | | | |
| EPC Portion | \$41.6 | \$42.5 | \$42.7 | \$45.8 | \$50.2 | \$49.8 |
| Non-EPC Portion | \$13.7 | \$13.7 | \$13.1 | \$13.3 | \$15.6 | \$12.7 |
| Total Project Costs, 2024 MM\$ | \$652 | \$663 | \$659 | \$697 | \$787 | \$737 |
| EPC Cost Per kW, 2024 \$/kW (Note 1) | \$1,156 | \$1,146 | \$1,162 | \$1,244 | \$1,363 | \$1,330 |
| Total Cost Per kW, 2024 \$/kW (Note 1) | \$1,677 | \$1,656 | \$1,659 | \$1,754 | \$1,948 | \$1,823 |

| GE 7HA.03 with SCR and Dual Fuel | | | | | | |
|--|---------------|---------------|-------------------|-------------------|---------------|---------------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED O&M COSTS | | | | | | |
| ESTIMATED STARTUP FUEL USAGE Start to Base Load, MMBtu | 376 | 376 | 376 | 376 | 376 | 376 |
| FIXED O&M COSTS (Note 2) | | | | | | |
| Fixed O&M Cost - LABOR, 2024\$MM/Yr | \$1.11 | \$1.22 | \$1.44 | \$1.80 | \$1.93 | \$1.93 |
| Fixed O&M Cost - OTHER, 2024\$MM/Yr | \$1.61 | \$1.61 | \$1.61 | \$1.61 | \$1.61 | \$1.61 |
| Property Insurance Allowance | \$2.70 | \$2.75 | \$2.77 | \$2.97 | \$3.31 | \$3.22 |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.38 | \$0.38 | \$0.38 | \$0.38 | \$7.7 | \$0.5 |
| Total Fixed O&M, \$/kW-yr | \$14.9 | \$14.9 | \$15.6 | \$17.0 | \$36.1 | \$17.9 |
| LEVELIZED CAPITAL MAINTENANCE COSTS - GAS OPERATION | | | | | | |
| Major Maintenance Cost, 2024\$/GT-hr or \$/engine-hr (Note 3) | \$650 | \$650 | \$650 | \$650 | \$650 | \$650 |
| Major Maintenance Cost, 2024\$/GT-start | \$23,100 | \$23,100 | \$23,100 | \$23,100 | \$23,100 | \$23,100 |
| Major Maintenance Cost, 2024\$/MWh | \$1.57 | \$1.51 | \$1.52 | \$1.52 | \$1.49 | \$1.53 |
| NON-FUEL VARIABLE O&M COSTS (EXCLUDES MAJOR MAINTENANCE, Note 4) - GAS OPERATION | | | | | | |
| Total Variable O&M Cost, 2024\$/MWh | \$1.45 | \$1.45 | \$1.45 | \$1.45 | \$1.54 | \$1.50 |
| Water Related O&M, \$/MWh | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.04 | \$0.00 |
| SCR Related Costs, \$/MWh | \$0.55 | \$0.55 | \$0.55 | \$0.55 | \$0.60 | \$0.60 |
| Other Consumables and Variable O&M, \$/MWh | \$0.90 | \$0.90 | \$0.90 | \$0.90 | \$0.90 | \$0.90 |
| NON-FUEL VARIABLE O&M COSTS (EXCLUDES MAJOR MAINTENANCE, Note 4) - FUEL OIL OPERATION | | | | | | |
| Total Variable O&M Cost, 2024\$/MWh | \$8.75 | \$8.55 | \$8.59 | \$8.59 | \$8.73 | \$8.49 |
| Water Related O&M, \$/MWh | \$6.98 | \$6.77 | \$6.82 | \$6.82 | \$6.99 | \$6.72 |
| SCR Related Costs, \$/MWh | \$0.87 | \$0.88 | \$0.87 | \$0.87 | \$0.84 | \$0.87 |
| Other Consumables and Variable O&M, \$/MWh | \$0.90 | \$0.90 | \$0.90 | \$0.90 | \$0.90 | \$0.90 |

| GE 7HA.03 with SCR and Dual Fuel | | | | | | |
|---|---------|---------|-------------------|-------------------|---------|---------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED BASE LOAD OPERATING EMISSIONS: NATURAL GAS (Note 5) | | | | | | |
| GT emissions prior to SCR / CO Catalyst (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 332 | 341 | 339 | 339 | 345 | 341 |
| SO2 | 1 | 1 | 1 | 1 | 1 | 1 |
| CO | 48 | 50 | 50 | 50 | 50 | 50 |
| CO2 | 432,900 | 445,770 | 442,260 | 442,260 | 449,280 | 452,790 |
| Stack emissions with SCR and CO Catalust (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 27 | 27 | 27 | 27 | 28 | 27 |
| SO2 | 1 | 1 | 1 | 1 | 1 | 1 |
| CO | 4 | 4 | 4 | 4 | 4 | 4 |
| CO2 | 432,900 | 445,770 | 442,260 | 442,260 | 449,280 | 452,790 |
| ESTIMATED BASE LOAD OPERATING EMISSIONS: ULTRA-LOW SULFUR FUEL OIL (Note 7) | | | | | | |
| GT Operating, NO SCR / CO Catalyst (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 556 | 574 | 569 | 569 | 580 | 578 |
| SO2 | 3 | 3 | 3 | 3 | 3 | 3 |
| CO | 74 | 77 | 76 | 76 | 77 | 77 |
| CO2 | 616,470 | 635,909 | 630,818 | 630,818 | 642,369 | 640,557 |
| GT with SCR and CO Catalyst (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 79 | 82 | 81 | 81 | 83 | 83 |
| SO2 | 3 | 3 | 3 | 3 | 3 | 3 |
| CO | 11 | 11 | 11 | 11 | 11 | 11 |
| CO2 | 616,470 | 635,909 | 630,818 | 630,818 | 642,369 | 640,557 |
| Notes: | | | | | | |
| [1] \$/kW values based on ICAP net plant performance outputs. | | | | | | |
| [2] All gas turbine FOM costs assume 7 full time personnel for first unit. | | | | | | |
| [3] Major maintenance \$/hr and \$/start are NOT additive. The maintenance will be either starts or hours based depending on operating profile. If average hours/start > 35.6, then maintenance will be hours based. | | | | | | |
| [4] Gas operation only. VOM assumes the use of temporary trailers for demineralized water treatment, where applicable. | | | | | | |
| [5] Emissions estimates are shown for steady state operation at ISO conditions for natural gas, unless otherwise stated. Estimates account for the impacts of SCR and CO catalysts, as applicable. Emissions estimates should not be used for permitting. | | | | | | |
| [6] SO2 emissions on Natural Gas assume 0.2 gr/100 scf of sulfur in the gas. | | | | | | |
| [7] Fuel oil emissions based on ultra low sulfur diesel. Per the US EPA, this fuel must meet 15 ppm sulfur. | | | | | | |
| [8] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR. | | | | | | |
| [9] GE 7HA.03 gas-only with SCR design was evaluated for C, F, and both G locations. Performance, capital cost costs, O&M, costs, and emissions are identical to the above table with the exception of "Dual Fuel Breakout Costs," which are \$0 for the gas-only design. | | | | | | |

| GE 7HA.02 without SCR and with Dual Fuel | | | | | | |
|---|--------------------------------------|--------------------------------------|--------------------------------------|-------------------|--------|--------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Number of Gas Turbines | 1 | 1 | 1 | | | |
| Representative Class Gas Turbine | GE 7HA.02 | GE 7HA.02 | GE 7HA.02 | | | |
| Assumed Land Use, Acres | 15 | 15 | 15 | | | |
| Fuel Design | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | Dual Fuel (Natural Gas and Fuel Oil) | | | |
| Heat Rejection | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | Fin Fan Heat Exchanger | | | |
| NO _x Control | Dry Low Nox / Water Injection | Dry Low Nox / Water Injection | Dry Low Nox / Water Injection | | | |
| CO Control | Good Combustion Practice | Good Combustion Practice | Good Combustion Practice | | | |
| Particulate Control | Good Combustion Practice | Good Combustion Practice | Good Combustion Practice | | | |
| Technology Rating | Mature | Mature | Mature | | | |
| Permitting & Construction Schedule (Years from FNTTP) | 3 | 3 | 3 | | | |
| ESTIMATED PERFORMANCE (BASED ON NATURAL GAS OPERATION) | | | | | | |
| Summer Base Load Performance | | | | | | |
| Net Plant Output, kW | 330,966 | 340,717 | 337,404 | | | |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,123 | 9,123 | 9,123 | | | |
| Heat Input, MMBtu/hr | 3,020 | 3,105 | 3,077 | | | |
| Summer DMNC Base Load Performance | | | | | | |
| Net Plant Output, kW | 325,665 | 335,794 | 331,250 | | | |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,153 | 9,143 | 9,153 | | | |
| Heat Input, MMBtu/hr | 2,982 | 3,067 | 3,029 | | | |
| Winter Base Load Performance | | | | | | |
| Net Plant Output, kW | 357,001 | 365,048 | 360,977 | | | |
| Net Plant Heat Rate, Btu/kWh (HHV) | 8,993 | 8,973 | 8,963 | | | |
| Heat Input, MMBtu/hr | 3,209 | 3,276 | 3,238 | | | |
| Winter DMNC Base Load Performance | | | | | | |
| Net Plant Output, kW | 352,172 | 363,722 | 331,250 | | | |
| Net Plant Heat Rate, Btu/kWh (HHV) | 8,963 | 8,973 | 9,153 | | | |
| Heat Input, MMBtu/hr | 3,153 | 3,257 | 3,029 | | | |
| ICAP Base Load Performance | | | | | | |
| Net Plant Output, kW | 321,026 | 330,682 | 328,126 | | | |
| Net Plant Heat Rate, Btu/kWh (HHV) | 9,183 | 9,173 | 9,173 | | | |
| Heat Input, MMBtu/hr | 2,944 | 3,029 | 3,011 | | | |

| GE 7HA.02 without SCR and with Dual Fuel | | | | | | |
|---|-----------------|-----------------|-------------------|-------------------|--------|--------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$346.85 | \$355.06 | \$356.54 | | | |
| Dual Fuel Breakout Costs, 2024 MM\$ (w/o Owner's Costs) | \$26.9 | \$26.9 | \$26.9 | | | |
| Owner's Costs, 2024 MM\$ | \$144 | \$144 | \$137 | | | |
| Owner's Project Development | \$1.2 | \$1.2 | \$1.2 | | | |
| Owner's Operational Personnel Prior to COD | \$0.3 | \$0.3 | \$0.3 | | | |
| Owner's Engineer | \$1.6 | \$1.6 | \$1.6 | | | |
| Owner's Project Management | \$1.6 | \$1.6 | \$1.6 | | | |
| Owner's Legal Costs | \$0.7 | \$0.7 | \$0.7 | | | |
| Owner's Start-up Engineering and Commissioning | \$0.1 | \$0.1 | \$0.1 | | | |
| Land | \$0.0 | \$0.0 | \$0.0 | | | |
| Construction Power and Water | \$0.5 | \$0.5 | \$0.5 | | | |
| Permitting Support | \$0.7 | \$0.7 | \$0.7 | | | |
| Switchyard | \$18.19 | \$18.2 | \$18.2 | | | |
| Transmission Line and Electrical Interconnection | \$26.05 | \$26.0 | \$26.0 | | | |
| Gas Interconnection and Reinforcement | \$35.4 | \$35.4 | \$35.4 | | | |
| System Deliverability Upgrade Costs | \$0.0 | \$0.0 | \$0.0 | | | |
| Water Supply Infrastructure | \$9.6 | \$9.6 | \$3.2 | | | |
| Emission Reduction Credits | \$0.0 | \$0.0 | \$0.0 | | | |
| Public Outreach and Area Development | \$0.6 | \$0.6 | \$0.6 | | | |
| Startup/Testing (Fuel & Consumables) | \$3.2 | \$3.2 | \$3.2 | | | |
| Initial Fuel Inventory | \$6.9 | \$6.9 | \$6.9 | | | |
| Site Security | \$0.7 | \$0.7 | \$0.7 | | | |
| Operating Spare Parts | \$10.0 | \$10.0 | \$10.0 | | | |
| Builders Risk Insurance (0.45% of Construction Costs) | \$1.7 | \$1.7 | \$1.7 | | | |
| Owner's Contingency (5% for Screening Purposes) | \$24.6 | \$25.0 | \$24.8 | | | |
| AFUDC, 2024 MM\$ | | | | | | |
| EPC Portion | \$34.6 | \$35.4 | \$35.5 | | | |
| Non-EPC Portion | \$13.3 | \$13.3 | \$12.7 | | | |
| Total Project Costs, 2024 MM\$ | \$565 | \$575 | \$569 | | | |
| EPC Cost Per kW, 2024 \$/kW (Note 1) | \$1,164 | \$1,155 | \$1,169 | | | |
| Total Cost Per kW, 2024 \$/kW (Note 1) | \$1,760 | \$1,738 | \$1,734 | | | |

| GE 7HA.02 without SCR and with Dual Fuel | | | | | | |
|--|---------------|---------------|-------------------|-------------------|--------|--------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED O&M COSTS | | | | | | |
| ESTIMATED STARTUP FUEL USAGE Start to Base Load, MMBtu | 240 | 240 | 240 | | | |
| FIXED O&M COSTS (Note 2) | | | | | | |
| Fixed O&M Cost - LABOR, 2024\$MM/Yr | \$1.10 | \$1.20 | \$1.20 | | | |
| Fixed O&M Cost - OTHER, 2024\$MM/Yr | \$1.60 | \$1.60 | \$1.60 | | | |
| Property Insurance Allowance | \$2.24 | \$2.29 | \$2.30 | | | |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.38 | \$0.38 | \$0.38 | | | |
| Total Fixed O&M, \$/kW-yr | \$16.6 | \$16.6 | \$16.7 | | | |
| LEVELIZED CAPITAL MAINTENANCE COSTS | | | | | | |
| Major Maintenance Cost, 2024\$/GT-hr or \$/engine-hr (Note 3) | \$620 | \$620 | \$620 | | | |
| Major Maintenance Cost, 2024\$/GT-start | \$23,000 | \$23,000 | \$23,000 | | | |
| Major Maintenance Cost, 2024\$/MWh | \$1.72 | \$1.70 | \$1.70 | | | |
| NON-FUEL VARIABLE O&M COSTS (EXCLUDES MAJOR MAINTENANCE, Note 4) | | | | | | |
| Total Variable O&M Cost, 2024\$/MWh | \$0.90 | \$0.90 | \$0.90 | | | |
| Water Related O&M, \$/MWh | \$0.00 | \$0.00 | \$0.00 | | | |
| SCR Related Costs, \$/MWh | NA | NA | NA | | | |
| Other Consumables and Variable O&M, \$/MWh | \$0.90 | \$0.90 | \$0.90 | | | |
| NON-FUEL VARIABLE O&M COSTS (EXCLUDES MAJOR MAINTENANCE, Note 4) - FUEL OIL OPERATION | | | | | | |
| Total Variable O&M Cost, 2024\$/MWh | \$8.75 | \$8.55 | \$8.59 | | | |
| Water Related O&M, \$/MWh | \$6.98 | \$6.77 | \$6.82 | | | |
| SCR Related Costs, \$/MWh | \$0.87 | \$0.88 | \$0.87 | | | |
| Other Consumables and Variable O&M, \$/MWh | \$0.90 | \$0.90 | \$0.90 | | | |

| GE 7HA.02 without SCR and with Dual Fuel | | | | | | |
|--|---------|---------|-------------------|-------------------|--------|--------|
| | ZONE C | ZONE F | ZONE G - Dutchess | Zone G - Rockland | ZONE J | ZONE K |
| ESTIMATED BASE LOAD OPERATING EMISSIONS: NATURAL GAS (Note 5) | | | | | | |
| GT emissions prior to SCR / CO Catalyst (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 332 | 341 | 339 | | | |
| SO2 | 1 | 1 | 1 | | | |
| CO | 48 | 50 | 50 | | | |
| CO2 | 432,900 | 430,560 | 442,260 | | | |
| ESTIMATED BASE LOAD OPERATING EMISSIONS: ULTRA-LOW SULFUR FUEL OIL (Note 7) | | | | | | |
| GT Operating, NO SCR / CO Catalyst (lb/hr, HHV) (Note 6) | | | | | | |
| NOX | 556 | 574 | 569 | | | |
| SO2 | 3 | 3 | 3 | | | |
| CO | 74 | 77 | 76 | | | |
| CO2 | 616,470 | 635,909 | 630,818 | | | |

Notes:

- [1] \$/kW values based on ICAP net plant performance outputs.
- [2] All gas turbine FOM costs assume 7 full time personnel for first unit.
- [3] Major maintenance \$/hr and \$/start are NOT additive. The maintenance will be either starts or hours based depending on operating profile. If average hours/start > 35.6, then maintenance will be hours based.
- [4] Gas operation only. VOM assumes the use of temporary trailers for demineralized water treatment, where applicable.
- [5] Emissions estimates are shown for steady state operation at ISO conditions for natural gas, unless otherwise stated. Estimates account for the impacts of SCR and CO catalysts, as applicable. Emissions estimates should not be used for permitting.
- [6] SO2 emissions on Natural Gas assume 0.2 gr/100 scf of sulfur in the gas.
- [7] Fuel oil emissions based on ultra low sulfur diesel. Per the US EPA, this fuel must meet 15 ppm sulfur.
- [8] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR.
- [9] GE 7HA.02 gas-only without SCR design was evaluated for C, F, and G (Dutchess County). Performance, capital cost costs, O&M, costs, and emissions are identical to the above table with the exception of "Dual Fuel Breakout Costs," which are \$0 for the gas-only design.

| 200 MW / 2-hr Lithium-Ion Battery Energy Storage System | | | | | | |
|--|---------------|---------------|--------------------------|--------------------------|---------------|---------------|
| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Nominal Output, MW | 200 | 200 | 200 | 200 | 200 | 200 |
| Nominal Duration, hr | 2 | 2 | 2 | 2 | 2 | 2 |
| Assumed Useful Life (years) | 20 | 20 | 20 | 20 | 20 | 20 |
| Equivalent Availability Factor (%) | 98% | 98% | 98% | 98% | 98% | 98% |
| Assumed Land Use During Operation, Acres (Not Construction Land Use) | 10 | 10 | 10 | 10 | 6 | 9 |
| Annual System Cycles | 365 | 365 | 365 | 365 | 365 | 365 |
| Storage System Initial Overbuild (Years) | 4 | 4 | 4 | 4 | 4 | 4 |
| Storage System AC Roundtrip Efficiency (%) | 85% | 85% | 85% | 85% | 85% | 85% |
| Interconnection Voltage, kV | 345 | 345 | 345 | 345 | 345 | 138 |
| Technology Rating | Mature | Mature | Mature | Mature | Mature | Mature |
| EPC Schedule (Years from NTP) | 2.50 | 2.50 | 2.50 | 2.50 | 2.50 | 2.50 |
| ESTIMATED PERFORMANCE | | | | | | |
| BESS Performance | | | | | | |
| Net Plant Output, kW | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 |
| Discharge Duration, hr | 2 | 2 | 2 | 2 | 2 | 2 |
| Net Plant Energy Capacity, kWh | 400,000 | 400,000 | 400,000 | 400,000 | 400,000 | 400,000 |
| Energy Capacity Installed with Overbuild, kWh AC at POI | 451,500 | 451,500 | 451,500 | 451,500 | 451,500 | 451,500 |

200 MW / 2-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|---|----------------|----------------|--------------------------|--------------------------|----------------|----------------|
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$167.8 | \$169.2 | \$167.9 | \$173.9 | \$206.1 | \$177.8 |
| Owner's Cost Allowances, 2024 MM\$ | \$61.2 | \$61.3 | \$61.2 | \$61.5 | \$102.7 | \$53.1 |
| Owner's Project Development | \$0.680 | \$0.680 | \$0.680 | \$0.680 | \$0.880 | \$0.680 |
| Owner's Operational Personnel Prior to COD | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 |
| Owner's Engineer | \$0.560 | \$0.560 | \$0.560 | \$0.560 | \$0.730 | \$0.560 |
| Owner's Project Management | \$0.830 | \$0.830 | \$0.830 | \$0.830 | \$1.080 | \$0.830 |
| Owner's Legal Costs | \$0.650 | \$0.650 | \$0.650 | \$0.650 | \$0.850 | \$0.650 |
| Owner's Start-up Engineering and Commissioning | \$0.060 | \$0.060 | \$0.060 | \$0.060 | \$0.080 | \$0.060 |
| Sales Tax | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Construction Power and Water | \$0.170 | \$0.170 | \$0.170 | \$0.170 | \$0.220 | \$0.170 |
| Permitting Support | \$0.980 | \$0.980 | \$0.980 | \$0.980 | \$1.270 | \$0.980 |
| Switchyard | \$18.190 | \$18.190 | \$18.190 | \$18.190 | \$51.040 | \$13.030 |
| Transmission Line and Electrical Interconnection | \$26.050 | \$26.050 | \$26.050 | \$26.050 | \$29.290 | \$23.030 |
| Gas Interconnection and Reinforcement | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| System Deliverability Upgrade Costs | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Water Supply Infrastructure | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Emission Reduction Credits | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Public Outreach and Area Development | \$0.280 | \$0.280 | \$0.280 | \$0.280 | \$0.360 | \$0.280 |
| Startup/Testing (Fuel & Consumables) | \$0.050 | \$0.050 | \$0.050 | \$0.050 | \$0.070 | \$0.050 |
| Initial Fuel Inventory | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Site Security | \$0.440 | \$0.440 | \$0.440 | \$0.440 | \$0.570 | \$0.440 |
| Operating Spare Parts | \$0.500 | \$0.500 | \$0.500 | \$0.500 | \$0.500 | \$0.500 |
| Builders Risk Insurance (0.45% of Construction Costs) | \$0.8 | \$0.8 | \$0.8 | \$0.8 | \$0.9 | \$0.8 |
| Owner's Contingency (5% for Screening Purposes) | \$10.9 | \$11.0 | \$10.9 | \$11.2 | \$14.7 | \$11.0 |
| AFUDC, 2024 MM\$ | \$18 | \$18 | \$18 | \$19 | \$24 | \$18 |
| EPC Portion | \$13.4 | \$13.5 | \$13.4 | \$13.9 | \$16.2 | \$14.2 |
| Non-EPC Portion | \$4.9 | \$4.9 | \$4.9 | \$4.9 | \$8.1 | \$4.2 |
| Total Project Costs, 2024 MM\$ | \$247 | \$249 | \$247 | \$254 | \$333 | \$249 |
| EPC Cost Per kW, 2024 \$/kW | \$839 | \$846 | \$840 | \$869 | \$1,031 | \$889 |
| Total Cost Per kW, 2024 \$/kW | \$1,236 | \$1,244 | \$1,237 | \$1,271 | \$1,665 | \$1,247 |
| EPC Cost Per kWh, 2024 \$/kWh AC at POI | \$372 | \$375 | \$372 | \$385 | \$456 | \$394 |
| Total Cost Per kWh, 2024 \$/kWh AC at POI | \$548 | \$551 | \$548 | \$563 | \$738 | \$552 |

200 MW / 2-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|--|---------|---------|-------------------|-------------------|---------|---------|
| ESTIMATED O&M COSTS | | | | | | |
| FIXED O&M COSTS | | | | | | |
| Fixed O&M Cost - Assumes LTSA with Integrator/OEM, 2024\$MM/Yr | \$2.4 | \$2.4 | \$2.4 | \$2.4 | \$2.4 | \$2.4 |
| Capacity Maintenance Agreement (Fixed Portion Levelized), 2024\$MM/Yr | \$0.9 | \$0.9 | \$0.9 | \$0.9 | \$0.9 | \$0.9 |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.3 | \$0.3 | \$0.3 | \$0.3 | \$3.9 | \$0.3 |
| Property Insurance Allowance, 2024\$MM/Yr | \$1.0 | \$1.0 | \$1.0 | \$1.0 | \$1.2 | \$1.1 |
| Total Fixed O&M, \$/kW-yr | \$22.68 | \$22.73 | \$22.69 | \$22.87 | \$41.85 | \$23.03 |
| VARIABLE O&M COSTS (Augmentation Model) | | | | | | |
| Capacity Maintenance Agreement (Variable Portion Levelized), 2024 \$/MWh | \$6.68 | \$6.68 | \$6.68 | \$6.68 | \$6.68 | \$6.68 |

Notes

[1] EPC electrical scope ends at the high side of the GSU. Includes engineering, procurement, construction (EPC) contracting methodology.

[2] EPC cost accounts for BESS sizing that accommodates system losses, equipment efficiencies, minimum state of charge, aux load, degradation during shipping/construction, and 4 years of overbuild.

[3] Battery FOM accounts for routine BESS and PCS maintenance, BOP maintenance, remote monitoring, asset management, performance guarantees, extended warranties, standby/idle aux loads, and an inverter replacement allowance.

[4] Augmentation typically occurs in milestone events, but the total lifetime augmentation estimates are levelized here, intended to account for maintaining rated energy capacity for 20-year life. Augmentation estimates are modeled in fixed and variable components to allow for cycle adjustments in DCR (both components together make up the augmentation estimate).

[5] Availability and outage rate assumptions are based on vendor correspondence and industry publications.

[6] Estimated Costs exclude decommissioning costs and salvage values.

[7] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR.

| 200 MW / 4-hr Lithium-Ion Battery Energy Storage System | | | | | | |
|--|---------|---------|-------------------|-------------------|---------|---------|
| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Nominal Output, MW | 200 | 200 | 200 | 200 | 200 | 200 |
| Nominal Duration, hr | 4 | 4 | 4 | 4 | 4 | 4 |
| Assumed Useful Life (years) | 20 | 20 | 20 | 20 | 20 | 20 |
| Equivalent Availability Factor (%) | 98% | 98% | 98% | 98% | 98% | 98% |
| Assumed Land Use During Operation, Acres (Not Construction Land Use) | 14 | 14 | 14 | 14 | 9 | 12 |
| Annual System Cycles | 365 | 365 | 365 | 365 | 365 | 365 |
| Storage System Initial Overbuild (Years) | 4 | 4 | 4 | 4 | 4 | 4 |
| Storage System AC Roundtrip Efficiency (%) | 85% | 85% | 85% | 85% | 85% | 85% |
| Interconnection Voltage, kV | 345 | 345 | 345 | 345 | 345 | 138 |
| Technology Rating | Mature | Mature | Mature | Mature | Mature | Mature |
| EPC Schedule (Years from NTP) | 2.75 | 2.75 | 2.75 | 2.75 | 2.75 | 2.75 |
| ESTIMATED PERFORMANCE | | | | | | |
| BESS Performance | | | | | | |
| Net Plant Output, kW | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 |
| Discharge Duration, hr | 4 | 4 | 4 | 4 | 4 | 4 |
| Net Plant Energy Capacity, kWh | 800,000 | 800,000 | 800,000 | 800,000 | 800,000 | 800,000 |
| Energy Capacity Installed with Overbuild, kWh AC at POI | 903,200 | 903,200 | 903,200 | 903,200 | 903,200 | 903,200 |

200 MW / 4-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|---|----------------|----------------|-------------------|-------------------|----------------|----------------|
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$289 | \$291 | \$289 | \$298 | \$361 | \$304 |
| Owner's Cost Allowances, 2024 MM\$ | \$68.5 | \$68.6 | \$68.5 | \$69.0 | \$111.8 | \$60.7 |
| Owner's Project Development | \$0.7 | \$0.7 | \$0.7 | \$0.7 | \$0.9 | \$0.7 |
| Owner's Operational Personnel Prior to COD | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 |
| Owner's Engineer | \$0.6 | \$0.6 | \$0.6 | \$0.6 | \$0.8 | \$0.6 |
| Owner's Project Management | \$0.9 | \$0.9 | \$0.9 | \$0.9 | \$1.2 | \$0.9 |
| Owner's Legal Costs | \$0.7 | \$0.7 | \$0.7 | \$0.7 | \$0.9 | \$0.7 |
| Owner's Start-up Engineering and Commissioning | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 |
| Sales Tax | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Construction Power and Water | \$0.2 | \$0.2 | \$0.2 | \$0.2 | \$0.2 | \$0.2 |
| Permitting Support | \$1.0 | \$1.0 | \$1.0 | \$1.0 | \$1.3 | \$1.0 |
| Switchyard | \$18.2 | \$18.2 | \$18.2 | \$18.2 | \$51.0 | \$13.0 |
| Transmission Line and Electrical Interconnection | \$26.1 | \$26.1 | \$26.1 | \$26.1 | \$29.3 | \$23.0 |
| Gas Interconnection and Reinforcement | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| System Deliverability Upgrade Costs | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Water Supply Infrastructure | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Emission Reduction Credits | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Public Outreach and Area Development | \$0.3 | \$0.3 | \$0.3 | \$0.3 | \$0.4 | \$0.3 |
| Startup/Testing (Fuel & Consumables) | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 | \$0.1 |
| Initial Fuel Inventory | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 | \$0.0 |
| Site Security | \$0.4 | \$0.4 | \$0.4 | \$0.4 | \$0.6 | \$0.4 |
| Operating Spare Parts | \$1.0 | \$1.0 | \$1.0 | \$1.0 | \$1.0 | \$1.0 |
| Builders Risk Insurance (0.45% of Construction Costs) | \$1.3 | \$1.3 | \$1.3 | \$1.3 | \$1.6 | \$1.4 |
| Owner's Contingency (5% for Screening Purposes) | \$17.0 | \$17.1 | \$17.0 | \$17.5 | \$22.5 | \$17.4 |
| AFUDC, 2024 MM\$ | \$29 | \$29 | \$29 | \$29 | \$37 | \$29 |
| EPC Portion | \$23.2 | \$23.4 | \$23.2 | \$23.9 | \$28.6 | \$24.5 |
| Non-EPC Portion | \$5.5 | \$5.5 | \$5.5 | \$5.5 | \$8.9 | \$4.9 |
| Total Project Costs, 2024 MM\$ | \$386 | \$388 | \$386 | \$396 | \$510 | \$394 |
| EPC Cost Per kW, 2024 \$/kW | \$1,445 | \$1,454 | \$1,445 | \$1,488 | \$1,803 | \$1,521 |
| Total Cost Per kW, 2024 \$/kW | \$1,931 | \$1,942 | \$1,932 | \$1,980 | \$2,549 | \$1,971 |
| EPC Cost Per kWh, 2024 \$/kWh AC at POI | \$320 | \$322 | \$320 | \$329 | \$399 | \$337 |
| Total Cost Per kWh, 2024 \$/kWh AC at POI | \$428 | \$430 | \$428 | \$438 | \$565 | \$436 |

200 MW / 4-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|--|---------------|---------------|--------------------------|--------------------------|---------------|---------------|
| ESTIMATED O&M COSTS | | | | | | |
| FIXED O&M COSTS | | | | | | |
| Fixed O&M Cost - Assumes LTSA with Integrator/OEM, 2024\$MM/Yr | \$3.9 | \$3.9 | \$3.9 | \$3.9 | \$3.9 | \$3.9 |
| Capacity Maintenance Agreement (Fixed Portion Levelized), 2024\$MM/Yr | \$1.6 | \$1.6 | \$1.6 | \$1.6 | \$1.6 | \$1.6 |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.4 | \$0.4 | \$0.4 | \$0.4 | \$5.8 | \$0.4 |
| Property Insurance Allowance, 2024\$MM/Yr | \$1.7 | \$1.7 | \$1.7 | \$1.8 | \$2.2 | \$1.8 |
| Total Fixed O&M, \$/kW-yr | \$37.62 | \$37.68 | \$37.62 | \$37.88 | \$66.95 | \$38.08 |
| VARIABLE O&M COSTS (Augmentation Model) | | | | | | |
| Capacity Maintenance Agreement (Variable Portion Levelized), 2024 \$/MWh | \$6.80 | \$6.80 | \$6.80 | \$6.80 | \$6.80 | \$6.80 |

Notes

[1] EPC electrical scope ends at the high side of the GSU. Includes engineering, procurement, construction (EPC) contracting methodology.

[2] EPC cost accounts for BESS sizing that accommodates system losses, equipment efficiencies, minimum state of charge, aux load, degradation during shipping/construction, and 4 years of overbuild.

[3] Battery FOM accounts for routine BESS and PCS maintenance, BOP maintenance, remote monitoring, asset management, performance guarantees, extended warranties, standby/idle aux loads, and an inverter replacement allowance.

[4] Augmentation typically occurs in milestone events, but the total lifetime augmentation estimates are levelized here, intended to account for maintaining rated energy capacity for 20-year life. Augmentation estimates are modeled in fixed and variable components to allow for cycle adjustments in DCR (both components together make up the augmentation estimate).

[5] Availability and outage rate assumptions are based on vendor correspondence and industry publications.

[6] Estimated Costs exclude decommissioning costs and salvage values.

[7] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR.

| 200 MW / 6-hr Lithium-Ion Battery Energy Storage System | | | | | | |
|--|---------------|---------------|--------------------------|--------------------------|---------------|---------------|
| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Nominal Output, MW | 200 | 200 | 200 | 200 | 200 | 200 |
| Nominal Duration, hr | 6 | 6 | 6 | 6 | 6 | 6 |
| Assumed Useful Life (years) | 20 | 20 | 20 | 20 | 20 | 20 |
| Equivalent Availability Factor (%) | 98% | 98% | 98% | 98% | 98% | 98% |
| Assumed Land Use During Operation, Acres (Not Construction Land Use) | 18 | 18 | 18 | 18 | 12 | 16 |
| Annual System Cycles | 365 | 365 | 365 | 365 | 365 | 365 |
| Storage System Initial Overbuild (Years) | 4 | 4 | 4 | 4 | 4 | 4 |
| Storage System AC Roundtrip Efficiency (%) | 85% | 85% | 85% | 85% | 85% | 85% |
| Interconnection Voltage, kV | 345 | 345 | 345 | 345 | 345 | 138 |
| Technology Rating | Mature | Mature | Mature | Mature | Mature | Mature |
| EPC Schedule (Years from NTP) | 3.00 | 3.00 | 3.00 | 3.00 | 3.00 | 3.00 |
| ESTIMATED PERFORMANCE | | | | | | |
| BESS Performance | | | | | | |
| Net Plant Output, kW | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 |
| Discharge Duration, hr | 6 | 6 | 6 | 6 | 6 | 6 |
| Net Plant Energy Capacity, kWh | 1,200,000 | 1,200,000 | 1,200,000 | 1,200,000 | 1,200,000 | 1,200,000 |
| Energy Capacity Installed with Overbuild, kWh AC at POI | 1,354,800 | 1,354,800 | 1,354,800 | 1,354,800 | 1,354,800 | 1,354,800 |

200 MW / 6-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|---|----------------|----------------|--------------------------|--------------------------|----------------|----------------|
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$418 | \$421 | \$418 | \$430 | \$512 | \$440 |
| Owner's Cost Allowances, 2024 MM\$ | \$76.5 | \$76.6 | \$76.5 | \$77.2 | \$121.2 | \$69.1 |
| Owner's Project Development | \$0.710 | \$0.710 | \$0.710 | \$0.710 | \$0.920 | \$0.710 |
| Owner's Operational Personnel Prior to COD | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 |
| Owner's Engineer | \$0.640 | \$0.640 | \$0.640 | \$0.640 | \$0.830 | \$0.640 |
| Owner's Project Management | \$0.940 | \$0.940 | \$0.940 | \$0.940 | \$1.220 | \$0.940 |
| Owner's Legal Costs | \$0.650 | \$0.650 | \$0.650 | \$0.650 | \$0.850 | \$0.650 |
| Owner's Start-up Engineering and Commissioning | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.100 | \$0.080 |
| Sales Tax | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Construction Power and Water | \$0.180 | \$0.180 | \$0.180 | \$0.180 | \$0.230 | \$0.180 |
| Permitting Support | \$1.060 | \$1.060 | \$1.060 | \$1.060 | \$1.380 | \$1.060 |
| Switchyard | \$18.190 | \$18.190 | \$18.190 | \$18.190 | \$51.040 | \$13.030 |
| Transmission Line and Electrical Interconnection | \$26.050 | \$26.050 | \$26.050 | \$26.050 | \$29.290 | \$23.030 |
| Gas Interconnection and Reinforcement | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| System Deliverability Upgrade Costs | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Water Supply Infrastructure | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Emission Reduction Credits | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Public Outreach and Area Development | \$0.280 | \$0.280 | \$0.280 | \$0.280 | \$0.360 | \$0.280 |
| Startup/Testing (Fuel & Consumables) | \$0.150 | \$0.150 | \$0.150 | \$0.150 | \$0.200 | \$0.150 |
| Initial Fuel Inventory | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Site Security | \$0.550 | \$0.550 | \$0.550 | \$0.550 | \$0.720 | \$0.550 |
| Operating Spare Parts | \$1.500 | \$1.500 | \$1.500 | \$1.500 | \$1.500 | \$1.500 |
| Builders Risk Insurance (0.45% of Construction Costs) | \$1.9 | \$1.9 | \$1.9 | \$1.9 | \$2.3 | \$2.0 |
| Owner's Contingency (5% for Screening Purposes) | \$23.6 | \$23.7 | \$23.6 | \$24.2 | \$30.2 | \$24.3 |
| AFUDC, 2024 MM\$ | \$47 | \$47 | \$47 | \$48 | \$59 | \$48 |
| EPC Portion | \$39.6 | \$39.8 | \$39.6 | \$40.7 | \$47.7 | \$41.7 |
| Non-EPC Portion | \$7.2 | \$7.3 | \$7.2 | \$7.3 | \$11.3 | \$6.5 |
| Total Project Costs, 2024 MM\$ | \$541 | \$544 | \$542 | \$555 | \$692 | \$558 |
| EPC Cost Per kW, 2024 \$/kW | \$2,090 | \$2,104 | \$2,091 | \$2,150 | \$2,560 | \$2,202 |
| Total Cost Per kW, 2024 \$/kW | \$2,707 | \$2,722 | \$2,708 | \$2,776 | \$3,461 | \$2,788 |
| EPC Cost Per kWh, 2024 \$/kWh AC at POI | \$309 | \$311 | \$309 | \$317 | \$378 | \$325 |
| Total Cost Per kWh, 2024 \$/kWh AC at POI | \$400 | \$402 | \$400 | \$410 | \$511 | \$412 |

200 MW / 6-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|--|---------|---------|-------------------|-------------------|---------|---------|
| ESTIMATED O&M COSTS | | | | | | |
| FIXED O&M COSTS | | | | | | |
| Fixed O&M Cost - Assumes LTSA with Integrator/OEM, 2024\$MM/Yr | \$5.4 | \$5.4 | \$5.4 | \$5.4 | \$5.4 | \$5.4 |
| Capacity Maintenance Agreement (Fixed Portion Levelized), 2024\$MM/Yr | \$2.3 | \$2.3 | \$2.3 | \$2.3 | \$2.3 | \$2.3 |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.5 | \$0.5 | \$0.5 | \$0.5 | \$7.7 | \$0.5 |
| Property Insurance Allowance, 2024\$MM/Yr | \$2.5 | \$2.5 | \$2.5 | \$2.6 | \$3.1 | \$2.6 |
| Total Fixed O&M, \$/kW-yr | \$53.34 | \$53.42 | \$53.35 | \$53.70 | \$92.50 | \$54.11 |
| VARIABLE O&M COSTS (Augmentation Model) | | | | | | |
| Capacity Maintenance Agreement (Variable Portion Levelized), 2024 \$/MWh | \$6.56 | \$6.56 | \$6.56 | \$6.56 | \$6.56 | \$6.56 |

Notes

[1] EPC electrical scope ends at the high side of the GSU. Includes engineering, procurement, construction (EPC) contracting methodology.

[2] EPC cost accounts for BESS sizing that accommodates system losses, equipment efficiencies, minimum state of charge, aux load, degradation during shipping/construction, and 4 years of overbuild.

[3] Battery FOM accounts for routine BESS and PCS maintenance, BOP maintenance, remote monitoring, asset management, performance guarantees, extended warranties, standby/idle aux loads, and an inverter replacement allowance.

[4] Augmentation typically occurs in milestone events, but the total lifetime augmentation estimates are levelized here, intended to account for maintaining rated energy capacity for 20-year life. Augmentation estimates are modeled in fixed and variable components to allow for cycle adjustments in DCR (both components together make up the augmentation estimate).

[5] Availability and outage rate assumptions are based on vendor correspondence and industry publications.

[6] Estimated Costs exclude decommissioning costs and salvage values.

[7] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR.

| 200 MW / 8-hr Lithium-Ion Battery Energy Storage System | | | | | | |
|--|-----------|-----------|-------------------|-------------------|-----------|-----------|
| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
| BASE PLANT DESCRIPTION | | | | | | |
| Nominal Output, MW | 200 | 200 | 200 | 200 | 200 | 200 |
| Nominal Duration, hr | 8 | 8 | 8 | 8 | 8 | 8 |
| Assumed Useful Life (years) | 20 | 20 | 20 | 20 | 20 | 20 |
| Equivalent Availability Factor (%) | 98% | 98% | 98% | 98% | 98% | 98% |
| Assumed Land Use During Operation, Acres (Not Construction Land Use) | 22 | 22 | 22 | 22 | 15 | 20 |
| Annual System Cycles | 365 | 365 | 365 | 365 | 365 | 365 |
| Storage System Initial Overbuild (Years) | 4 | 4 | 4 | 4 | 4 | 4 |
| Storage System AC Roundtrip Efficiency (%) | 85% | 85% | 85% | 85% | 85% | 85% |
| Interconnection Voltage, kV | 345 | 345 | 345 | 345 | 345 | 138 |
| Technology Rating | Mature | Mature | Mature | Mature | Mature | Mature |
| EPC Schedule (Years from NTP) | 3.25 | 3.25 | 3.25 | 3.25 | 3.25 | 3.25 |
| ESTIMATED PERFORMANCE | | | | | | |
| BESS Performance | | | | | | |
| Net Plant Output, kW | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 | 200,000 |
| Discharge Duration, hr | 8 | 8 | 8 | 8 | 8 | 8 |
| Net Plant Energy Capacity, kWh | 1,600,000 | 1,600,000 | 1,600,000 | 1,600,000 | 1,600,000 | 1,600,000 |
| Energy Capacity Installed with Overbuild, kWh AC at POI | 1,806,400 | 1,806,400 | 1,806,400 | 1,806,400 | 1,806,400 | 1,806,400 |

200 MW / 8-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|---|----------------|----------------|--------------------------|--------------------------|----------------|----------------|
| ESTIMATED CAPITAL COSTS | | | | | | |
| EPC Project Capital Costs, 2024 MM\$ (w/o Owner's Costs) | \$540 | \$543 | \$540 | \$555 | \$664 | \$569 |
| Owner's Cost Allowances, 2024 MM\$ | \$84.1 | \$84.3 | \$84.2 | \$85.0 | \$130.6 | \$77.1 |
| Owner's Project Development | \$0.730 | \$0.730 | \$0.730 | \$0.730 | \$0.950 | \$0.730 |
| Owner's Operational Personnel Prior to COD | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 | \$0.080 |
| Owner's Engineer | \$0.720 | \$0.720 | \$0.720 | \$0.720 | \$0.940 | \$0.720 |
| Owner's Project Management | \$1.000 | \$1.000 | \$1.000 | \$1.000 | \$1.300 | \$1.000 |
| Owner's Legal Costs | \$0.650 | \$0.650 | \$0.650 | \$0.650 | \$0.850 | \$0.650 |
| Owner's Start-up Engineering and Commissioning | \$0.110 | \$0.110 | \$0.110 | \$0.110 | \$0.140 | \$0.110 |
| Sales Tax | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Construction Power and Water | \$0.200 | \$0.200 | \$0.200 | \$0.200 | \$0.260 | \$0.200 |
| Permitting Support | \$1.140 | \$1.140 | \$1.140 | \$1.140 | \$1.480 | \$1.140 |
| Switchyard | \$18.190 | \$18.190 | \$18.190 | \$18.190 | \$51.040 | \$13.030 |
| Transmission Line and Electrical Interconnection | \$26.050 | \$26.050 | \$26.050 | \$26.050 | \$29.290 | \$23.030 |
| Gas Interconnection and Reinforcement | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| System Deliverability Upgrade Costs | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Water Supply Infrastructure | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Emission Reduction Credits | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Public Outreach and Area Development | \$0.280 | \$0.280 | \$0.280 | \$0.280 | \$0.360 | \$0.280 |
| Startup/Testing (Fuel & Consumables) | \$0.200 | \$0.200 | \$0.200 | \$0.200 | \$0.260 | \$0.200 |
| Initial Fuel Inventory | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 | \$0.000 |
| Site Security | \$0.660 | \$0.660 | \$0.660 | \$0.660 | \$0.860 | \$0.660 |
| Operating Spare Parts | \$2.000 | \$2.000 | \$2.000 | \$2.000 | \$2.000 | \$2.000 |
| Builders Risk Insurance (0.45% of Construction Costs) | \$2.4 | \$2.4 | \$2.4 | \$2.5 | \$3.0 | \$2.6 |
| Owner's Contingency (5% for Screening Purposes) | \$29.7 | \$29.9 | \$29.7 | \$30.5 | \$37.8 | \$30.8 |
| AFUDC, 2024 MM\$ | \$73 | \$74 | \$73 | \$75 | \$92 | \$76 |
| EPC Portion | \$63.4 | \$63.9 | \$63.5 | \$65.3 | \$76.9 | \$66.9 |
| Non-EPC Portion | \$9.9 | \$9.9 | \$9.9 | \$10.0 | \$15.1 | \$9.1 |
| Total Project Costs, 2024 MM\$ | \$697 | \$701 | \$697 | \$715 | \$887 | \$722 |
| EPC Cost Per kW, 2024 \$/kW | \$2,698 | \$2,715 | \$2,699 | \$2,774 | \$3,319 | \$2,843 |
| Total Cost Per kW, 2024 \$/kW | \$3,485 | \$3,505 | \$3,486 | \$3,575 | \$4,433 | \$3,609 |
| EPC Cost Per kWh, 2024 \$/kWh AC at POI | \$299 | \$301 | \$299 | \$307 | \$368 | \$315 |
| Total Cost Per kWh, 2024 \$/kWh AC at POI | \$386 | \$388 | \$386 | \$396 | \$491 | \$400 |

200 MW / 8-hr Lithium-Ion Battery Energy Storage System

| | ZONE C | ZONE F | ZONE G - Dutchess | ZONE G - Rockland | ZONE J | ZONE K |
|--|---------|---------|-------------------|-------------------|----------|---------|
| ESTIMATED O&M COSTS | | | | | | |
| FIXED O&M COSTS | | | | | | |
| Fixed O&M Cost - Assumes LTSA with Integrator/OEM, 2024\$MM/Yr | \$6.9 | \$6.9 | \$6.9 | \$6.9 | \$6.9 | \$6.9 |
| Capacity Maintenance Agreement (Fixed Portion Levelized), 2024\$MM/Yr | \$2.9 | \$2.9 | \$2.9 | \$2.9 | \$2.9 | \$2.9 |
| Site Leasing Allowance, 2024\$/MM/Yr | \$0.6 | \$0.6 | \$0.6 | \$0.6 | \$9.7 | \$0.6 |
| Property Insurance Allowance, 2024\$MM/Yr | \$3.2 | \$3.3 | \$3.2 | \$3.3 | \$4.0 | \$3.4 |
| Total Fixed O&M, \$/kW-yr | \$68.04 | \$68.14 | \$68.04 | \$68.50 | \$117.27 | \$69.11 |
| VARIABLE O&M COSTS (Augmentation Model) | | | | | | |
| Capacity Maintenance Agreement (Variable Portion Levelized), 2024 \$/MWh | \$6.73 | \$6.73 | \$6.73 | \$6.73 | \$6.73 | \$6.73 |

Notes

[1] EPC electrical scope ends at the high side of the GSU. Includes engineering, procurement, construction (EPC) contracting methodology.

[2] EPC cost accounts for BESS sizing that accommodates system losses, equipment efficiencies, minimum state of charge, aux load, degradation during shipping/construction, and 4 years of overbuild.

[3] Battery FOM accounts for routine BESS and PCS maintenance, BOP maintenance, remote monitoring, asset management, performance guarantees, extended warranties, standby/idle aux loads, and an inverter replacement allowance.

[4] Augmentation typically occurs in milestone events, but the total lifetime augmentation estimates are levelized here, intended to account for maintaining rated energy capacity for 20-year life. Augmentation estimates are modeled in fixed and variable components to allow for cycle adjustments in DCR (both components together make up the augmentation estimate).

[5] Availability and outage rate assumptions are based on vendor correspondence and industry publications.

[6] Estimated Costs exclude decommissioning costs and salvage values.

[7] Preliminary estimates include a preliminary assumption of no required SDU costs. Preliminary assumption may be subject to change based on the results of the NYISO's deliverability assessment for the 2025-2029 DCR.