

Operations Performance Metrics Monthly Report



December 2018 Report

Operations & Reliability Department New York Independent System Operator

Prepared by NYISO Operations Analysis and Services, based on settlements initial invoice data collected on or before January 09, 2019.

Table of Contents

- ◆ **Highlights**
 - *Operations Performance*

- ◆ **Reliability Performance Metrics**
 - *Alert State Declarations*
 - *Major Emergency State Declarations*
 - *IROL Exceedance Times*
 - *Balancing Area Control Performance*
 - *Reserve Activations*
 - *Disturbance Recovery Times*
 - *Load Forecasting Performance*
 - *Wind Forecasting Performance*
 - *Wind Performance and Curtailments*
 - *Lake Erie Circulation and ISO Schedules*

- ◆ **Broader Regional Market Performance Metrics**
 - *PAR Interconnection Congestion Coordination Monthly Value*
 - *PAR Interconnection Congestion Coordination Daily Value*
 - *Regional Generation Congestion Coordination Monthly Value*
 - *Regional Generation Congestion Coordination Daily Value*
 - *Regional RT Scheduling - PJM Monthly Value*
 - *Regional RT Scheduling - PJM Daily Value*

- ◆ **Market Performance Metrics**
 - *Monthly Statewide Uplift Components and Rate*
 - *RTM Congestion Residuals Monthly Trend*
 - *RTM Congestion Residuals Daily Costs*
 - *RTM Congestion Residuals Event Summary*
 - *RTM Congestion Residuals Cost Categories*
 - *DAM Congestion Residuals Monthly Trend*
 - *DAM Congestion Residuals Daily Costs*
 - *DAM Congestion Residuals Cost Categories*
 - *NYCA Unit Uplift Components Monthly Trend*
 - *NYCA Unit Uplift Components Daily Costs*
 - *Local Reliability Costs Monthly Trend & Commitment Hours*
 - *TCC Monthly Clearing Price with DAM Congestion*
 - *ICAP Spot Market Clearing Price*
 - *UCAP Awards*

December 2018 Operations Performance Highlights

- Peak load of 22,080 MW occurred on 12/18/2018 HB 17
- All-time winter capability period peak load of 25,738 MW occurred on 1/7/2014 HB 18
- 0 hours of Thunder Storm Alerts were declared
- 0 hours of NERC TLR level 3 curtailment
- NYISO activated the enhanced Niagara modeling and all of the remaining 115kV facilities previously identified for securing in the energy market models for 2018 in the Real-Time Market on December 4, 2018 and in the Day-Ahead Market execution occurring on December 5, 2018 for the December 6, 2018 market day.
- The following table identifies the estimated production cost savings associated with the Broader Regional Market initiatives.



	Current Month Value (\$M)	Year-to-Date Value (\$M)
NY Savings from PJM-NY Congestion Coordination	\$0.61	\$14.07
NY Savings from PJM-NY Coordinated Transaction Scheduling	\$0.30	(\$0.19)
NY Savings from NE-NY Coordinated Transaction Scheduling	\$0.03	(\$0.06)
Total NY Savings	\$0.94	\$13.82
Regional Savings from PJM-NY Coordinated Transaction Scheduling	\$0.18	\$4.17
Regional Savings from NE-NY Coordinated Transaction Scheduling	\$0.05	\$0.79
Total Regional Savings	\$0.23	\$4.96



- Statewide uplift cost monthly average was (\$0.52)/MWh
- The following table identifies the Monthly ICAP spot market prices and the price delta.

Spot Auction Price Results	NYCA	Lower Hudson Valley Zones	New York City Zone	Long Island Zone
January 2019 Spot Price	\$0.13	\$1.52	\$1.52	\$0.43
December 2018 Spot Price	\$0.10	\$1.52	\$1.52	\$1.95
Delta	\$0.03	\$0.00	\$0.00	(\$1.52)


- LI - Price increase by \$1.52 due to increase in unoffered capacity

Reliability Performance Metrics






NERC Balancing Authority ACE Limit Standard







The amount of time the clock-minute average ACE exceeds the clock-minute Balancing Authority ACE Limit (BAAL) is an indicator of the NYISO Area resource and demand balancing. The maximum BAAL exceedance time is identified. BAAL exceedances of less than 30 consecutive clock-minutes are NERC compliant.



Reserve Activations







NYISO Reserve Activations are indicators of the need to respond to unexpected operational conditions within the NYISO Area or to assist a neighboring Area (Simultaneous Activation of Reserves) by activating an immediate resource and demand balancing operation.























Broader Regional Market Performance Metrics





PAR Interconnection Congestion Coordination	
<u>Category</u>	<u>Description</u>
NY	Represents the value NY realizes from Market-to-Market PAR Coordination when experiencing congestion. This is the estimated savings to NY for additional deliveries into NY
RECO	Represents the value of PJM's obligation to deliver 80% of service to RECO load over Ramapo 5018. This is the estimated reduction in NYCA congestion due to the PJM delivery of RECO over Ramapo 5018.
M2M PAR Settlement	Market-to-Market PAR Coordination settlement on coordinated flowgates. Through April 2017 this value was included in the NY and RECO categories. The positive sign convention indicates settlement to NY while the negative indicates settlement to PJM.





Regional Generation Congestion Coordination



Category

NY


Description



NYISO savings that result from PJM payments to NYISO when PJM's transmission use (PJM's market flow) is greater than PJM's entitlement of the NY transmission system and NYISO is incurring Western or Central NY congestion. Additionally, NYISO savings may result from the more efficient regional utilization of PJM's generation resources to directly address Western or Central NY transmission congestion.





Market Performance Metrics





Day's investigated in December: 12, 13, 24



Event	Date (yyyymmdd)	Hours	Description
	12/12/2018	12, 16	Early Return to Service Gowanus-Greenwood 138kV (#42232)
	12/12/2018	2, 3	Derate Central East
	12/12/2018	0, 1, 4, 6	HQ_CEDARS-NY Scheduling Limit
	12/12/2018	0-4, 6, 7	NE_AC-NY Scheduling Limit
	12/12/2018	2	NE_AC DNI Ramp Limit
	12/13/2018	7, 15	NYCA DNI Ramp Limit
	12/13/2018	1-4, 15, 17, 23	Derate Sprainbrook-East Garden City 345kV (#Y49)
	12/13/2018	0-7, 15, 17, 23	NE_AC-NY Scheduling Limit
	12/13/2018	6, 7	NE_AC DNI Ramp Limit
	12/13/2018	6	PJM_AC DNI Ramp Limit
	12/24/2018	15	NYCA DNI Ramp Limit
	12/24/2018	0	Derate Central East
	12/24/2018	12, 14	Uprate Central East
	12/24/2018	0, 8, 16	NE_AC DNI Ramp Limit
	12/24/2018	0, 14, 15	Lake Erie Circulation, DAM-RTM exceeds +/-125MW; Central East

Real-Time Balancing Market Congestion Residual (Uplift Cost) Categories

<u>Category</u>	<u>Cost Assignment</u>	<u>Events Types</u>	<u>Event Examples</u>
Storm Watch	Zone J	Thunderstorm Alert (TSA)	TSA Activations
Unscheduled Transmission Outage	Market-wide	Reduction in DAM to RTM transfers related to unscheduled transmission outage	Forced Line Outage, Unit AVR Outages
Interface Derate - NYISO Security	Market-wide	Reduction in DAM to RTM transfers not related to transmission outage	Interface Derates due to RTM voltages
Interface Derate - External Security	Market-wide	Reduction in DAM to RTM transfers related to External Control Area Security Events	TLR Events, External Transaction Curtailments
Unscheduled Loop Flows	Market-wide	Changes in DAM to RTM unscheduled loop flows impacting NYISO Interface transmission constraints	DAM to RTM Lake Erie Loop Flows exceeding +/- 125 MW
M2M Settlement	Market-wide	Settlement result inclusive of coordinated redispatch and Ramapo flowgates	



Monthly Balancing Market Congestion Report Assumptions/Notes



- 1) Storm Watch Costs are identified as daily total uplift costs
- 2) Days with a value of BMCR less M2M Settlement of \$100K/HR, shortfall of \$200K/Day or more, or surplus of \$100K/Day or more are investigated.
- 3) Uplift costs associated with multiple event types are apportioned equally by hour







Day-Ahead Market Congestion Residual Categories

<u>Category</u>	<u>Cost Assignment</u>	<u>Events Types</u>	<u>Event Examples</u>
NYTO Outage Allocation	Responsible TO	Direct allocation to NYTO's responsible for transmission equipment status change.	DAM scheduled outage for equipment modeled in-service for the TCC Auction.
External Outage Allocation	All TO by Monthly Allocation Factor	Direct allocation to transmission equipment status change caused by change in status of external equipment.	Tie line required out-of-service by TO of neighboring control area.
Central East Commitment Derate	All TO by Monthly Allocation Factor	Reductions in the DAM Central East_VC limit as compared to the TCC Auction limit, which are not associated with transmission line outages.	










TCC & Day Ahead Market Selected External Path Congestion

TCC Monthly Reconfiguration Auction vs. Monthly DAM Average
with Autumn 2018 Centralized TCC Auction Six-Month Average



- PJM-Central TCC Auction
- NE-Central TCC Auction
- OH-Central TCC Auction
- HQ-Central TCC Auction
- PJM-Central DAM Congestion
- NE-Central DAM Congestion
- OH-Central DAM Congestion
- HQ-Central DAM Congestion

