

NYC PPTN Update

Supriya Tawde

Manager,
Transmission Integration

Sarah Carkner

Manager,
Long Term Assessments

Transmission Planning Advisory Subcommittee (TPAS)
Electric System Planning Working Group (ESPWG)

Wednesday, June 25, 2025

Agenda

- **NYC PPTN Review**
- **Preliminary Evaluation Results**
 - Independent Capital Cost Estimates
 - Offshore Wind Injection
 - Production Cost Savings
 - Impact on Transfer Limit
 - Risk Assessment – Potential Construction Delays
- **Next Steps**

NYC PPTN Review

NYC PPTN Review

- **The NYC PPTN calls for proposed solutions that must accommodate the full output of at least 4,770 MW of incremental offshore wind (OSW) generation into New York City**
 - Consistent with the PSC's order identifying the NYC PPTN, the NYISO can use scenarios representing up to 8,000 MW of incremental OSW generation to evaluate performance of proposed solutions for expandability, renewable energy deliverability, and other metrics in evaluation phase
- **“Appendix A: Technical Requirements” of the PSC's order contains technical details that will be used in defining the viability & sufficiency criteria and evaluation criteria**


NYC PPTN Review (cont.)

- **Solutions to address the NYC PPTN must, among other things:**
 - Consist of a complete end-to-end solution comprised of both offshore and onshore components to enable power injection into Zone J
 - Contain a plan to complete all permitting and construction activities for facilities required to inject 4,770 MW of OSW generation into Zone J to achieve an in-service date no later than January 1, 2033
 - Contain a plan for how OSW generation would interconnect to the end-to-end transmission proposal at the offshore interconnection points

Complete “End-to-End” Solutions

- **A complete end-to-end solution must be comprised of both offshore and onshore components to enable power injection into Zone J and should include the following components:**
 - offshore interconnection point(s),
 - offshore transmission (i.e., submarine cables),
 - sites for cable landing points,
 - onshore transmission path(s) (i.e., terrestrial cables) from cable landing points to points of interconnection in Zone J, including sites for converter stations, and
 - necessary improvements to and/or expansion of the existing onshore transmission system.

New York City Offshore Wind PPTN Illustrative Diagram



Sufficiency Criteria

- Accommodate the full output of at least 4,770 MW of incremental OSW generation injected into New York City (Zone J), under applicable reliability standards, without reducing the overall output of other renewable resources interconnected in Zones J and K
- 4,770 MW of OSW generation is incremental to the 816 MW of OSW generation identified as interconnecting into Zone J in the PSC's order identifying the NYC PPTN

Sufficiency Criteria (cont.)

- **Consist of a complete end-to-end solution comprised of both offshore and onshore components to enable power injection into Zone J**
- **Demonstrate that facilities that are required to inject 4,770 MW of OSW generation can achieve an in-service date no later than January 1, 2033**

Viability and Sufficiency Assessment

- The NYISO's assessment found that all 28 projects meet the viability and sufficiency criteria
- The report was filed with the PSC on October 30, 2024 and is available [here](#)

NYC PPTN Project Proposals

Developer Name	Project ID #	Project Name	Abbreviated Project Name	Project Proposed In-Service Date	# of Offshore Platforms
energyRe Giga-Projects USA, LLC	T102	Clean Borough Power Link 1	CBPL 1	Dec-2032	4
energyRe Giga-Projects USA, LLC	T103	Clean Borough Power Link 2	CBPL 2	Dec-2032	4
energyRe Giga-Projects USA, LLC	T104	Clean Borough Power Link 3	CBPL 3	Dec-2032	4
Viridon NY Inc	T105	Liberty Link 1	LL 1	Dec-2032	4
Viridon NY Inc	T106	Liberty Link 2	LL 2	Dec-2032	4
Viridon NY Inc	T107	Liberty Link 3	LL 3	Dec-2032	4
NY Transco LLC	T108	Energy Link New York Solution 1	ELNY S1	Jan-2033	4
NY Transco LLC	T109	Energy Link New York Solution 2	ELNY S2	Jan-2033	4
NY Transco LLC	T110	Energy Link New York Solution 3	ELNY S3	Jan-2033	4
NY Transco LLC	T111	Energy Link New York Solution 4	ELNY S4	Jan-2033	4
NY Transco LLC	T112	Energy Link New York Solution 5	ELNY S5	Jan-2033	4
NY Transco LLC	T113	Energy Link New York Solution 6	ELNY S6	Jan-2033	4
NY Transco LLC	T114	Energy Link New York Solution 7	ELNY S7	Jan-2033	4
NY Transco LLC	T115	Energy Link New York Solution 8	ELNY S8	Jan-2033	4
NY Transco LLC	T116	Energy Link New York Solution 9	ELNY S9	Jan-2033	4
NY Transco LLC	T117	Energy Link New York Solution 10	ELNY S10	Jan-2033	4
NYPA & LS Power Grid NY Corporation I	T118	Five Boro Energy Connect – Mint	FBEC – Mint	Oct-2032	4
NYPA & LS Power Grid NY Corporation I	T119	Five Boro Energy Connect – Sage	FBEC – Sage	Sep-2032	4
NYPA & LS Power Grid NY Corporation I	T120	Five Boro Energy Connect – Olive	FBEC – Olive	Jun-2033	5
NYPA & LS Power Grid NY Corporation I	T121	Five Boro Energy Connect – Kelly	FBEC – Kelly	Aug-2033	5
NYPA & LS Power Grid NY Corporation I	T122	Five Boro Energy Connect – Hazel	FBEC – Hazel	Dec-2033	5
NYPA & LS Power Grid NY Corporation I	T123	Five Boro Energy Connect – Navy	FBEC – Navy	Sep-2032	4
NYPA & LS Power Grid NY Corporation I	T124	Five Boro Energy Connect – Royal	FBEC – Royal	May-2033	5
NYPA & LS Power Grid NY Corporation I	T125	Five Boro Energy Connect – Cobalt	FBEC – Cobalt	Oct-2033	6
NYPA & LS Power Grid NY Corporation I	T126	Five Boro Energy Connect – Ruby	FBEC – Ruby	Sep-2032	4
NYPA & LS Power Grid NY Corporation I	T127	Five Boro Energy Connect – Rose	FBEC – Rose	Sep-2032	4
NYPA & LS Power Grid NY Corporation I	T128	Five Boro Energy Connect – Honey	FBEC – Honey	Oct-2033	5
NYPA & LS Power Grid NY Corporation I	T129	Five Boro Energy Connect – Golden	FBEC – Golden	Oct-2033	6

Preliminary Evaluation Results

Preliminary Evaluation Results

- Independent Capital Cost Estimates
- Offshore Wind (OSW) Injection
- Production Cost Savings
- Impact on Transfer Limit
- Risk Assessment – Potential Construction Delays

Independent Capital Cost Estimates

Preliminary Independent Capital Cost Estimates

■ Purpose

- Overnight independent capital costs developed by NYISO's consultants are used to inform quantitative and qualitative assessment of the proposed projects

■ Evaluation

- An overnight independent capital cost includes the following:
 - Major equipment cost (e.g., procurement, installation, testing and commissioning)
 - Labor and construction cost
 - Engineering and design cost
 - Permitting cost
 - Site acquisition
- Overnight independent capital costs were developed using consistent assumptions, while accommodating differences in design, for example:
 - Accuracy range as per AACE Class 4 Estimating Practices (-15% to -30%) and (+20% to +50%)
 - Contingency
 - No escalation
 - Sales Tax
 - Estimate based on 2025 budgetary pricing

Preliminary Independent Capital Cost Estimates


- **Considerations**

- Primary cost drivers

- HVDC system
 - Submarine and terrestrial routing
 - Phase angle regulators (“PARs”), transformers, and circuit breakers
 - Construction costs
 - Site Acquisition costs

- **Design summaries for the proposed projects are included in the Appendix**

Preliminary Independent Capital Cost Estimates



Preliminary Independent Capital Cost Estimates

Project	Independent Capital Cost Estimate (\$Million)
T102 energyRe CBPL 1	\$12,746
T103 energyRe CBPL 2	\$12,860
T104 energyRe CBPL 3	\$13,506
T105 Viridon LL 1	\$10,801
T106 Viridon LL 2	\$11,321
T107 Viridon LL 3	\$12,193
T108 Transco ELNY S1	\$16,828
T109 Transco ELNY S2	\$16,177
T110 Transco ELNY S3	\$15,921
T111 Transco ELNY S4	\$16,794
T112 Transco ELNY S5	\$16,745
T113 Transco ELNY S6	\$17,079
T114 Transco ELNY S7	\$17,779
T115 Transco ELNY S8	\$18,491
T116 Transco ELNY S9	\$18,924
T117 Transco ELNY S10	\$18,344
T118 NYPA/LSP FBEC – Mint	\$7,973
T119 NYPA/LSP FBEC – Sage	\$14,911
T120 NYPA/LSP FBEC – Olive	\$18,939
T121 NYPA/LSP FBEC – Kelly	\$18,465
T122 NYPA/LSP FBEC – Hazel	\$10,097
T123 NYPA/LSP FBEC – Navy	\$14,324
T124 NYPA/LSP FBEC – Royal	\$18,442
T125 NYPA/LSP FBEC – Cobalt	\$22,633
T126 NYPA/LSP FBEC – Ruby	\$14,805
T0127 NYPA/LSP FBEC – Rose	\$8,299
T128 NYPA/LSP FBEC – Honey	\$18,298
T129 NYPA/LSP FBEC – Golden	\$23,940

Preliminary Independent Capital Cost Estimates

- **Preliminary independent cost estimates to be finalized based on the following information:**
 - Developer's feedback on the independent capital cost estimates
 - NUFs identified in the System Impact Study to become available during the evaluation

Offshore Wind Injection

OSW Injection: Overview

■ Purpose

- Maximize MW injection of OSW into Zone J under contingency conditions (N-1 and N-1-1)


■ Evaluation

- Analysis utilized the VSA baseline case (Summer Peak) and Baseline case (Spring Light load) assumptions. Detailed assumptions are included in the Appendix
- All 100 kV and above lines were secured to their normal rating under all lines in service condition and to applicable emergency rating (LTE) in post-contingency conditions while maximizing OSW injection into Zone J
- OSW is dispatched only up to its capability as proposed in the project proposal

■ Considerations

- Higher OSW injection under N-1 and N-1-1 contingency conditions
- OSW injection under N-1 and N-1-1 contingency conditions compared to its proposed capability

OSW Injection: Results



OSW Injection: Results Summer Peak

Project	Proposed OSW Injection Capability		OSW Injection at Onshore Converter Station	
	Offshore POI Capability (MW)	Onshore Converter Station Capability (MW)	N-1 (MW)	N-1-1 (MW)
T102 energyRe CBPL 1	5,352	5,240	5,240	4,920
T103 energyRe CBPL 2	5,267	5,039	5,030	5,030
T104 energyRe CBPL 3	5,355	5,232	5,230	5,220
T105 Viridon LL 1	5,250	5,151	5,150	4,920
T106 Viridon LL 2	5,242	5,143	5,140	4,960
T107 Viridon LL 3	5,146	5,050	5,050	4,920
T108 Transco ELNY S1	5,360	5,228	5,230	4,970
T109 Transco ELNY S2	5,360	5,216	5,220	4,980
T110 Transco ELNY S3	5,372	5,236	5,170	4,780
T111 Transco ELNY S4	5,372	5,236	5,180	4,940
T112 Transco ELNY S5	5,372	5,228	5,170	4,930
T113 Transco ELNY S6	5,372	5,235	5,230	5,230
T114 Transco ELNY S7	5,372	5,236	5,180	4,940
T115 Transco ELNY S8	5,360	5,227	5,230	5,220
T116 Transco ELNY S9	5,360	5,215	5,220	5,210
T117 Transco ELNY S10	5,372	5,228	5,170	4,930
T118 NYPA/LSP FBEC – Mint	5,370	5,244	5,240	5,230
T119 NYPA/LSP FBEC – Sage	5,600	5,468	5,460	5,460
T120 NYPA/LSP FBEC – Olive	6,713	6,554	6,550	6,540
T121 NYPA/LSP FBEC – Kelly	7,000	6,835	6,830	6,820
T122 NYPA/LSP FBEC – Hazel	7,000	6,835	6,830	6,820
T123 NYPA/LSP FBEC – Navy	5,368	5,243	5,190	4,790
T124 NYPA/LSP FBEC – Royal	6,710	6,553	6,490	6,100
T125 NYPA/LSP FBEC – Cobalt	8,054	7,865	7,820	7,420
T126 NYPA/LSP FBEC – Ruby	5,369	5,243	5,240	5,230
T127 NYPA/LSP FBEC – Rose	5,600	5,468	5,470	5,460
T128 NYPA/LSP FBEC – Honey	6,712	6,554	6,550	6,550
T129 NYPA/LSP FBEC – Golden	8,072	7,865	7,860	7,850

OSW Injection: Results Spring Light Load

Project	Proposed OSW Injection Capability		OSW Injection at Onshore Converter Station	
	Offshore POI Capability (MW)	Onshore Converter Station Capability (MW)	N-1 (MW)	N-1-1 (MW)
T102 energyRe CBPL 1	5,352	5,240	4,830	4,520
T103 energyRe CBPL 2	5,267	5,039	5,010	4,520
T104 energyRe CBPL 3	5,355	5,232	5,090	4,690
T105 Viridon LL 1	5,250	5,151	4,910	4,590
T106 Viridon LL 2	5,242	5,143	4,910	4,590
T107 Viridon LL 3	5,146	5,050	4,940	4,430
T108 Transco ELNY S1	5,360	5,228	4,900	4,600
T109 Transco ELNY S2	5,360	5,216	4,900	4,590
T110 Transco ELNY S3	5,372	5,236	4,870	4,450
T111 Transco ELNY S4	5,372	5,236	4,900	4,580
T112 Transco ELNY S5	5,372	5,228	4,890	4,560
T113 Transco ELNY S6	5,372	5,235	4,980	4,660
T114 Transco ELNY S7	5,372	5,236	4,990	4,670
T115 Transco ELNY S8	5,360	5,227	5,190	4,680
T116 Transco ELNY S9	5,360	5,215	5,190	4,680
T117 Transco ELNY S10	5,372	5,228	4,980	4,670
T118 NYPA/LSP FBEC – Mint	5,370	5,244	5,240	5,230
T119 NYPA/LSP FBEC – Sage	5,600	5,468	5,240	5,230
T120 NYPA/LSP FBEC – Olive	6,713	6,554	6,520	5,900
T121 NYPA/LSP FBEC – Kelly	7,000	6,835	6,830	6,440
T122 NYPA/LSP FBEC – Hazel	7,000	6,835	6,590	5,970
T123 NYPA/LSP FBEC – Navy	5,368	5,243	4,940	4,450
T124 NYPA/LSP FBEC – Royal	6,710	6,553	6,200	5,730
T125 NYPA/LSP FBEC – Cobalt	8,054	7,865	6,650	5,960
T126 NYPA/LSP FBEC – Ruby	5,369	5,243	5,240	4,990
T127 NYPA/LSP FBEC – Rose	5,600	5,468	5,470	5,030
T128 NYPA/LSP FBEC – Honey	6,712	6,554	6,550	6,070
T129 NYPA/LSP FBEC – Golden	8,072	7,865	7,230	5,980

Production Cost Savings

Production Cost Savings: Overview

■ Purpose

- Assess the economic benefits of proposed projects and assumed OSW generation by reducing generation production costs to serve the New York Control Area

■ Evaluation

- Hourly resolution production cost simulations for 2033, 2035, 2040, 2045, 2050, 2052 under future scenario modeling

■ Considerations

- Projects that facilitate higher levels of OSW energy production have higher production cost savings
- Production cost savings are a societal benefit that reduce the cost of producing electricity to meet New York electricity demand

Production Cost Savings: Assumptions

- **The production cost database is based on the 2023-2042 System & Resource Outlook's Policy Case: Higher Demand Scenario, with modifications to align with other analyses in the NYC PPTN evaluation**
 - Updated generator assumptions (i.e., firm new generators and generator retirements)
 - Updated network model
 - Added contingencies associated with the projects
- **Detailed assumptions are included in the Appendix**


Production Cost Savings: Assumptions (cont.)

- **Pre-project and post-project cases were developed to quantify the production cost savings associated with the proposed transmission projects**
 - **Pre-project case**
 - Reflects the system conditions absent proposed transmission to satisfy the NYC PPTN need
 - OSW generation assumed to be in-service aligns with the PSC order identifying the NYC PPTN
 - ~816 MW OSW generation connected to Zone J, ~3,000 MW OSW generation connected to Zone K
 - **Post-project cases**
 - Inclusion of the proposed transmission project
 - OSW generation assumed to be in-service includes (i) the pre-project assumptions and (ii) the OSW generation identified by the developers based on the stated capacity of their projects

Production Cost Savings: Key Takeaways

- **Preliminary results estimate production cost savings between ~\$40-70B nominal over a 20-year period (2033-2052)**
 - Savings are in nominal dollars and do not include discounting
 - The capital costs of the proposed NYC PPTN projects and assumed OSW generation projects are not accounted in this metric
- **Preliminary results show a strong correlation between OSW generation and production cost savings (i.e., projects that propose higher OSW injections tend to show higher production cost savings)**
 - The NYISO is evaluating additional factors driving the production cost savings
- **Production cost savings increase significantly for all proposed transmission projects model years 2040 and beyond**

Production Cost Savings: Preliminary Results



Production Cost Savings: Preliminary Results

Project	Estimated Total 20-Year Savings (\$B nominal)*
T102 energyRe CBPL 1	45.2
T103 energyRe CBPL 2	40.2
T104 energyRe CBPL 3	55.1
T105 Viridon LL 1	44.0
T106 Viridon LL 2	44.5
T107 Viridon LL 3	44.6
T108 Transco ELNY S1	45.1
T109 Transco ELNY S2	45.1
T110 Transco ELNY S3	45.9
T111 Transco ELNY S4	45.6
T112 Transco ELNY S5	45.3
T113 Transco ELNY S6	54.8
T114 Transco ELNY S7	55.9
T115 Transco ELNY S8	46.1
T116 Transco ELNY S9	45.9
T117 Transco ELNY S10	55.0
T118 NYPA/LSP FBEC – Mint	43.8
T119 NYPA/LSP FBEC – Sage	40.3
T120 NYPA/LSP FBEC – Olive	50.1
T121 NYPA/LSP FBEC – Kelly	50.0
T122 NYPA/LSP FBEC – Hazel	51.7
T123 NYPA/LSP FBEC – Navy	46.0
T124 NYPA/LSP FBEC – Royal	53.2
T125 NYPA/LSP FBEC – Cobalt	50.0
T126 NYPA/LSP FBEC – Ruby	43.8
T127 NYPA/LSP FBEC – Rose	45.9
T128 NYPA/LSP FBEC – Honey	61.7
T129 NYPA/LSP FBEC – Golden	68.7

*The capital costs of the proposed NYC PPTN projects and assumed OSW generation projects are not accounted in this metric

Impact on Transfer Limit

Impact on Transfer Limit: Overview

■ Purpose

- Identify incremental impact on import capability into Zone J across Dunwoodie - South interface due to the proposed onshore transmission facilities contained in each project

■ Evaluation


- All 100 kV and above lines were secured to their normal rating under all lines in service condition and to applicable emergency rating (LTE) in post-contingency conditions

■ Consideration

- Larger increase in transfer limit due to the proposed onshore transmission facilities

Impact on Transfer Limit: Results

Project	Incremental Impact on Dunwoodie South (MW)
T102 energyRe CBPL 1	+291
T103 energyRe CBPL 2	+191
T104 energyRe CBPL 3	+197
T105 Viridon LL 1	+293
T106 Viridon LL 2	+296
T107 Viridon LL 3	+199
T108 Transco ELNY S1	+312
T109 Transco ELNY S2	+300
T110 Transco ELNY S3	+290
T111 Transco ELNY S4	+317
T112 Transco ELNY S5	+316
T113 Transco ELNY S6	+288
T114 Transco ELNY S7	+314
T115 Transco ELNY S8	+566
T116 Transco ELNY S9	+568
T117 Transco ELNY S10	+304
T118 NYPA/LSP FBEC - Mint	+295
T119 NYPA/LSP FBEC - Sage	+275
T120 NYPA/LSP FBEC - Olive	+273
T121 NYPA/LSP FBEC - Kelly	+571
T122 NYPA/LSP FBEC - Hazel	+281
T123 NYPA/LSP FBEC - Navy	+638
T124 NYPA/LSP FBEC - Royal	+924
T125 NYPA/LSP FBEC - Cobalt	+288
T126 NYPA/LSP FBEC - Ruby	+656
T127 NYPA/LSP FBEC - Rose	+609
T128 NYPA/LSP FBEC - Honey	+277
T129 NYPA/LSP FBEC - Golden	+345



Risk Assessment - Potential Construction Delays

Risk Assessment

- **NYISO's independent consultant identified risks in each proposed project, including the following categories:**
 - Potential Construction Delays
 - Design Concerns
 - Construction Concerns

Potential Drivers for Construction Delays

- Substation Modifications
- Construction Outages
- Routing - Submarine and Terrestrial
- Onshore Converter Designs
- Offshore Point of Interconnection Design (i.e., “DC Connectors”)
- Long-Lead-Time Equipment

Potential Construction Delays – Substation Modifications

- **Installing proposed underground cables and/or new equipment in the existing substations pose the following challenges:**
 - Potential impact on existing foundations, conduit/trench systems, grounding, and bus work
 - Relocation of existing assets and complex construction sequences
 - Additional or concurrent outages
 - Expensive construction methods

Potential Construction Delays – Construction Outages

- In order to construct the proposed projects, several existing elements (e.g., transformers, PARs, transmission lines, main buses) will need to be removed from service
- Developer's proposed outage plans were reviewed for
 - Reasonableness of proposed outage window compared to the scope of work to be completed during the proposed outage window
 - Potential impact on the reliability of the system

Potential Construction Delays – Routing

■ Terrestrial

- Modifications may be required for routing cables through congested areas and due to existing utility underground infrastructure
- Different construction techniques than those planned may need to be used to cross multi-lane roadways, under low clearance bridges, and crossing railroads

■ Submarine

- Narrows
 - Cables entering through the Narrows and the areas immediately north pose a physical constraint due to the number of cables coming into the Upper NY Harbor
 - Owner consent/consultation may be required to cross existing infrastructure (e.g., cables, pipelines, tunnels)
 - Given the limited amount of space that physically exists in the Narrows and setbacks between cables necessary for installation and maintenance, cable routing may pose a construction sequencing challenge
- Long Island Sound
 - Time of year restrictions will likely be imposed during construction. Combined restrictions from federal and state agencies would result in smaller allowable work window

Potential Construction Delays – Long-Lead-Time Equipment

- Due to high demand and equipment complexities, manufacturers are quoting longer lead times after execution of the contract for HVDC converter stations and other major equipment like transformers and PARs
- Longer lead times to procure equipment will require the developers to work with the manufacturers to mitigate potential delays in schedule

Potential Construction Delays – Proposed Onshore HVDC Converter Design

- **Unique onshore HVDC converter design may lead to longer than planned engineering and installation time**
 - Multi-floor HVDC designs (stacked or 2 story) that have components (example converter valves, filters) physically arranged across two vertical floors as opposed to a flat design in which all components are installed on single level may require longer than planned engineering and installation time

Potential Construction Delays – Proposed Offshore POI Design

- **Certain projects proposed an offshore POI which is an offshore platform without an HVDC converter station (“DC Connector”)**
 - The use of a “DC Connector” for the purpose of OSW generation integration has not been used in the past and may present challenges associated with design, engineering, and installation
 - As proposed by the developer, DC Connectors require offshore converter stations that would be required to be installed by another entity (e.g., OSW generator) to facilitate interconnection of offshore wind generation in the future
 - This unique design and approach requires extensive cooperation and coordination with OSW generators to design and install compatible offshore converter stations beyond the developer’s proposal

Summary of Risks

Project	Potential Construction Delays				
	Substation Modifications				
	Academy 345 kV	Mott Haven 345 kV	Rainey 345 kV	Sprainbrook 345 kV	W49th St. 345 kV
T102 energyRe CBPL 1				X	
T103 energyRe CBPL 2					
T104 energyRe CBPL 3					
T105 Viridon LL 1				X	
T106 Viridon LL 2				X	
T107 Viridon LL 3					
T108 Transco ELNY S1				X	
T109 Transco ELNY S2				X	
T110 Transco ELNY S3				X	
T111 Transco ELNY S4				X	
T112 Transco ELNY S5				X	
T113 Transco ELNY S6				X	
T114 Transco ELNY S7				X	
T115 Transco ELNY S8		X	X	X	
T116 Transco ELNY S9		X	X	X	
T117 Transco ELNY S10				X	
T118 NYPA/LSP FBEC – Mint	X		X		
T119 NYPA/LSP FBEC – Sage	X				
T120 NYPA/LSP FBEC – Olive	X		X		
T121 NYPA/LSP FBEC – Kelly	X		X		
T122 NYPA/LSP FBEC – Hazel	X		X		
T123 NYPA/LSP FBEC – Navy					
T124 NYPA/LSP FBEC – Royal			X		X
T125 NYPA/LSP FBEC – Cobalt	X		X		
T126 NYPA/LSP FBEC – Ruby			X		X
T127 NYPA/LSP FBEC – Rose			X		X
T128 NYPA/LSP FBEC – Honey	X		X		
T129 NYPA/LSP FBEC – Golden	X		X		

If a risk identified for the Project, it is indicated with an “X”

Summary of Risks

Project	Potential Construction Delays					
	Terrestrial Routing	Submarine Routing		Onshore Converter Station Design	Offshore POI Design	Construction Outage
	Misc	Narrows	Long Island Sound	Multi-floor Design	DC Connector	
T102 energyRe CBPL 1	X	X				X
T103 energyRe CBPL 2	X	X				X
T104 energyRe CBPL 3	X	X	X			X
T105 Viridon LL 1		X				X
T106 Viridon LL 2		X				X
T107 Viridon LL 3		X				X
T108 Transco ELNY S1	X					X
T109 Transco ELNY S2	X					X
T110 Transco ELNY S3	X	X				X
T111 Transco ELNY S4	X	X				X
T112 Transco ELNY S5	X	X				X
T113 Transco ELNY S6	X					X
T114 Transco ELNY S7	X	X				X
T115 Transco ELNY S8	X					X
T116 Transco ELNY S9	X					X
T117 Transco ELNY S10	X	X				X
T118 NYPA/LSP FBEC – Mint	X	X		X	X	X
T119 NYPA/LSP FBEC – Sage	X	X		X		X
T120 NYPA/LSP FBEC – Olive	X	X	X	X		X
T121 NYPA/LSP FBEC – Kelly	X	X		X		X
T122 NYPA/LSP FBEC – Hazel	X	X		X	X	X
T123 NYPA/LSP FBEC – Navy	X	X		X		X
T124 NYPA/LSP FBEC – Royal	X	X		X		X
T125 NYPA/LSP FBEC – Cobalt	X	X	X	X		X
T126 NYPA/LSP FBEC – Ruby	X	X		X		X
T127 NYPA/LSP FBEC – Rose	X	X		X	X	X
T128 NYPA/LSP FBEC – Honey	X	X		X		X
T129 NYPA/LSP FBEC – Golden	X	X	X	X	X	X

If a risk identified for the Project, it is indicated with an “X”

Additional Risks

- **NYISO is continuing to assess additional risks associated with the proposed solutions, such as:**
 - Property Acquisition
 - Environmental and Permitting Concerns
 - Supplemental Criteria from the PSC Order (Appendix B)
 - System Impact Study Results

Next Steps

Targeted Review Schedule

- Further metric results will be presented at future TPAS/ESPWG meetings, specifically leading to:
 - September TPAS/ESPWG: Top tier project list
 - October/November TPAS/ESPWG: Initial report review

Feedback

- Feedback and questions related to the NYC PPTN should be raised during stakeholder discussions or provided to the NYISO by submitting questions to stakeholder_services@nyiso.com with the subject line “NYC PPTN”

New York City PPTN Data Catalog

Stakeholder Presentations

July 25, 2023

[NYC PPTN Update](#)

August 22, 2023

[NYC PPTN Update](#)

[PPTPP Lessons Learned](#)

September 21, 2023

[NYC PPTN Update](#)

October 2, 2023

[NYC PPTN Update](#)

October 24, 2023

[NYC PPTN Update](#)

November 2, 2023

[NYC PPTN Update](#)

November 6, 2023

[NYISO Technical Conference](#)

November 21, 2023

[NYC PPTN Update](#)

December 7, 2023

[NYISO Technical Conference](#)

December 19, 2023

[PPTPP Manual Updates](#)

January 23, 2024

[NYC PPTN Update](#)

February 6, 2024

[NYC PPTN Update](#)

February 22, 2024

[NYC PPTN Update](#)

March 8, 2024

[NYC PPTN Update](#)

March 21, 2024

[NYC PPTN Update](#)

June 7, 2024

[NYC PPTN Update](#)

August 6, 2024

[NYC PPTN Update](#)

September 27, 2024

[NYC PPTN Update](#)

October 21, 2024

[NYC PPTN Update](#)


January 6, 2025

[NYC PPTN Update](#)


May 21, 2025

[NYC PPTN Update](#)

PSC Order



NYC PPTN Report



Other Documents

[DPS/NYISO PSC Order Q&A Document](#)

[NYISO CEII Data Request Form](#)

[Con Edison NYC PPTN Related Website](#)

[NYSERDA Offshore Wind Cable Corridor Constraints Assessment](#)

[Agency Working Group Technical Conference Presentation](#)

[Con Edison Technical Conference Presentation](#)

[Con Edison FAQs](#)

[NYISO FAQs #1](#) [NYISO FAQs #2](#) [NYISO FAQs #3](#) [NYISO FAQs #4](#)

[DPS PSC Order Q&A Document \(Jan 2024\)](#)

[DPS PSC Order Q&A Document \(Feb 2024\)](#)

[DPS NYC PPTN Letter to NYISO](#)

[Attachment B, Q13 – NYC PPTN Information Request Form](#)

[NYCPPTN Final Facility Characterization List](#)

[NYC PPTN Viability and Sufficiency Report](#)

Our Mission & Vision



Mission

Ensure power system reliability and competitive markets for New York in a clean energy future



Vision

Working together with stakeholders to build the cleanest, most reliable electric system in the nation

Appendix

Project Design Summary

Major Equipment Information								
Project	HVAC Cable Terrestrial Mileage (approx. miles)	HVAC Cable Submarine Mileage (approx. miles)	HVDC Cable Terrestrial Mileage (approx. miles)	HVDC Cable Submarine Mileage (approx. miles)	No. of Proposed 345 kV/138 kV PARs	No. of 345 kV Breakers	No. of 345-138 kV Transformers	No. of 138 kV Breakers
T102 energyRe CBPL 1	12	14	1	347	6 - 345 kV	4	-	-
T103 energyRe CBPL 2	7	19	1	352	-	11	-	-
T104 energyRe CBPL 3	11	9	0	423	2-345 kV 2-138 kV	11	2	-
T105 Viridon LL 1	1	61	0	340	4 - 345 kV	4	-	-
T106 Viridon LL 2	1	42	0	340	4 - 345 kV	4	-	-
T107 Viridon LL 3	0	56	0	339	2 - 345 kV	14	-	-
T108 Transco ELNY S1	47	0	59	325	6 - 345 kV	4	-	-
T109 Transco ELNY S2	47	0	59	419	6 - 345 kV	4	-	-
T110 Transco ELNY S3	77	0	28	338	6 - 345 kV	10	-	-
T111 Transco ELNY S4	91	3	29	341	6 - 345 kV	9	-	-
T112 Transco ELNY S5	93	0	29	440	6 - 345 kV	9	-	-
T113 Transco ELNY S6	61	0	58	325	6 - 345 kV 2 - 138 kV	13	2	-
T114 Transco ELNY S7	95	0	29	341	6 - 345 kV 2 - 138 kV	20	2	-
T115 Transco ELNY S8	55	0	58	325	4 - 345 kV	35	-	-
T116 Transco ELNY S9	55	0	59	419	4 - 345 kV	35	-	-
T117 Transco ELNY S10	108	0	29	438	6 - 345 kV 2 - 138 kV	20	2	-

Major Equipment Information								
Project	HVAC Cable Terrestrial Mileage (approx. miles)	HVAC Cable Submarine Mileage (approx. miles)	HVDC Cable Terrestrial Mileage (approx. miles)	HVDC Cable Submarine Mileage (approx. miles)	No. of Proposed 345 kV/138 kV PARs	No. of 345 kV Breakers	No. of 345-138 kV Transformers	No. of 138 kV Breakers
T118 NYPA/LSP FBEC – Mint	15	4	4	262	1 - 345 kV	12	-	-
T119 NYPA/LSP FBEC – Sage	14	5	8	412	1 - 345 kV	19	-	-
T120 NYPA/LSP FBEC – Olive	14	6	4	608	1 - 345 kV	21	-	-
T121 NYPA/LSP FBEC – Kelly	19	6	7	603	2 - 345 kV	22	-	-
T122 NYPA/LSP FBEC – Hazel	14	6	7	356	1 - 345 kV	21	-	-
T123 NYPA/LSP FBEC – Navy	9	4	11	396	2 - 345 kV 1- 138 kV	21	-	-
T124 NYPA/LSP FBEC – Royal	19	7	11	501	2 - 345 kV 1- 138 kV	30	-	-
T125 NYPA/LSP FBEC – Cobalt	14	6	11	696	1 - 345 kV 1- 138 kV	29	-	-
T126 NYPA/LSP FBEC – Ruby	14	5	4	413	1 - 345 kV	18	-	-
T127 NYPA/LSP FBEC – Rose	14	5	4	262	1 - 345 kV	18	-	-
T128 NYPA/LSP FBEC – Honey	15	5	4	504	3 - 345 kV	24	2	8
T129 NYPA/LSP FBEC – Golden	14	17	0	789	3 - 345 kV	39	2	8

Preliminary Evaluation Results

OSW Injection: Assumptions

	OSW Injection	
	Summer Peak	Spring Light Load
Zone J Seasonal Peak Load	~11,310 MW	~4,773 MW
Zone J Total OSW Capacity	816 MW	
Empire Wind 1 (J) Gowanus 345 kV	816 MW	
OSW Generation	Pre-Project: 0 MW Post-Project: As proposed by developer	
Zone K Total OSW Capacity	3,895 MW	
South Fork Wind (K) East Hampton 69 kV	139 MW	
Sunrise Wind (K) Holbrook 138 kV	880 MW	
Empire Wind 2 (K) Barrett 138 kV	1,260 MW	
Additional (i.e., non-awarded, K): Ruland Road 138 kV	800 MW	
Renewable Build Out	70% by 2030 build out based on 2021-2040 Outlook Projects that have accepted and posted Security for its cost allocation in Class Year '21	

OSW Injection: Assumptions

	OSW Injection	
	Summer Peak	Spring Light Load
Zone J Local Transmission Plan Projects (Firm)	Brooklyn Clean Energy Hub 345 kV	
	Eastern Queens Substation 138 kV	
	4th Gowanus - Greenwood 138 kV Feeder	
Transmission Projects		
T051 Propel Alternate Solution 5	Yes	Yes
Champlain-Hudson Power Express	~600 MW*	0 MW
Clean Path NY	0 MW	0 MW
NYC Import Schedules		
HTP	0 MW	
Linden VFT	311 MW	
ConEd-LIPA-Wheel	300 MW	
Pre-Contingency Rating	Normal	
Post-Contingency Rating	LTE	

*Based on the document filed by PSC on February 14, 2024 available at the following [location](#).

Production Cost Savings

Production Cost: Assumptions

■ Key considerations for the production cost database:

- 2023-2042 System & Resource Outlook's Policy Case: Higher Demand Scenario is the starting point for the NYC PPTN evaluation cases
 - Details on the assumptions from the 2023-2042 System & Resource Outlook can be found in the [Outlook Data Catalog](#)
- Updated generation assumptions (i.e., firm new generators and generator retirements)
 - Included generation from Class Year 2021 (e.g., batteries, UPV, LBW)
 - Included OSW generation to align with the PSC Order identifying the NYC PPTN
 - Updated fossil retirements to align with the 2023 Q3 through 2024 Q4 STAR reports
 - Replaced the [generic solution](#) to 2023 Q2 STAR need, as assumed in the 2023-2042 Outlook, with the [retention of the peaker generators on the Gowanus 2 & 3 and Narrows 1 & 2 barges](#)
- Updated the network model to align with other analyses in the NYC PPTN evaluation
 - Added Dover PARs, Hillside PARs, and 3rd Gowanus-Greenwood PAR
 - Added 4th Gowanus-Greenwood 345/138 kV PAR controlled feeder (2025 ConEd LTP)
- Added limiting contingencies within Zone J (NYC) as identified by N-1 analysis to align with other analyses in the OSW injection metric

Production Cost

- Represents the societal cost of producing electricity to meet New York electricity demand
- NYISO adjusts for import cost and export “revenue” and designates the adjusted metric as the “NYCA Wide Production Cost”

$$\text{Annual NYCA Wide Production Cost} = \sum_{\text{hour } 1}^{\text{hour } 8760} \text{Fuel} + \text{VOM} + \text{Emissions} + \text{Net Import Cost}$$

Note: Import cost is negative if exporting, which looks like a “revenue.” Import/export transactions are priced using LBMP at a proxy node.