

Tailored Availability Metric

Emily Conway

Associate, Capacity Market Design

ICAPWG/MIWG

July 24th, 2019



Agenda

- **Recap**
- **Purpose of Discussion**
- **Background**
- **Analysis**
- **Next Steps & Schedule**

Recap

Recap

- For availability-based resources, stakeholders encouraged the NYISO to evaluate an hourly weighting of the EFORd calculation in order to more accurately reflect availability of the resources
- Previous analysis focused on statistics that represented start time and duration of forced outages, forced derates, and failed starts in Combustion Turbines (CTs), Combined Cycles (CCs) and Steam Turbines (STs)
 - See Appendix

Purpose of Discussion



Purpose of Discussion

- **The purpose of this presentation is to discuss the additional analysis done for availability-based resources using the EFORd to determine the Seasonal Derating Factor (AEFORd)**
 - We will come back at a future Working Group meeting with discussion and analysis for performance-based resources

Background




EFORd Background

- The Equivalent Forced Outage Rate demand (EFORd) is defined as the portion of time a unit is in demand, but is unavailable due to forced outages and forced derates
- The NYISO uses the calculated EFORd in order to measure the amount of Unforced Capacity a unit is allowed to sell
 - $UCAP = \text{Available ICAP} * (1 - AEFORd)$
 - A higher EFORd value results in less UCAP for the unit, and a lower EFORd value will result in more UCAP

EFORd Background

- The current methodology for calculating a Capability Period AEFORd is the average of six consecutive (rolling) 12-month EFORd calculations
- For a Summer Capability Period AEFORd, the value is calculated based on the following months:



EFORd Background

- **Currently, for the Summer Capability Period AEFORd, the summer peak months (June, July, and August) account for 25% of the weight of the calculation**
 - This means that 75% of the weight of the calculation for a Summer Capability Period AEFORd is measured based off of data from peak winter months and shoulder months

EFORd Calculation

- The EFORd equation looks at 7 different inputs to calculate the value
- **Event Hours:**
 - Service Hours (SH) – sum of all Unit Service Hours
 - Reserve Shutdown Hours (RSH) – sum of all Unit Reserve Shutdown Hours
 - Forced Outage Hours (FOH) – sum of all hours experienced during Forced Outages or Startup Failure
 - Equivalent Forced Derated Hours (EFDH) – the sum of all forced derating hours multiplied by the size of the reduction (MW), divided by the Net Maximum Capacity (NMC)
- **Event Counts:**
 - Number of Forced Outage Events
 - Number of Attempted Start Events
 - Number of Actual Start Events

EFORd Calculation

$$EFORd = \frac{f_f \times FOH + f_p \times (EFDH)}{SH + f_f \times FOH}$$

$$f_f = \frac{\frac{1}{r} + \frac{1}{T}}{\frac{1}{r} + \frac{1}{T} + \frac{1}{D}} \quad f_p = \frac{SH}{AH}$$

- $r = \text{average forced outage deration} = \frac{FOH}{\text{number of forced outages}}$
- $T = \text{average time between calls for a unit to run} = \frac{RSH}{\text{number of attempted starts}}$
- $D = \text{average run time} = \frac{SH}{\text{number of successful starts}}$

Analysis

Analysis

- **In the analysis completed thus far for availability-based resources, statistics have been compiled that more accurately reflect event data for these different resource types**
 - Heat maps of the data for the Summer Capability Period 2018 for CTs, CCs, and STs shows the percentages of duration and count of the analyzed events
 - See Appendix

Analysis

- **For CTs and CCs, longer duration events have a higher weight in the total number of hours, and shorter duration events have a higher weight in the total count**
 - A unit with a forced outage that lasts 6 months will have a high number of Forced Outage Hours, and one forced outage count
 - A unit with multiple shorter duration outages (i.e., 1 hour) will have a lower number of Forced Outage Hours, and high number of forced outage counts
- **The next analysis shows Forced Outage Hours and Service Hours drive the EFORd calculation, more so than other variables**

Analysis

- **Additional analysis done calculated a total, peak, and non-peak AEFORd for 4 different units**
 - Calculated EFORd values show what potential changes could occur when peak hours are weighted
 - Summer: HB 12 through HB 19
 - Winter: HB 14 through HB 21

EFORd Calculation

- **Generators that use GADS submit data on an event by event basis**
 - Events are reported every minute
 - Service Hours are not submitted but can be calculated by the time in between each reported event
 - A typical event report will include the event type with its respective start and end time stamp, as well as the derating amount each event has on the unit
- **By assigning timestamps, events can be separated into peak and non-peak hours**
 - Summer: HB 12 through HB 19
 - Winter: HB 14 through HB 21

EFORd Calculation

- **Using the existing methodology to calculate the NYISO EFORd, a total, peak, and non-peak Seasonal Derating Factor can be calculated**
 - The data analyzed calculated an AEFORd for Summer Capability Period 2018
 - Using the rolling 12-month average of the current model, this looked at data from August 2016 to December 2017
- **Using this process, the NYISO analyzed 3 peaker gas turbine units, and 1 steam turbine weighting the peak EFORd**
 - GT Units 1 and 2 recorded a high EFORd
 - GT Unit 3 recorded an extremely low EFORd
 - ST Unit 4 recorded a low EFORd

Gas Turbine Unit 1

| Calc No. | EFORd | Peak | Non-Peak | Weighted (1:2) | Weighted (2:2) | Weighted (3:2) | Weighted (4:2) |
|-------------------|-------|-------|----------|----------------|----------------|----------------|----------------|
| 1 | 20.89 | 19.88 | 25.13 | 23.38 | 22.51 | 21.98 | 21.63 |
| 2 | 16.59 | 15.73 | 20.03* | 18.60 | 17.88 | 17.45 | 17.16 |
| 3 | 13.32 | 12.08 | 17.20 | 15.49 | 14.64 | 14.12 | 13.78 |
| 4 | 10.62 | 8.90 | 14.97 | 12.94 | 11.93 | 11.33 | 10.92 |
| 5 | 11.44 | 9.62 | 15.77 | 13.72 | 12.70 | 12.08 | 11.67 |
| 6 | 12.70 | 10.15 | 49.42 | 36.33 | 29.78 | 25.86 | 23.24 |
| AEFORd (%) | 14.26 | 12.73 | 23.75 | 20.08 | 18.24 | 17.14 | 16.40 |

- The weighting shows the ratio of peak to non-peak
 - For example: (1 peak: 2 non-peak)

* Correction to original posted value

| Weighting | |
|-------------|---|
| Peak | 1 |
| Non-Peak | 2 |
| Denominator | 3 |
| Peak | 2 |
| Non-Peak | 2 |
| Denominator | 4 |
| Peak | 3 |
| Non-Peak | 2 |
| Denominator | 5 |
| Peak | 4 |
| Non-Peak | 2 |
| Denominator | 6 |

Gas Turbine Unit 2

| Calc No. | EFORd | Peak | Non-Peak | Weighted (1:2) | Weighted (2:2) | Weighted (3:2) | Weighted (4:2) |
|-------------------|-------|-------|----------|-------------------|-------------------|-------------------|-------------------|
| 1 | 21.71 | 16.57 | 35.94 | 29.49 | 26.26 | 24.32 | 23.03 |
| 2 | 13.02 | 11.00 | 30.55 | 24.04 | 20.78 | 18.82 | 17.52 |
| 3 | 6.10 | 2.65 | 18.10 | 12.95 | 10.37 | 8.83 | 7.80 |
| 4 | 0.43 | 0.36 | 0.67 | 0.57 | 0.52 | 0.49 | 0.46 |
| 5 | 9.76 | 8.95 | 15.25 | 13.15 | 12.10 | 11.47 | 11.05 |
| 6 | 18.01 | 17.27 | 23.00 | 21.09 | 20.13 | 19.56 | 19.18 |
| AEFORd (%) | 11.51 | 9.47 | 20.59 | 16.88 | 15.03 | 13.92 | 13.17 |

| Weighting | |
|-------------|---|
| Peak | 1 |
| Non-Peak | 2 |
| Denominator | 3 |
| | |
| Peak | 2 |
| Non-Peak | 2 |
| Denominator | 4 |
| | |
| Peak | 3 |
| Non-Peak | 2 |
| Denominator | 5 |
| | |
| Peak | 4 |
| Non-Peak | 2 |
| Denominator | 6 |

Gas Turbine Unit 3

| Calc No. | EFORd | Peak | Non-Peak | Weighted (1:2) | Weighted (2:2) | Weighted (3:2) | Weighted (4:2) |
|-------------------|-------|------|----------|-------------------|-------------------|-------------------|-------------------|
| 1 | 1.75 | 1.57 | 1.91 | 1.80 | 1.74 | 1.70 | 1.68 |
| 2 | 1.70 | 1.47 | 2.03 | 1.84 | 1.75 | 1.69 | 1.66 |
| 3 | 1.75 | 1.61 | 1.93 | 1.82 | 1.77 | 1.74 | 1.72 |
| 4 | 1.78 | 1.63 | 1.99 | 1.87 | 1.81 | 1.77 | 1.75 |
| 5 | 1.80 | 1.63 | 2.01 | 1.89 | 1.82 | 1.79 | 1.76 |
| 6 | 2.08 | 1.88 | 2.16 | 2.07 | 2.02 | 2.00 | 1.98 |
| AEFORd (%) | 1.81 | 1.63 | 2.01 | 1.88 | 1.82 | 1.78 | 1.76 |

| Weighting | |
|-------------|---|
| Peak | 1 |
| Non-Peak | 2 |
| Denominator | 3 |
| | |
| Peak | 2 |
| Non-Peak | 2 |
| Denominator | 4 |
| | |
| Peak | 3 |
| Non-Peak | 2 |
| Denominator | 5 |
| | |
| Peak | 4 |
| Non-Peak | 2 |
| Denominator | 6 |

Steam Turbine Unit 4

| Calc No. | EFORd | Peak | Non-Peak | Weighted (1:2) | Weighted (2:2) | Weighted (3:2) | Weighted (4:2) |
|-------------------|-------|------|----------|-------------------|-------------------|-------------------|-------------------|
| 1 | 5.96 | 6.01 | 5.98 | 5.99 | 6.00 | 6.00 | 6.00 |
| 2 | 6.55 | 6.56 | 6.61 | 6.59 | 6.59 | 6.58 | 6.58 |
| 3 | 6.75 | 6.76 | 6.83 | 6.80 | 6.79 | 6.79 | 6.78 |
| 4 | 4.93 | 4.93 | 4.97 | 4.96 | 4.95 | 4.95 | 4.94 |
| 5 | 4.35 | 4.35 | 4.38 | 4.37 | 4.37 | 4.36 | 4.36 |
| 6 | 4.06 | 4.07 | 4.08 | 4.08 | 4.07 | 4.07 | 4.07 |
| AEFORd (%) | 5.43 | 5.45 | 5.48 | 5.47 | 5.46 | 5.46 | 5.46 |

| Weighting | |
|-------------|---|
| Peak | 1 |
| Non-Peak | 2 |
| Denominator | 3 |
| | |
| Peak | 2 |
| Non-Peak | 2 |
| Denominator | 4 |
| | |
| Peak | 3 |
| Non-Peak | 2 |
| Denominator | 5 |
| | |
| Peak | 4 |
| Non-Peak | 2 |
| Denominator | 6 |

Conclusions

- **The driving force behind the EFORd calculation is the Service Hours in relation to the Forced Outage Hours**
 - For these three peaker plants, Service Hours typically occur during Peak Hours
 - If an outage occurs that has a long duration (e.g., 1 month), it will drive the non-peak EFORd up due to the fact that the peaking units typically record less Service Hours during non-peak periods

Conclusions

- For example, one 12-month EFORd recorded for Unit 1:

| | SH | FOH | PH | EFORd (%) |
|----------|------|-------|------|-----------|
| Peak | 61.3 | 58.6 | 2920 | 16.6 |
| Non-Peak | 9.1 | 142.1 | 5840 | 35.9 |

| | |
|-----|---------------------|
| SH | Service Hours |
| FOH | Forced Outage Hours |
| PH | Period Hours |

- Under a weighting methodology, if the non-peak EFORd is much higher than the peak EFORd, the results show the total AEFORd value increases

Conclusions

- At this time, the NYISO believes the current structure of the EFORd calculation captures the incentive to be available during peak hours

Market Design Concept Proposal

- **The NYISO proposes to weight peak months more heavily in the EFORd calculation**
 - Peak months are currently weighted 25% in the existing Capability Period AEFORd calculation
 - Summer Peak months: June, July, and August
 - Winter Peak months: December, January, and February
- **Monthly weightings will be analyzed as a part of the Market Design Complete**

Next Steps & Schedule



Next Steps

- The NYISO will begin detailed discussion of assessing performance-based resources at a later working group meeting

Schedule

■ Stakeholder Engagement Plan:

- This meeting - July, 2019: Discussion of Analysis
- August – September, 2019: Discussion of Analysis and Results of Analysis
- September, 2019: Market Design Concept Proposal for performance-based resources
- 2020: Market Design Complete

Feedback/Questions?

- The NYISO will consider input received during today's Working Group meeting and further input sent in writing to deckles@nyiso.com and econway@nyiso.com

Appendix

Resource Type

| Resource Type | Availability-Based | Performance-Based |
|---------------------------|--------------------|-------------------|
| Most Generation | X | |
| Dispatchable DER | X | |
| ESRs | X | |
| Intermittent Resources | | X |
| Limited Control RoR Hydro | | X |
| SCRs | | X |

ICAP Manual Attachment J

- ICAP Manual Link

- (https://www.nyiso.com/documents/20142/2923301/icap_mnl.pdf/)

- $UCAP = (1 - EFORd) \times DMNC$

- $EFORd = \frac{f_f \times FOH + f_p \times (EFDH)}{SH + f_f \times FOH}$

- $f_f = \frac{\frac{1}{r} + \frac{1}{T}}{\frac{1}{r} + \frac{1}{T} + \frac{1}{D}}$

ICAP Manual Attachment J

- $r = \text{average forced outage duration} = \frac{FOH}{\text{number of forced outages}}$
- $T = \text{average time between calls for a unit to run} = \frac{RSH}{\text{number of attempted starts}}$
- $D = \text{average run time} = \frac{SH}{\text{number of successful starts}}$
- $f_p = \frac{SH}{AH}$

ICAP Manual Attachment J

- $f_f = \text{full } f - \text{factor}$
- $f_p = \text{partial } f - \text{factor}$
- $FOH = \text{(Full) Forced Outage Hours}$
- $EFDH = \text{Equivalent Forced Derated Hours}$
- $SH = \text{Service Hours; time a unit is electrically connected to the system}$
- $AH = \text{Available Hours; time a unit is capable of producing energy, regardless of capacity level}$
- $RSH = \text{Reserve Shutdown Hours; time a unit is available for service but not dispatched}$
- $PH = \text{Period Hours; 24 times the number of days in the reporting period}$

UOL Calculation

- **Derating Factors for Energy Storage Resources will be calculated based upon a time-weighted UOL availability evaluated against the ICAP sold**
 - For each RTD interval that the UOL is adjusted down due to a NYISO or a TO reliability need, the NYISO will replace the UOL with the bid UOL
 - The Normal UOL will have a floor of 0 and be capped against the ICAP Sold, and the number of seconds will be calculated for that interval
 - For the intervals where the unit was on a planned or scheduled outage approved by NYISO operations, the seconds will be set to 0, removing it from the calculation


UOL Calculation

- **Derating Factors for Energy Storage Resources will be calculated based upon a time-weighted UOL availability evaluated against the ICAP sold**
 - For each month, 4 values will be calculated
 - Total Seconds – Sum of seconds in the month that the unit was not on an approved outage
 - Total Available Capacity – Sum of (Normal UOL for interval * seconds in interval) for the month
 - Total Expected Capacity – ICAP sold * Total Seconds
 - Monthly Availability – Total Available Capacity / Total Expected Capacity

UOL Calculation

- 12-month blocks will be calculated, summing the Total Available Capacity, the Total Expected Capacity, and the availability calculation for the 12-month block
- The Derating Factor for Energy Storage Resources will be the average of 6 of the 12-month blocks
 - These will be the same 12-month blocks used in the existing EFORd calculation
 - Derating Factor to determine Summer UCAP uses a 12 month period ending in July, August, September, October, November, and December from the prior year
 - Derating Factor to determine Winter UCAP uses a 12 month period ending in January, February, March, April, May, and June from the current year
 - Derating Factor = $1 - \text{Availability Factor}$


Event Start Time - CT



Class Average EFORd:
9.05 %

FO = Forced Outage
D = Derate
SF = Startup Failure


Event Start Time - CC



Class Average EFORD:
3.72 %

FO = Forced Outage
D = Derate
SF = Startup Failure

Event Start Time - ST




Class Average EFORd:
7.96 %

FO = Forced Outage
D = Derate
SF = Startup Failure


Duration of Events - CT

Peak Summer Months



■ Peak Summer Months ■ Non-Peak Months

Peak Hours




■ Peak Hours ■ Non-Peak Hours




Duration of Events - CC

Peak Summer Months




Peak Hours




Duration of Events - ST

Peak Summer Months



Peak Hours



GTs – Forced Outages

| Hour | Total Forced Outage Hours | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 1% | 0% | 2% | 3% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 7 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 8 | 0% | 0% | 0% | 0% | 0% | 18% | 19% |
| 9 | 0% | 0% | 0% | 0% | 0% | 30% | 30% |
| 10 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 11 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 12 | 0% | 0% | 0% | 0% | 0% | 1% | 2% |
| 13 | 0% | 0% | 0% | 0% | 0% | 1% | 2% |
| 14 | 0% | 0% | 0% | 0% | 0% | 3% | 3% |
| 15 | 0% | 0% | 0% | 0% | 0% | 5% | 6% |
| 16 | 0% | 0% | 0% | 0% | 0% | 4% | 4% |
| 17 | 0% | 0% | 0% | 0% | 1% | 1% | 2% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 19 | 0% | 0% | 0% | 0% | 1% | 1% | 2% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 22 | 0% | 0% | 0% | 0% | 0% | 6% | 6% |
| 23 | 0% | 0% | 0% | 0% | 0% | 15% | 15% |
| Total | 0% | 0% | 0% | 4% | 4% | 91% | |

| Hour | Total Forced Outage Count | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 6% | 1% | 1% | 8% |
| 1 | 0% | 0% | 1% | 0% | 1% | 0% | 2% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 2% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 6 | 1% | 0% | 0% | 1% | 0% | 0% | 2% |
| 7 | 1% | 1% | 1% | 1% | 0% | 0% | 4% |
| 8 | 3% | 1% | 0% | 1% | 0% | 1% | 6% |
| 9 | 2% | 0% | 0% | 2% | 0% | 1% | 4% |
| 10 | 2% | 0% | 0% | 1% | 0% | 0% | 4% |
| 11 | 1% | 0% | 0% | 1% | 0% | 0% | 3% |
| 12 | 1% | 1% | 0% | 1% | 0% | 1% | 4% |
| 13 | 2% | 4% | 1% | 1% | 1% | 0% | 9% |
| 14 | 3% | 0% | 0% | 0% | 0% | 1% | 4% |
| 15 | 4% | 1% | 1% | 0% | 0% | 1% | 8% |
| 16 | 2% | 1% | 0% | 1% | 1% | 1% | 5% |
| 17 | 4% | 0% | 1% | 3% | 1% | 0% | 10% |
| 18 | 2% | 0% | 1% | 3% | 0% | 0% | 7% |
| 19 | 2% | 0% | 0% | 0% | 1% | 1% | 6% |
| 20 | 1% | 0% | 0% | 0% | 0% | 0% | 2% |
| 21 | 0% | 0% | 0% | 1% | 1% | 0% | 2% |
| 22 | 1% | 0% | 0% | 0% | 0% | 0% | 2% |
| 23 | 0% | 1% | 0% | 1% | 1% | 1% | 4% |
| Total | 34% | 12% | 6% | 27% | 10% | 11% | |

GTs – Forced Derates

| Hour | Total Derating Hours | | | | | | Total |
|--------------|----------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 56% | 56% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 1% | 0% | 1% |
| 7 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 8 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 10 | 0% | 0% | 0% | 0% | 0% | 1% | 2% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 13 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 14 | 0% | 0% | 0% | 0% | 0% | 32% | 32% |
| 15 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 16 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 17 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 0% | 0% | 0% | 1% | 3% | 96% | |

| Hour | Total Derate Count | | | | | | Total |
|--------------|--------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 3% | 3% |
| 1 | 5% | 0% | 0% | 0% | 0% | 0% | 5% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 1% | 0% | 1% | 3% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 1% | 0% | 0% | 1% | 3% | 0% | 5% |
| 7 | 3% | 0% | 0% | 1% | 1% | 0% | 5% |
| 8 | 3% | 0% | 0% | 0% | 1% | 1% | 5% |
| 9 | 1% | 0% | 0% | 1% | 1% | 0% | 4% |
| 10 | 3% | 1% | 1% | 3% | 3% | 1% | 11% |
| 11 | 3% | 0% | 0% | 0% | 1% | 0% | 4% |
| 12 | 1% | 0% | 0% | 1% | 0% | 1% | 4% |
| 13 | 3% | 1% | 1% | 1% | 0% | 0% | 6% |
| 14 | 5% | 0% | 1% | 1% | 0% | 1% | 9% |
| 15 | 3% | 0% | 0% | 0% | 1% | 1% | 5% |
| 16 | 5% | 0% | 0% | 1% | 0% | 1% | 8% |
| 17 | 4% | 1% | 0% | 1% | 0% | 1% | 8% |
| 18 | 6% | 0% | 0% | 0% | 0% | 0% | 6% |
| 19 | 1% | 0% | 0% | 0% | 0% | 1% | 3% |
| 20 | 3% | 0% | 0% | 0% | 0% | 0% | 3% |
| 21 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 22 | 1% | 0% | 0% | 0% | 1% | 0% | 3% |
| 23 | 3% | 0% | 0% | 0% | 0% | 0% | 3% |
| Total | 53% | 4% | 4% | 14% | 13% | 14% | |

GTs – Startup Failures

| Hour | Total Startup Failure Hours | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 1% | 1% | 0% | 2% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 2% | 3% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 7 | 0% | 0% | 0% | 0% | 0% | 3% | 3% |
| 8 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 9 | 0% | 0% | 0% | 0% | 2% | 0% | 3% |
| 10 | 0% | 0% | 0% | 0% | 1% | 2% | 3% |
| 11 | 0% | 0% | 0% | 0% | 0% | 10% | 10% |
| 12 | 0% | 0% | 0% | 0% | 1% | 2% | 3% |
| 13 | 0% | 0% | 0% | 0% | 1% | 6% | 7% |
| 14 | 0% | 0% | 0% | 0% | 0% | 7% | 8% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 1% | 10% | 12% |
| 17 | 0% | 0% | 0% | 0% | 1% | 16% | 18% |
| 18 | 0% | 0% | 0% | 0% | 1% | 3% | 4% |
| 19 | 0% | 0% | 0% | 0% | 1% | 11% | 13% |
| 20 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 21 | 0% | 0% | 0% | 0% | 1% | 1% | 2% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 1% | 4% | 5% |
| Total | 1% | 1% | 1% | 4% | 12% | 81% | |

| Hour | Total Startup Failure Count | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 1% | 0% | 1% | 1% | 0% | 3% |
| 1 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 5 | 1% | 0% | 0% | 0% | 0% | 0% | 2% |
| 6 | 5% | 0% | 0% | 0% | 0% | 0% | 5% |
| 7 | 3% | 0% | 0% | 0% | 0% | 0% | 3% |
| 8 | 2% | 0% | 0% | 0% | 0% | 0% | 2% |
| 9 | 1% | 1% | 1% | 2% | 3% | 0% | 8% |
| 10 | 3% | 1% | 0% | 2% | 0% | 0% | 7% |
| 11 | 3% | 1% | 1% | 0% | 0% | 1% | 6% |
| 12 | 1% | 0% | 1% | 1% | 1% | 1% | 5% |
| 13 | 3% | 1% | 0% | 0% | 0% | 1% | 5% |
| 14 | 2% | 1% | 0% | 0% | 0% | 1% | 4% |
| 15 | 5% | 0% | 0% | 0% | 0% | 0% | 6% |
| 16 | 6% | 2% | 0% | 1% | 1% | 1% | 12% |
| 17 | 3% | 0% | 1% | 2% | 1% | 1% | 8% |
| 18 | 5% | 0% | 0% | 0% | 0% | 0% | 6% |
| 19 | 1% | 0% | 0% | 0% | 1% | 1% | 4% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 21 | 3% | 0% | 0% | 0% | 1% | 0% | 5% |
| 22 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 23 | 1% | 0% | 0% | 0% | 1% | 0% | 3% |
| Total | 48% | 11% | 5% | 14% | 12% | 10% | |

CCs – Forced Outages

| Hour | Total Forced Outage Hours | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 1% | 5% | 6% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 3 | 0% | 0% | 0% | 0% | 0% | 2% | 2% |
| 4 | 0% | 0% | 0% | 1% | 0% | 8% | 10% |
| 5 | 0% | 0% | 0% | 1% | 1% | 4% | 6% |
| 6 | 0% | 0% | 0% | 1% | 0% | 0% | 2% |
| 7 | 0% | 0% | 0% | 0% | 1% | 0% | 2% |
| 8 | 0% | 0% | 0% | 1% | 1% | 0% | 2% |
| 9 | 0% | 0% | 0% | 1% | 0% | 0% | 2% |
| 10 | 0% | 0% | 0% | 1% | 1% | 21% | 22% |
| 11 | 0% | 0% | 0% | 1% | 0% | 3% | 5% |
| 12 | 0% | 0% | 0% | 1% | 0% | 7% | 9% |
| 13 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 14 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 15 | 0% | 0% | 0% | 1% | 0% | 6% | 7% |
| 16 | 0% | 0% | 0% | 0% | 0% | 3% | 4% |
| 17 | 0% | 0% | 0% | 0% | 0% | 3% | 3% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 2% | 2% |
| 20 | 0% | 0% | 0% | 0% | 0% | 3% | 4% |
| 21 | 0% | 0% | 0% | 0% | 0% | 3% | 4% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 5% | 5% |
| Total | 2% | 3% | 2% | 11% | 7% | 76% | |

| Hour | Total Forced Outage Count | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 1% | 1% | 2% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 2 | 0% | 1% | 0% | 0% | 0% | 0% | 1% |
| 3 | 1% | 0% | 0% | 0% | 0% | 0% | 3% |
| 4 | 1% | 0% | 0% | 1% | 0% | 0% | 4% |
| 5 | 1% | 1% | 0% | 2% | 0% | 0% | 6% |
| 6 | 2% | 2% | 1% | 2% | 0% | 0% | 8% |
| 7 | 2% | 1% | 0% | 0% | 1% | 0% | 5% |
| 8 | 3% | 2% | 0% | 1% | 1% | 0% | 8% |
| 9 | 3% | 1% | 0% | 2% | 0% | 0% | 7% |
| 10 | 3% | 0% | 1% | 2% | 0% | 2% | 9% |
| 11 | 2% | 1% | 0% | 1% | 0% | 0% | 6% |
| 12 | 0% | 1% | 1% | 3% | 0% | 0% | 7% |
| 13 | 1% | 1% | 0% | 1% | 0% | 0% | 5% |
| 14 | 0% | 1% | 0% | 1% | 0% | 0% | 4% |
| 15 | 2% | 0% | 0% | 1% | 0% | 1% | 5% |
| 16 | 1% | 2% | 0% | 0% | 0% | 0% | 5% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 2% |
| 18 | 0% | 1% | 0% | 0% | 0% | 0% | 1% |
| 19 | 0% | 1% | 0% | 0% | 0% | 0% | 3% |
| 20 | 1% | 1% | 0% | 1% | 0% | 0% | 4% |
| 21 | 0% | 0% | 1% | 1% | 0% | 1% | 3% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 2% |
| 23 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| Total | 29% | 22% | 9% | 24% | 6% | 10% | |

CCs – Forced Derates

| Hour | Total Derating Hours | | | | | | Total |
|--------------|----------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 1% | 1% | 10% | 12% |
| 1 | 0% | 0% | 0% | 0% | 0% | 3% | 4% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 1% | 1% | 0% | 2% |
| 5 | 0% | 0% | 0% | 2% | 1% | 3% | 6% |
| 6 | 0% | 0% | 0% | 1% | 1% | 3% | 5% |
| 7 | 0% | 0% | 0% | 2% | 1% | 7% | 11% |
| 8 | 0% | 0% | 0% | 0% | 1% | 5% | 7% |
| 9 | 0% | 0% | 0% | 1% | 0% | 1% | 2% |
| 10 | 0% | 0% | 0% | 1% | 2% | 9% | 12% |
| 11 | 0% | 0% | 0% | 1% | 2% | 0% | 3% |
| 12 | 0% | 0% | 0% | 0% | 1% | 0% | 2% |
| 13 | 0% | 0% | 0% | 1% | 0% | 2% | 3% |
| 14 | 0% | 0% | 0% | 1% | 0% | 1% | 2% |
| 15 | 0% | 0% | 0% | 0% | 0% | 2% | 3% |
| 16 | 0% | 0% | 0% | 1% | 1% | 0% | 3% |
| 17 | 0% | 0% | 0% | 1% | 1% | 0% | 2% |
| 18 | 0% | 0% | 0% | 1% | 0% | 4% | 5% |
| 19 | 0% | 0% | 0% | 0% | 0% | 1% | 3% |
| 20 | 0% | 0% | 0% | 0% | 0% | 1% | 1% |
| 21 | 0% | 0% | 0% | 0% | 2% | 0% | 2% |
| 22 | 0% | 0% | 0% | 1% | 2% | 6% | 9% |
| 23 | 0% | 0% | 0% | 0% | 1% | 1% | 2% |
| Total | 2% | 3% | 3% | 15% | 19% | 59% | |

| Hour | Total Derate Count | | | | | | Total |
|--------------|--------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 1% | 1% | 0% | 1% | 0% | 1% | 3% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 2 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 3 | 1% | 0% | 0% | 0% | 0% | 0% | 2% |
| 4 | 1% | 0% | 0% | 1% | 0% | 0% | 3% |
| 5 | 1% | 0% | 1% | 3% | 0% | 0% | 7% |
| 6 | 2% | 1% | 0% | 2% | 1% | 1% | 6% |
| 7 | 4% | 2% | 1% | 3% | 1% | 1% | 12% |
| 8 | 3% | 1% | 1% | 1% | 1% | 0% | 6% |
| 9 | 4% | 1% | 0% | 1% | 0% | 0% | 8% |
| 10 | 2% | 1% | 0% | 1% | 1% | 1% | 6% |
| 11 | 1% | 1% | 0% | 2% | 1% | 0% | 5% |
| 12 | 2% | 0% | 0% | 0% | 1% | 0% | 4% |
| 13 | 2% | 1% | 1% | 1% | 0% | 0% | 5% |
| 14 | 1% | 0% | 0% | 1% | 0% | 0% | 3% |
| 15 | 2% | 1% | 0% | 1% | 0% | 0% | 4% |
| 16 | 3% | 0% | 0% | 2% | 1% | 0% | 5% |
| 17 | 1% | 0% | 0% | 1% | 1% | 0% | 3% |
| 18 | 1% | 1% | 0% | 1% | 0% | 0% | 4% |
| 19 | 2% | 1% | 1% | 0% | 0% | 0% | 4% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 21 | 0% | 0% | 1% | 0% | 1% | 0% | 2% |
| 22 | 0% | 0% | 0% | 1% | 1% | 1% | 3% |
| 23 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| Total | 36% | 15% | 9% | 23% | 10% | 7% | |

CCs – Startup Failures

| Hour | Total Startup Failure Hours | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 10% | 0% | 0% | 0% | 10% |
| 3 | 2% | 0% | 5% | 13% | 0% | 0% | 20% |
| 4 | 0% | 3% | 0% | 7% | 0% | 0% | 10% |
| 5 | 2% | 6% | 0% | 10% | 0% | 0% | 19% |
| 6 | 1% | 0% | 5% | 0% | 0% | 0% | 6% |
| 7 | 1% | 3% | 0% | 8% | 0% | 0% | 12% |
| 8 | 2% | 4% | 0% | 0% | 0% | 0% | 6% |
| 9 | 0% | 3% | 0% | 0% | 0% | 0% | 3% |
| 10 | 0% | 7% | 0% | 0% | 0% | 0% | 7% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 6% | 0% | 0% | 0% | 6% |
| 14 | 2% | 0% | 0% | 0% | 0% | 0% | 2% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 9% | 27% | 26% | 38% | 0% | 0% | |

| Hour | Total Startup Failure Count | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 8% | 0% | 0% | 0% | 8% |
| 3 | 4% | 0% | 4% | 4% | 0% | 0% | 12% |
| 4 | 0% | 4% | 0% | 4% | 0% | 0% | 8% |
| 5 | 8% | 8% | 0% | 4% | 0% | 0% | 19% |
| 6 | 4% | 0% | 4% | 0% | 0% | 0% | 8% |
| 7 | 8% | 4% | 0% | 4% | 0% | 0% | 15% |
| 8 | 8% | 4% | 0% | 0% | 0% | 0% | 12% |
| 9 | 0% | 4% | 0% | 0% | 0% | 0% | 4% |
| 10 | 0% | 8% | 0% | 0% | 0% | 0% | 8% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 4% | 0% | 0% | 0% | 4% |
| 14 | 4% | 0% | 0% | 0% | 0% | 0% | 4% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 35% | 31% | 19% | 15% | 0% | 0% | |

STs – Forced Outages

| Hour | Total Forced Outage Hours | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 8% | 0% | 0% | 8% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 5% | 0% | 0% | 0% | 0% | 5% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 24% | 0% | 0% | 24% |
| 7 | 1% | 7% | 0% | 14% | 0% | 0% | 22% |
| 8 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 10 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 14 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 23% | 0% | 0% | 23% |
| 19 | 0% | 0% | 0% | 15% | 0% | 0% | 15% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 4% | 0% | 0% | 0% | 0% | 4% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 1% | 16% | 0% | 83% | 0% | 0% | |

| Hour | Total Forced Outage Count | | | | | | Total |
|--------------|---------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 10% | 0% | 0% | 10% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 10% | 0% | 0% | 0% | 0% | 10% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 10% | 0% | 0% | 10% |
| 7 | 10% | 20% | 0% | 10% | 0% | 0% | 40% |
| 8 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 10 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 14 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 10% | 0% | 0% | 10% |
| 19 | 0% | 0% | 0% | 10% | 0% | 0% | 10% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 10% | 0% | 0% | 0% | 0% | 10% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 10% | 40% | 0% | 50% | 0% | 0% | |

STs – Forced Derates

| Hour | Total Derating Hours | | | | | | Total |
|--------------|----------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 1% | 5% | 21% | 27% |
| 1 | 0% | 0% | 0% | 2% | 0% | 0% | 3% |
| 2 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 1% | 0% | 1% |
| 7 | 1% | 0% | 0% | 1% | 0% | 0% | 1% |
| 8 | 0% | 0% | 0% | 0% | 1% | 0% | 2% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 1% |
| 10 | 1% | 0% | 0% | 1% | 0% | 0% | 1% |
| 11 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 0% | 1% | 0% | 40% | 41% |
| 14 | 0% | 0% | 0% | 2% | 3% | 0% | 5% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 17 | 0% | 0% | 0% | 1% | 2% | 0% | 3% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| 20 | 0% | 0% | 0% | 0% | 2% | 0% | 2% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 2% | 3% | 0% | 5% |
| 23 | 0% | 0% | 0% | 1% | 0% | 0% | 1% |
| Total | 4% | 3% | 2% | 14% | 17% | 61% | |

| Hour | Total Derate Count | | | | | | Total |
|--------------|--------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 2% | 0% | 1% | 4% |
| 1 | 2% | 0% | 1% | 3% | 2% | 0% | 5% |
| 2 | 0% | 0% | 1% | 2% | 0% | 0% | 3% |
| 3 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 1% | 1% | 0% | 0% | 0% | 0% | 2% |
| 6 | 0% | 0% | 0% | 0% | 1% | 0% | 1% |
| 7 | 8% | 1% | 0% | 1% | 0% | 0% | 10% |
| 8 | 3% | 2% | 0% | 0% | 1% | 0% | 6% |
| 9 | 9% | 0% | 0% | 1% | 0% | 0% | 10% |
| 10 | 8% | 2% | 0% | 1% | 0% | 0% | 11% |
| 11 | 3% | 2% | 0% | 1% | 0% | 0% | 6% |
| 12 | 2% | 0% | 1% | 0% | 0% | 0% | 3% |
| 13 | 3% | 1% | 0% | 1% | 0% | 2% | 6% |
| 14 | 6% | 1% | 1% | 2% | 1% | 0% | 10% |
| 15 | 3% | 1% | 0% | 0% | 0% | 0% | 3% |
| 16 | 1% | 0% | 0% | 1% | 0% | 0% | 2% |
| 17 | 1% | 2% | 0% | 2% | 1% | 0% | 5% |
| 18 | 2% | 1% | 0% | 0% | 0% | 0% | 3% |
| 19 | 1% | 1% | 0% | 1% | 0% | 0% | 3% |
| 20 | 0% | 0% | 1% | 0% | 1% | 0% | 2% |
| 21 | 1% | 0% | 0% | 0% | 0% | 0% | 1% |
| 22 | 1% | 0% | 0% | 2% | 1% | 0% | 3% |
| 23 | 3% | 0% | 0% | 1% | 0% | 0% | 3% |
| Total | 57% | 13% | 4% | 18% | 7% | 3% | |

STs – Startup Failures

| Hour | Total Startup Failure Hours | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 73% | 0% | 73% |
| 7 | 0% | 0% | 0% | 27% | 0% | 0% | 27% |
| 8 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 10 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 14 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 0% | 0% | 0% | 27% | 73% | 0% | |

| Hour | Total Startup Failure Count | | | | | | Total |
|--------------|-----------------------------|-----------|-----------|------------|-------------|------|-------|
| | ≤ 1 | 1 < X ≤ 2 | 2 < X ≤ 3 | 3 < X ≤ 10 | 10 < X ≤ 24 | 24 < | |
| 0 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 1 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 2 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 3 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 4 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 5 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 6 | 0% | 0% | 0% | 0% | 50% | 0% | 50% |
| 7 | 0% | 0% | 0% | 50% | 0% | 0% | 50% |
| 8 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 9 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 10 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 11 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 12 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 13 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 14 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 15 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 16 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 17 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 18 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 19 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 20 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 21 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 22 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| 23 | 0% | 0% | 0% | 0% | 0% | 0% | 0% |
| Total | 0% | 0% | 0% | 50% | 50% | 0% | |

The Mission of the New York Independent System Operator, in collaboration with its stakeholders, is to serve the public interest and provide benefits to consumers by:

- Maintaining and enhancing regional reliability
- Operating open, fair and competitive wholesale electricity markets
- Planning the power system for the future
- Providing factual information to policy makers, stakeholders and investors in the power system



www.nyiso.com